



DTE Energy®

M3 Appalachia Gathering

April 18, 2017

Director
WVDEP – Division of Air Quality
601 57th Street SE
Charleston, WV 25304

Tracking No. 1Z642A3R0292108736

RE: M3 Appalachia Gathering, LLC
Hamilton Compressor Station (Facility ID No. 061-00206, Permit No. R13-3292)
G35-D Construction Application

To Whom It May Concern:

M3 Appalachia Gathering, LLC (M3) is submitting this G35-D Construction Application to convert the Hamilton Compressor Station's current R13 permit into a G35-D and install new sources at the facility.


Enclosed are one (1) original hard copy and two (2) CDs with PDFs of the application, along with a check for the application fee in the amount of \$4,000. The affidavit of publication for the Class I Legal Advertisement will be forwarded upon receipt.

M3 appreciates your review of this submittal. If you have any questions or comments about the attached information, please contact me at (724) 416-7262.

Respectfully,

Ryan Mathews
Pipeline Engineer

Attachments



PROJECT REPORT
M3 Appalachia Gathering, LLC
Hamilton Compressor Station

G35-D Permit Application

DTE Energy®



TRINITY CONSULTANTS
4500 Brooktree Drive
Suite 103
Wexford, PA 15090
(724) 935-2611

April 2017

Trinity 
Consultants

Environmental solutions delivered uncommonly well

TABLE OF CONTENTS

1. INTRODUCTION	4
1.1. Facility and Project Description	4
1.2. Source Status	5
1.3. G35-D Application Organization	6
2. SAMPLE EMISSION SOURCE CALCULATIONS	7
3. REGULATORY DISCUSSION	9
3.1. PSD and NNSR Source Classification	9
3.2. Title V Operating Permit Program	9
3.3. New Source Performance Standards	10
3.3.1. NSPS Subparts D, Da, Db, and Dc – Steam Generating Units	10
3.3.2. NSPS Subparts K, Ka, and Kb – Storage Vessels for Petroleum Liquids/Volatile Organic Liquids	10
3.3.3. NSPS Subpart GG – Stationary Gas Turbines	10
3.3.4. NSPS Subpart JJJJ – Stationary Spark Ignition Internal Combustion Engines	10
3.3.5. NSPS Subpart KKKK – Stationary Combustion Turbines	11
3.3.6. NSPS Subpart OOOO — Crude Oil and Natural Gas Production, Transmission, and Distribution	11
3.3.7. NSPS Subpart OOOOa — Crude Oil and Natural Gas Facilities	11
3.3.8. Non-Applicability of All Other NSPS	12
3.4. National Emission Standards for Hazardous Air Pollutants	12
3.4.1. NESHAP Subpart HH – Oil and Natural Gas Production Facilities	12
3.4.2. NESHAP Subpart ZZZZ – Stationary Reciprocating Internal Combustion Engines	12
3.4.3. NESHAP JJJJJ – Industrial, Commercial, and Institutional Boilers	13
3.5. West Virginia SIP Regulations	13
3.5.1. 45 CSR 2: To Prevent and Control Particulate Air Pollution from Combustion of Fuel in Indirect Heat Exchangers	13
3.5.2. 45 CSR 4: To Prevent and Control the Discharge of Air Pollutants into the Air Which Causes or Contributes to an Objectionable Odor	13
3.5.3. 45 CSR 6: To Prevent and Control the Air Pollution from the Combustion of Refuse	13
3.5.4. 45 CSR 10: To Prevent and Control Air Pollution from the Emission of Sulfur Oxides	13
3.5.5. 45 CSR 16: Standards of Performance for New Stationary Sources	13
3.5.6. 45 CSR 17: To Prevent and Control Particulate Matter Air Pollution from Materials Handling, Preparation, Storage and Other Sources of Fugitive Particulate Matter	14
3.5.7. 45 CSR 21-28: Petroleum Liquid Storage in Fixed Roof Tanks	14
3.5.8. 45 CSR 34: Emissions Standards for Hazardous Air Pollutants	14
3.5.9. Non-Applicability of Other SIP Rules	14
4. G35-D APPLICATION FORMS	15
ATTACHMENT A SINGLE SOURCE DETERMINATION FORM	
ATTACHMENT B SITING CRITERIA WAIVER (IF APPLICABLE)	
ATTACHMENT C CURRENT BUSINESS CERTIFICATE	

ATTACHMENT D	PROCESS FLOW DIAGRAM
ATTACHMENT E	PROCESS DESCRIPTION
ATTACHMENT F	PLOT PLAN
ATTACHMENT G	AREA MAP
ATTACHMENT H	G35-D SECTION APPLICABILITY FORM
ATTACHMENT I	EMISSION UNITS/ERD TABLE
ATTACHMENT J	FUGITIVE EMISSIONS SUMMARY
ATTACHMENT K	STORAGE VESSEL(S) DATA SHEET
ATTACHMENT L	NATURAL GAS FIRED FUEL BURNING UNIT(S) DATA SHEET
ATTACHMENT M	INTERNAL COMBUSTION ENGINE DATA SHEET(S)
ATTACHMENT N	TANKER TRUCK LOADING DATA SHEET (IF APPLICABLE)
ATTACHMENT O	GLYCOL DEHYDRATION UNIT DATA SHEET(S)
ATTACHMENT P	PNEUMATIC CONTROLLERS DATA SHEET(S)
ATTACHMENT Q	CENTRIFUGAL COMPRESSOR DATA SHEET(S)
ATTACHMENT R	RECIPROCATING COMPRESSOR DATA SHEET(S)
ATTACHMENT S	BLOWDOWN AND PIGGING OPERATIONS DATA SHEET(S)
ATTACHMENT T	AIR POLLUTION CONTROL DEVICE
ATTACHMENT U	EMISSION CALCULATIONS
ATTACHMENT V	FACILITY-WIDE EMISSION SUMMARY SHEET(S)
ATTACHMENT W	CLASS I LEGAL ADVERTISEMENT

1. INTRODUCTION

M3 Appalachia Gathering, LLC (M3), which is owned by DTE Energy Company, is submitting this G35-D Permit application to the West Virginia Department of Environmental Protection (WVDEP) for an existing natural gas compressor station located in Monongalia County, West Virginia (Hamilton Compressor Station or ‘Hamilton Station’). The Hamilton Station is currently operating under R13 permit number R13-3292. This general permit application seeks to add new compression, dehydration and ancillary equipment and replace the current R13 permit with a G-35D permit.

1.1. FACILITY AND PROJECT DESCRIPTION

The Hamilton Station is an existing natural gas compressor station covered under standard industrial code (SIC) 1311. The station compresses and dehydrates natural gas from nearby wells for transportation across the pipeline.

The station currently consists of the following equipment:

- > One (1) 75 million standard cubic feet per day (MMscfd) triethylene glycol dehydration unit (TEG-1) with associated flash tank, and 1.5 MMBtu/hr reboiler (REB-1);
- > One (1) PSI generator engine (GE-2), rated at 85 bhp;
- > One (1) 16,800 gallon waste fluids tank (T11); and
- > One (1) 500 gallon triethylene glycol tank (T12).

Please note that there are multiple other sources included in the current R13 permit which have yet to be installed. As these source have yet to be installed, their source is denoted as ‘New’ for the purposes of this permit application. However, as they are authorized by the facility’s current R13 permit, the applicant reserves the right to install them prior to the issuance of the requested G35-D.

With this submittal, the applicant specifically seeks to do the following:

- > Add three (3) Caterpillar G3606 compressor engines (CE-4 to CE-6), each rated at 1,775 bhp;
- > Add one (1) Generac 14.2 L emergency generator engine (GE-1), rated at 304 bhp;
- > Add one (1) 75 million standard cubic feet per day (MMscfd) triethylene glycol dehydration unit (TEG-2) with associated flash tank, and 1.5 MMBtu/hr reboiler (REB-2);
- > Add one (1) Flex Energy GT250S microturbine (MT-1);
- > Add several miscellaneous tanks (in place of those currently in the permit)¹;
- > Correct the source names of the three (3) Caterpillar compressor engines (CE-1 to CE-3) currently in the permit²;
- > Clarify/revise other source names³; and

¹ The permit application forms include a complete listing of tanks; the applicant is requesting that the issued permit reflect the forms.

² These sources have yet to be installed. Although the horsepower rating and emissions profiles are accurate, the engines are currently listed in the permit as Caterpillar ‘G3616’, whereas the correct model is ‘G3606’.

³ The permit application forms include a complete listing of all requested source names; the applicant is requesting that the issued permit reflect the forms. Some sources have yet to be installed (although they may be included in the current permit) and thus are designated as ‘New’ in the forms.

- > Remove the condenser from the current dehydration unit (TEG-1)⁴.

A process flow diagram is included as Attachment D.

1.2. SOURCE STATUS

WVDEP must make stationary source determinations on a case-by-case basis using the guidance under the Clean Air Act (CAA) and EPA's and WVDEP's implementing regulations. The definition of stationary source in 40 CFR 51.166(b) includes the following:

“(6) Building, structure, facility, or installation means all of the pollutant emitting activities which belong to the same industrial grouping, are located on or more contiguous or adjacent properties, and are under control of the same person (or persons under common control).”

Other additional pollutant emitting facilities should be aggregated with the Hamilton Station for air permitting purposes if, and only if, all three elements of the “stationary source” definition above are fulfilled. WVDEP previously determined that the Hamilton Station is a separate stationary source when the current permit was issued. There are no facilities within a quarter-mile radius of the facility.

⁴ The existing dehydration unit (TEG-1) is permitted with a condenser. However, this control device has negligible impact on emissions, as there is no detectable level of heavy hydrocarbons (ex. benzene, toluene, etc.) in the gas. Therefore, the applicant is requesting the removal of this control device from the issued permit, as it provides minimal environmental benefit at high cost. **A GRI-GLYCalc run showing the ineffectiveness of the condenser is included for reference.**

1.3. G35-D APPLICATION ORGANIZATION

This West Virginia G35-D permit application is organized as follows:

- > Section 2: Sample Emission Source Calculations;
- > Section 3: Regulatory Discussion;
- > Section 4: G35-D Application Form;
- > Attachment A: Single Source Determination Form
- > Attachment B: Siting Criteria Waiver (*not applicable*)
- > Attachment C: Current Business Certificate
- > Attachment D: Process Flow Diagram
- > Attachment E: Process Description
- > Attachment F: Plot Plan
- > Attachment G: Area Map
- > Attachment H: G35-D Section Applicability Form
- > Attachment I: Emission Units/ERD Table
- > Attachment J: Fugitive Emission Summary Sheet(s)
- > Attachment K: Storage Vessels Data Sheet(s)
- > Attachment L: Natural Gas Fired Fuel Burning Unit Data Sheet(s)
- > Attachment M: Internal Combustion Engine Data Sheet(s)
- > Attachment N: Tanker Truck Loading Data Sheet
- > Attachment O: Glycol Dehydration Unit Data Sheet(s)
- > Attachment P: Pneumatic Controller Data Sheet(s)
- > Attachment Q: Centrifugal Compressor Data Sheet(s)
- > Attachment R: Reciprocating Compressor Data Sheet(s)
- > Attachment S: Blowdown and Pigging Operation Data Sheet(s)
- > Attachment T: Air Pollution Control Device Data Sheet(s)
- > Attachment U: Emission Calculations
- > Attachment V: Facility-wide Emission Summary Sheet(s)
- > Attachment W: Class I Legal Advertisement

2. SAMPLE EMISSION SOURCE CALCULATIONS

The characteristics of air emissions from the facility, along with the methodology for calculating emissions, are briefly described in this section of the application. Detailed emission calculations are presented in Attachment U of this application.

Emissions at this facility will result from combustion of natural gas (in the engines, microturbine and reboilers), operation of the dehydration units and storage tanks, as well as piping blowdowns and fugitive emissions from components leaks and the facility roadway. The methods by which emissions from each of these source types is calculated are summarized below.

- > **Compressor Engines:** Potential emissions of nitrogen oxides (NO_x), CO, VOC, formaldehyde are calculated using factors provided by the engine and catalyst manufacturer. Potential emissions of sulfur dioxide (SO₂), particulate matter (PM/PM₁₀/PM_{2.5}), and all other hazardous air pollutants (HAPs) are calculated using U.S. EPA's AP-42 factors for four-stroke lean-burn engines.
- > **Generator Engines:** Potential emissions of nitrogen oxides (NO_x), CO and VOC are calculated using factors provided in the EPA Certificates of Conformity. Potential emissions of sulfur dioxide (SO₂), particulate matter (PM/PM₁₀/PM_{2.5}), and all other hazardous air pollutants (HAPs) are calculated using U.S. EPA's AP-42 factors for four-stroke rich-burn engines.
- > **Microturbine:** Potential emissions of nitrogen oxides (NO_x), CO and VOC are calculated using factors provided by the manufacturer. Potential emissions of sulfur dioxide (SO₂), particulate matter (PM/PM₁₀/PM_{2.5}), and all other hazardous air pollutants (HAPs) are calculated using U.S. EPA's AP-42 factors for stationary gas turbines.
- > **TEG Dehydration Unit:** Potential emissions of hazardous air pollutants (HAPs), volatile organic compounds (VOC), and methane from the dehydration unit are calculated using GRI-GLYCalc v4.0 and a site-specific gas analysis.
- > **Reboilers:** Potential emissions of all criteria pollutants and HAPs are calculated using U.S. EPA's AP-42 factors for natural gas external combustion equipment.⁵ These calculations assume a site-specific heat content of natural gas.
- > **Storage Tanks and Liquid Loading:** Working, breathing and flashing emissions of VOC and HAPs from the waste fluid tanks are calculated using E&P TANK v2.0 software. Working and breathing emissions from all other tanks, along with the waste fluid loading emissions, were calculated using EPA Tanks 4.0.9d and AP-42 methodology.
- > **Fugitive Emissions:** Emissions from fugitive equipment leaks are calculated using published EPA emission factors and 40 CFR Part 98, Subpart W emission factors. Emissions from blowdown events are calculated using engineering estimates of the amount of gas vented. Site specific gas analyses were used to speciate VOC, HAP, and GHG emissions.
- > **Haul Roads:** Fugitive dust emitted from facility roadways has been estimated using projected vehicle miles traveled along with U.S. EPA's AP-42 factors for unpaved haul roads.⁶

⁵ U.S. EPA, AP 42, Fifth Edition, Volume I, Chapter 1.4, Natural Gas Combustion, July 1998.

⁶ U.S. EPA, AP 42, Fifth Edition, Volume I, Section 13.2.2, Unpaved Roads, November 2006.

Potential emissions of greenhouse gas pollutants (GHGs) are calculated using manufacturer's data as available (CO₂ and CH₄ in this case) and U.S. EPA's emission factors from 40 CFR Part 98, Subpart C for all others.

3. REGULATORY DISCUSSION

This section documents the applicability determinations made for Federal and State air quality regulations. In this section, applicability or non-applicability of the following regulatory programs is addressed:

- > Prevention of Significant Deterioration (PSD) permitting;
- > Non-attainment New Source Review (NNSR) permitting;
- > Title V of the 1990 Clean Air Act Amendments;
- > New Source Performance Standards (NSPS);
- > National Emission Standards for Hazardous Air Pollutants (NESHAP); and
- > West Virginia State Implementation Plan (SIP) regulations.

This review is presented to supplement and/or add clarification to the information provided in the WVDEP G35-D operating permit application forms.

In addition to providing a summary of applicable requirements, this section of the application also provides non-applicability determinations for certain regulations, allowing the WVDEP to confirm that identified regulations are not applicable to the facility. Note that explanations of non-applicability are limited to those regulations for which there may be some question of applicability specific to the operations at the station. Regulations that are categorically non-applicable are not discussed (e.g., NSPS Subpart J, Standards of Performance for Petroleum Refineries).

3.1. PSD AND NNSR SOURCE CLASSIFICATION

Federal construction permitting programs regulate new and modified sources of attainment pollutants under Prevention of Significant Deterioration and new and modified sources of non-attainment pollutants under Non-Attainment New Source Review. PSD regulations apply when a new source is constructed in which emissions exceed major source thresholds, an existing minor source undergoes a modification in which emission increases exceed PSD major source thresholds, or an existing major source undergoes a modification in which emission increases exceed PSD significant emission rates. The facility will remain a minor source with respect to the NSR program after the project since potential emissions are below all the PSD thresholds. As such, PSD permitting is not triggered by this construction activity. NNSR regulations only apply in areas designated as non-attainment. The facility is located in Monongalia County, which is designated as attainment/unclassifiable for all criteria pollutants.⁷ Therefore, NNSR regulations do not apply to the facility.

3.2. TITLE V OPERATING PERMIT PROGRAM

Title 40 of the Code of Federal Regulations Part 70 (40 CFR 70) establishes the federal Title V operating permit program. West Virginia has incorporated the provisions of this federal program in its Title V operating permit program in West Virginia Code of State Regulations (CSR) 45-30. The major source thresholds with respect to the West Virginia Title V operating permit program regulations are 10 tons per year (tpy) of a single HAP, 25 tpy of any combination of HAP, and 100 tpy of all other regulated pollutants. The potential emissions of all regulated pollutants are below the corresponding threshold(s) at this facility after the proposed project. Therefore, the facility is not a major source for Title V purposes.

⁷ U.S. EPA Green Book, http://www.epa.gov/airquality/greenbook/anayo_wv.html, as of February 13, 2017.

3.3. NEW SOURCE PERFORMANCE STANDARDS

New Source Performance Standards, located in 40 CFR 60, require new, modified, or reconstructed sources to control emissions to the level achievable by the best demonstrated technology as specified in the applicable provisions. Moreover, any source subject to an NSPS is also subject to the general provisions of NSPS Subpart A, except where expressly noted. The following is a summary of applicability and non-applicability determinations for NSPS regulations of relevance to the facility. Besides 40 CFR 60 Subpart A (NSPS Subpart A), which is similar to 40 CFR 63 Subpart A (NESHAP Subpart A), the following NSPS could potentially apply to the facility:

- > 40 CFR Part 60 Subparts D, Da, Db, and Dc – Steam Generating Units
- > 40 CFR Part 60 Subparts K, Ka, and Kb – Storage Vessels for Petroleum Liquids/Volatile Organic Liquids
- > 40 CFR Part 60 Subpart GG – Stationary Gas Turbines
- > 40 CFR Part 60 Subpart JJJJ – Stationary Spark Ignition Internal Combustion Engines
- > 40 CFR Part 60 Subpart KKKK – Stationary Combustion Turbines
- > 40 CFR Part 60 Subpart OOOO – Crude Oil and Natural Gas Production, Transmission, and Distribution
- > 40 CFR Part 60 Subpart OOOOa – Crude Oil and Natural Gas Facilities

3.3.1. NSPS Subparts D, Da, Db, and Dc - Steam Generating Units

These subparts apply to steam generating units of various sizes, all greater than 10 MMBtu/hr. The proposed project does not include any steam generating units with a heat input greater than 10 MMBtu/hr, therefore the requirements of these subparts do not apply.

3.3.2. NSPS Subparts K, Ka, and Kb - Storage Vessels for Petroleum Liquids/Volatile Organic Liquids

These subparts apply to storage tanks of certain sizes constructed, reconstructed, or modified during various time periods. Subpart K applies to storage tanks constructed, reconstructed, or modified prior to 1978, and Subpart Ka applies to those constructed, reconstructed, or modified prior to 1984. Both Subparts K and Ka apply to storage tanks with a capacity greater than 40,000 gallons. Subpart Kb applies to volatile organic liquid (VOL) storage tanks constructed, reconstructed, or modified after July 23, 1984 with a capacity equal to or greater than 75 m³ (~19,813 gallons). All of the tanks at the facility have a capacity of 19,813 gallons or less. As such, Subparts K, Ka, and Kb do not apply to the storage tanks at the facility.

3.3.3. NSPS Subpart GG - Stationary Gas Turbines

Subpart GG, Standards of Performance for Stationary Gas Turbines, applies to all gas turbines with a heat input at peak load greater than or equal to 10 MMBtu/hr based on the lower heating value of the fuel fired. This standard was promulgated in 1979. The applicability of Subpart KKKK, promulgated in 2006, is similar to that of Subpart GG and applies to stationary combustion turbines that commence construction after February 18, 2005. The proposed microturbine is not subject to the requirements of Subpart GG based on heat input.

3.3.4. NSPS Subpart JJJJ - Stationary Spark Ignition Internal Combustion Engines

Subpart JJJJ, Standards of Performance for Stationary Spark Ignition Internal Combustion Engines, applies to manufacturers, owners and operators of stationary spark ignition (SI) engines. The requirements for SI engines with a maximum power rating greater than or equal to 500 hp (except lean burn engines 500 hp ≤ hp < 1,350) apply to owner/operators of such engines ordered on or after July 1, 2007. The proposed compressor engines will be a 4-stroke, lean burn spark ignition RICE rated at 1,775 hp each. As such, the engines will be subject to the emissions standards per Table 1 to NSPS Subpart JJJJ (for non-emergency use engines), as well as performance testing every 8,760 hours of operation or three (3) years, and associated notification and reporting requirements.

The generator engines (GE-1 and GE-2) are subject to Subpart JJJJ. However, as these are EPA Certified Units (see attached Certificates of Conformity), the applicant is not required to conduct performance testing. Instead, it is required to operate and maintain the certified stationary SI internal combustion engines and control device according to the manufacturer's emission-related written instructions.

3.3.5. NSPS Subpart KKKK - Stationary Combustion Turbines

Subpart KKKK, Standards of Performance for Stationary Combustion Turbines, applies to stationary combustion units with a heat input at peak load equal to or greater than 10 MMBtu/hr, based on the higher heating value of the fuel, commencing construction after February 18, 2005. The proposed microturbine will have a heat input less than 10 MMBtu/hr and is therefore not subject to this standard.

3.3.6. NSPS Subpart OOOO – Crude Oil and Natural Gas Production, Transmission, and Distribution

Subpart OOOO – *Standards of Performance for Crude Oil and Natural Gas Production, Transmission, and Distribution*, applies to affected facilities that commenced construction, reconstruction, or modification after August 23, 2011 and before September 18, 2015. The facility does not include any existing sources that are affected sources under this regulation, nor will any new sources fall into this date range. Therefore, the facility has no applicable requirements under this regulation.

3.3.7. NSPS Subpart OOOOa – Crude Oil and Natural Gas Facilities

Subpart OOOOa, Standards of Standards of Performance for Crude Oil and Natural Gas Facilities, will apply to affected facilities that commenced construction, reconstruction, or modification after September 18, 2015. The regulation was published final in the Federal Register on June 3, 2016. The rule includes provisions for the following facilities:

- > Hydraulically fractured wells;
- > Centrifugal compressors located between the wellhead and the point of custody transfer to the natural gas distribution segment;
- > Reciprocating compressors located between the wellhead and the point of custody transfer to the natural gas distribution segment;
- > Continuous bleed natural gas-driven pneumatic controllers with a bleed rate of > 6 scfh located in the production, gathering, processing, or transmission and storage segments (excluding natural gas processing plants);
- > Continuous bleed natural gas-driven pneumatic controllers located at natural gas processing plants;
- > Pneumatic pumps located in the production, gathering, processing, or transmission and storage segments;
- > Storage vessels located in the production, gathering, processing, or transmission and storage segments;
- > The collection of fugitive emissions components at a well site;
- > The collection of fugitive emissions components at a compressor station; and
- > Sweetening units located onshore that process natural gas produced from either onshore or offshore wells.

The new reciprocating compressors will be required to change rod packing every 26,000 hours of operation or every 36 months, or collect the methane and VOC emissions using a rod packing collection system which operates under negative pressure. The compressors will also be subject to the recordkeeping and annual reporting requirements of the rule.

The new waste fluid storage tank will be a 'storage vessel' as defined by the regulation, however, potential emissions of VOC will be less than six tons per year. Therefore, it will not be a storage vessel affected facility under the rule.

As a result of the proposed project (installation of new compressors), the applicant will be required to monitor all fugitive emission components (ex. connectors, flanges, etc.) with an optical gas imaging (OGI) device, and repair all sources of fugitive emissions in accordance with the rule. The applicant must also develop a monitoring plan, conduct

surveys on a quarterly basis, and will be subject to the applicable recordkeeping and reporting requirements of the rule.

All pneumatic controllers currently at or proposed to be located at the facility are intermittent or low-bleed. Therefore, they will not be subject to any pneumatic controller requirements under Subpart 0000a. As currently proposed, there are no other affected source categories under the rule that will apply to the proposed equipment involved in this project.

3.3.8. Non-Applicability of All Other NSPS

NSPS are developed for particular industrial source categories. Other than NSPS developed for natural gas processing plants (Subparts 0000 and 0000a) and associated equipment (Subpart K-Kb), the applicability of a particular NSPS to the facility can be readily ascertained based on the industrial source category covered. All other NSPS are categorically not applicable to the proposed project.

3.4. NATIONAL EMISSION STANDARDS FOR HAZARDOUS AIR POLLUTANTS

Part 63 NESHAP allowable emission limits are established on the basis of a maximum achievable control technology (MACT) determination for a particular major source. A HAP major source is defined as having potential emissions in excess of 25 tpy for total HAP and/or potential emissions in excess of 10 tpy for any individual HAP. The facility is an area (minor) source of HAP since its potential emissions of HAP are less than the 10/25 major source thresholds. Besides 40 CFR 63 Subpart A (NESHAP Subpart A), which is similar to 40 CFR 60 Subpart A (NSPS Subpart A), the following NESHAP could potentially apply to the facility:

- > 40 CFR Part 63 Subpart HH – Oil and Natural Gas Production Facilities
- > 40 CFR 63 Subpart ZZZZ – Stationary Reciprocating Internal Combustion Engines
- > 40 CFR Part 63 Subpart JJJJJ – Industrial, Commercial, and Institutional Boilers

3.4.1. NESHAP Subpart HH - Oil and Natural Gas Production Facilities

This MACT standard contains requirements for both major and area sources of HAP. The benzene emissions from the existing and new glycol dehydrator vents will be less than 0.90 megagrams per year (1 tpy) each, therefore, the facility is exempt from the requirements of NESHAP Subpart HH pursuant to 40 CFR §63.764(e)(1)(ii), except for the requirement to keep records of the actual average natural gas flow rate or actual average benzene emissions from the dehydrators, per 40 CFR §63.774(d)(1). The applicant will continue to comply with the requirements of Subpart HH.

3.4.2. NESHAP Subpart ZZZZ - Stationary Reciprocating Internal Combustion Engines

Stationary reciprocating internal combustion engines (RICE) at both area and major sources of HAP emissions are potentially subject to Subpart ZZZZ – NESHAP for Stationary Reciprocating Internal Combustion Engines (RICE). Per §63.6590(a)(2)(iii), a stationary RICE located at an area source of HAP emissions is new if you commenced construction of the stationary reciprocating internal combustion engine (RICE) on or after 6/12/2006. The compressor engines and generator engines have or will have commenced construction after this date, and are therefore new RICE under Subpart ZZZZ. Per §63.6590(c), “[...] An affected source that meets any of the criteria in paragraphs (c)(1) through (7) of this section must meet the requirements of this part by meeting the requirements of 40 CFR part 60 subpart IIII, for compression ignition engines or 40 CFR part 60 Subpart JJJJ, for spark ignition engines. No further requirements apply for such engines under this part.” Specifically, §63.6590(c)(1) includes “a new or reconstructed stationary RICE located at an area source”; the compressors engine and generator engines fall into this category. Therefore, the engines have no applicable Subpart ZZZZ requirements, other than to comply with any applicable 40 CFR 60 Subpart JJJJ requirements.

3.4.3. NESHAP JJJJJJ - Industrial, Commercial, and Institutional Boilers

This MACT standard applies to industrial, commercial, and institutional boilers of various sizes and fuel types at area sources. The reboilers are natural gas-fired and thus specifically exempt from this subpart. Therefore, no sources at the facility are subject to any requirements under 40 CFR 63 Subpart JJJJJ.

3.5. WEST VIRGINIA SIP REGULATIONS

The facility is potentially subject to regulations contained in the West Virginia Code of State Regulations, Chapter 45 (Code of State Regulations). The Code of State Regulations fall under two main categories: those regulations that are generally applicable (e.g., permitting requirements), and those that have specific applicability (e.g., PM standards for manufacturing equipment).

3.5.1. 45 CSR 2: To Prevent and Control Particulate Air Pollution from Combustion of Fuel in Indirect Heat Exchangers

45 CSR 2 applies to fuel burning units, defined as equipment burning fuel “for the primary purpose of producing heat or power by indirect heat transfer”. The reboilers are fuel burning units and therefore must comply with this regulation. Per 45 CSR 2-3, opacity of emissions from units shall not exceed 10 percent, based on a six-minute block average. Note that as the reboilers are less than 10 MMBtu/hr, they are exempt from PM emission limits.

3.5.2. 45 CSR 4: To Prevent and Control the Discharge of Air Pollutants into the Air Which Causes or Contributes to an Objectionable Odor

According to 45 CSR 4-3:

No person shall cause, suffer, allow or permit the discharge of air pollutants which cause or contribute to an objectionable odor at any location occupied by the public.

The facility is generally subject to this requirement. However, due to the nature of the process at the station, production of objectionable odor during normal operation is unlikely.

3.5.3. 45 CSR 6: To Prevent and Control the Air Pollution from the Combustion of Refuse

45 CSR 6 applies to activities involving incineration of refuse, defined as “the destruction of combustible refuse by burning in a furnace designed for that purpose. For the purposes of this rule, the destruction of any combustible liquid or gaseous material by burning in a flare or flare stack, thermal oxidizer or thermal catalytic oxidizer stack shall be considered incineration.” There are no control devices at the facility that utilize ‘incineration’.

3.5.4. 45 CSR 10: To Prevent and Control Air Pollution from the Emission of Sulfur Oxides

This rule potentially applies to fuel burning units, including glycol dehydration unit reboilers. Per 45 CSR 10-10.1, units rated less than 10 MMBtu/hr are exempt from the SO₂ emission limitations and testing, monitoring, recordkeeping, and reporting requirements of this rule. The reboilers are rated less than 10 MMBtu/hr and as such are exempt from this rule.

3.5.5. 45 CSR 16: Standards of Performance for New Stationary Sources

45 CSR 16-1 incorporates the federal Clean Air Act (CAA) standards of performance for new stationary sources set forth in 40 CFR Part 60 by reference. As such, by complying with all applicable requirements of 40 CFR Part 60 at the facility, the applicant will be complying with 45 CSR 16.

3.5.6. 45 CSR 17: To Prevent and Control Particulate Matter Air Pollution from Materials Handling, Preparation, Storage and Other Sources of Fugitive Particulate Matter

According to 45 CSR 17-3.1:

No person shall cause, suffer, allow or permit fugitive particulate matter to be discharged beyond the boundary lines of the property lines of the property on which the discharge originates or at any public or residential location, which causes or contributes to statutory air pollution.

Due to the nature of the activities at the facility, it is unlikely that fugitive particulate matter emissions will be emitted under normal operating conditions. However, the applicant will take measures to ensure any fugitive particulate matter emissions will not cross the property boundary should any such emissions occur.

3.5.7. 45 CSR 21-28: Petroleum Liquid Storage in Fixed Roof Tanks

45 CSR 21-28 applies to any fixed roof petroleum liquid storage tank with a capacity greater than 40,000 gallons located in Putnam County, Kanawha County, Cabell County, Wayne County, and Wood County. The capacity of each storage tank at the facility is less than 40,000 gallons and the facility is not located in the listed counties. Therefore, 45 CSR 21-28 does not apply to the storage tanks at this station.

3.5.8. 45 CSR 34: Emissions Standards for Hazardous Air Pollutants

45 CSR 34-1 incorporates the federal Clean Air Act (CAA) national emissions standards for hazardous air pollutants (NESHAPs) as set forth in 40 CFR Parts 61 and 63 by reference. As such, by complying with all applicable requirements of 40 CFR Parts 61 and 63 at the facility, the applicant will be complying with 45 CSR 34.

3.5.9. Non-Applicability of Other SIP Rules

A thorough examination of the West Virginia SIP rules with respect to applicability at the facility reveals many SIP regulations that do not apply or impose additional requirements on operations. Such SIP rules include those specific to a particular type of industrial operation that is categorically not applicable to the facility.

4. G35-D APPLICATION FORMS

The WVDEP permit application forms contained in this application include all applicable G35-D application forms including the required attachments.



west virginia department of environmental protection

Division of Air Quality
601 57th Street SE
Charleston, WV 25304
Phone (304) 926-0475
Fax (304) 926-0479
www.dep.wv.gov

G35-D GENERAL PERMIT REGISTRATION APPLICATION

PREVENTION AND CONTROL OF AIR POLLUTION IN REGARD TO THE CONSTRUCTION, MODIFICATION, RELOCATION, ADMINISTRATIVE UPDATE AND OPERATION OF NATURAL GAS COMPRESSOR AND/OR DEHYDRATION FACILITIES

- CONSTRUCTION
- MODIFICATION
- RELOCATION

- CLASS I ADMINISTRATIVE UPDATE
- CLASS II ADMINISTRATIVE UPDATE

SECTION 1. GENERAL INFORMATION

Name of Applicant (as registered with the WV Secretary of State's Office): M3 Appalachia Gathering, LLC

Federal Employer ID No. (FEIN): 45-0718671

Applicant's Mailing Address: 333 Technology Drive, Ste 109

City: Canonsburg

State: PA

ZIP Code: 15317

Facility Name: Hamilton Compressor Station

Operating Site Physical Address: See lat/long
If none available, list road, city or town and zip of facility.

City: Fairview

Zip Code: 26570

County: Monongalia

Latitude & Longitude Coordinates (NAD83, Decimal Degrees to 5 digits):

Latitude: 39.64194

Longitude: -80.20528

SIC Code: 1311

DAQ Facility ID No. (For existing facilities)
061-00206

NAICS Code: 211111

CERTIFICATION OF INFORMATION

This G35-D General Permit Registration Application shall be signed below by a Responsible Official. A Responsible Official is a President, Vice President, Secretary, Treasurer, General Partner, General Manager, a member of the Board of Directors, or Owner, depending on business structure. A business may certify an Authorized Representative who shall have authority to bind the Corporation, Partnership, Limited Liability Company, Association, Joint Venture or Sole Proprietorship. Required records of daily throughput, hours of operation and maintenance, general correspondence, compliance certifications and all required notifications must be signed by a Responsible Official or an Authorized Representative. If a business wishes to certify an Authorized Representative, the official agreement below shall be checked off and the appropriate names and signatures entered. **Any administratively incomplete or improperly signed or unsigned G35-D Registration Application will be returned to the applicant. Furthermore, if the G35-D forms are not utilized, the application will be returned to the applicant. No substitution of forms is allowed.**

I hereby certify that _____ is an Authorized Representative and in that capacity shall represent the interest of the business (e.g., Corporation, Partnership, Limited Liability Company, Association Joint Venture or Sole Proprietorship) and may obligate and legally bind the business. If the business changes its Authorized Representative, a Responsible Official shall notify the Director of the Division of Air Quality immediately.

I hereby certify that all information contained in this G35-D General Permit Registration Application and any supporting documents appended hereto is, to the best of my knowledge, true, accurate and complete, and that all reasonable efforts have been made to provide the most comprehensive information possible.

Responsible Official Signature: 

Name and Title: Ken Magyar, VP, Project Development & Business Development

Phone: (724) 416-7263

Fax: n/a

Email: Kenneth.Magyar@dteenergy.com

Date: APRIL 18, 2017

If applicable:

Authorized Representative Signature: _____

Name and Title:


Phone:

Fax:

Email:

Date:

If applicable:

Environmental Contact 

Name and Title: Ryan Mathews, Gas Pipeline Engineer

Phone: (724) 416-7262

Fax:

Email: ryan.mathews@dteenergy.com

Date: APRIL 18, 2017

OPERATING SITE INFORMATION

Briefly describe the proposed new operation and/or any change(s) to the facility:
 Addition of compression, dehydration and ancillary equipment to the facility.

Directions to the facility:
 From 601 57th St SE, Charleston, WV 25304: head northeast on 57th St SE toward Washington Ave SE (travel 0.1 mi). Turn left onto MacCorkle Ave SE (travel 1.8 mi). Turn right onto 36th St SE (travel 0.2 mi). Continue onto 36th St Southeast Bridge (travel 0.2 mi). Use the right lane to take the ramp onto I-64 W/I-77 N (travel 0.1 mi). Merge onto I-64 W/I-77 N (travel 2.5 mi). Use the right 2 lanes to take the Interstate 77 N/Interstate 79 N exit toward Parkersburg (travel 0.5 mi). Continue onto I-77 N (travel 1.4 mi). Keep right at the fork to continue on I-79 N, follow signs for Clarksburg (travel 131 mi). Take exit 132 for US-250 toward S Fairmont (travel 397 ft). Turn right onto US-250 S/White Hall Blvd (signs for Grafton) (travel 0.2 mi). Turn right onto Middletown Rd (travel 0.9 mi). Turn right onto Industrial Park Rd (travel 1.4 mi). Turn left onto Manley Chapel Rd (travel 1.6 mi). Turn right onto Co Rd 27 (travel 1.0 mi). Continue onto Everson St (travel 341 ft). Everson St turns slightly left and becomes Co Rd 27 (travel 0.6 mi). Turn left onto US-19 S (travel 0.4 mi). Turn right onto WV-218 N (travel 4.4 mi). Turn right onto US-250 S (travel 0.3 mi). Turn left onto WV-218 N/Main St and continue to follow WV-218 N (travel 6.9 mi). Turn right onto WV-218 N/Jefferson St and continue to follow WV-218 N (travel 3.4 mi). Make a sharp right onto Statler Run Rd and the facility entrance road will be on the left.

ATTACHMENTS AND SUPPORTING DOCUMENTS

I have enclosed the following required documents:

Check payable to WVDEP – Division of Air Quality with the appropriate application fee (per 45CSR13 and 45CSR22).

- Check attached to front of application.
- I wish to pay by electronic transfer. Contact for payment (incl. name and email address):
- I wish to pay by credit card. Contact for payment (incl. name and email address):

- \$500 (Construction, Modification, and Relocation) \$300 (Class II Administrative Update)
- \$1,000 NSPS fee for 40 CFR60, Subpart IIII, JJJJ and/or OOOO and/or OOOOa ¹
- \$2,500 NESHAP fee for 40 CFR63, Subpart ZZZZ and/or HH ²

¹ Only one NSPS fee will apply.
² Only one NESHAP fee will apply. The Subpart ZZZZ NESHAP fee will be waived for new engines that satisfy requirements by complying with NSPS, Subparts IIII and/or JJJJ.
NSPS and NESHAP fees apply to new construction or if the source is being modified.

- Responsible Official or Authorized Representative Signature (if applicable)
- Single Source Determination Form (**must be completed in its entirety**) – Attachment A
- Siting Criteria Waiver (if applicable) – Attachment B Current Business Certificate – Attachment C
- Process Flow Diagram – Attachment D Process Description – Attachment E
- Plot Plan – Attachment F Area Map – Attachment G
- G35-D Section Applicability Form – Attachment H Emission Units/ERD Table – Attachment I
- Fugitive Emissions Summary Sheet – Attachment J
- Storage Vessel(s) Data Sheet (include gas sample data, USEPA Tanks, simulation software (e.g. ProMax, E&P Tanks, HYSYS, etc.), etc. where applicable) – Attachment K
- Natural Gas Fired Fuel Burning Unit(s) Data Sheet (GPUs, Heater Treaters, In-Line Heaters if applic.) – Attachment L
- Internal Combustion Engine Data Sheet(s) (include manuf. performance data sheet(s) if applicable) – Attachment M
- Tanker Truck Loading Data Sheet (if applicable) – Attachment N
- Glycol Dehydration Unit Data Sheet(s) (include wet gas analysis, GRI- GLYCalc™ input and output reports and information on reboiler if applicable) – Attachment O
- Pneumatic Controllers Data Sheet – Attachment P
- Centrifugal Compressor Data Sheet – Attachment Q
- Reciprocating Compressor Data Sheet – Attachment R
- Blowdown and Pigging Operations Data Sheet – Attachment S
- Air Pollution Control Device/Emission Reduction Device(s) Sheet(s) (include manufacturer performance data sheet(s) if applicable) – Attachment T
- Emission Calculations (please be specific and include all calculation methodologies used) – Attachment U
- Facility-wide Emission Summary Sheet(s) – Attachment V
- Class I Legal Advertisement – Attachment W
- One (1) paper copy and two (2) copies of CD or DVD with pdf copy of application and attachments

All attachments must be identified by name, divided into sections, and submitted in order.

Single Source Determination Form

ATTACHMENT A - SINGLE SOURCE DETERMINATION FORM

Classifying multiple facilities as one “stationary source” under 45CSR13, 45CSR14, and 45CSR19 is based on the definition of Building, structure, facility, or installation as given in §45-14-2.13 and §45-19-2.12. The definition states:

“Building, Structure, Facility, or Installation” means all of the pollutant-emitting activities which belong to the same industrial grouping, are located on one or more contiguous or adjacent properties, and are under the control of the same person (or persons under common control). Pollutant-emitting activities are a part of the same industrial grouping if they belong to the same “Major Group” (i.e., which have the same two (2)-digit code) as described in the Standard Industrial Classification Manual, 1987 (United States Government Printing Office stock number GPO 1987 0-185-718:QL 3).

The Source Determination Rule for the oil and gas industry was published in the Federal Register on June 3, 2016 and will become effective on August 2, 2016. EPA defined the term “adjacent” and stated that equipment and activities in the oil and gas sector that are under common control will be considered part of the same source if they are located on the same site or on sites that share equipment and are within ¼ mile of each other.

Is there equipment and activities in the same industrial grouping (defined by SIC code)?

Yes No

Is there equipment and activities under the control of the same person/people?

Yes No

Is there equipment and activities located on the same site or on sites that share equipment and are within ¼ mile of each other?

Yes No

ATTACHMENT A: SINGLE SOURCE DETERMINATION MAP



Figure 1 - Map of Location with 1 Mile Radius Circle

Coordinates:

Latitude: 39° 38' 31" N, Longitude: 80° 12' 19" W

Siting Criteria Waiver *(not applicable)*

ATTACHMENT B – SITING CRITERIA WAIVER – NOT APPLICABLE

If applicable, please complete this form and it must be notarized.

**G35-D General Permit
Siting Criteria Waiver**

WV Division of Air Quality 300' Waiver

I _____ hereby
Print Name
acknowledge and agree that _____ will
General Permit Applicant's Name
construct an emission unit(s) at a natural gas compressor and/or dehydration facility
that will be located within 300' of my dwelling and/or business.

I hereby offer this waiver of siting criteria to the West Virginia Department of Environmental Protection
Division of Air Quality as permission to construct, install and operate in such location.

Signed:

Signature Date

Signature Date

Taken, subscribed and sworn before me this _____ day of

_____, 20____.

My commission expires: _____

SEAL _____
Notary Public

Current Business Certificate

**WEST VIRGINIA
STATE TAX DEPARTMENT
BUSINESS REGISTRATION
CERTIFICATE**

ISSUED TO:
**M3 APPALACHIA GATHERING, LLC
600 TRAVIS ST 4910
HOUSTON, TX 77002-3025**

BUSINESS REGISTRATION ACCOUNT NUMBER: 2252-1954

This certificate is issued on: **06/28/2011**

*This certificate is issued by
the West Virginia State Tax Commissioner
in accordance with Chapter 11, Article 12, of the West Virginia Code*

*The person or organization identified on this certificate is registered
to conduct business in the State of West Virginia at the location above.*

This certificate is not transferrable and must be displayed at the location for which issued.



This certificate shall be permanent until cessation of the business for which the certificate of registration was granted or until it is suspended, revoked or cancelled by the Tax Commissioner.

Change in name or change of location shall be considered a cessation of the business and a new certificate shall be required.

TRAVELING/STREET VENDORS: Must carry a copy of this certificate in every vehicle operated by them.
CONTRACTORS, DRILLING OPERATORS, TIMBER/LOGGING OPERATIONS: Must have a copy of this certificate displayed at every job site within West Virginia.

Process Flow Diagram

* Note that this is a simplified diagram for the purposes of explaining basic facility flow and emission points. The actual design is more complex and may vary.



Source Legend

- Existing Source
- New Source
- Permitted, yet to be installed source

Flow Legend

- Gas Flow
- Stack Emissions
- Emission Point
- Control Device

M3 Appalachia Gathering, LLC

Process Flow Diagram
Hamilton Compressor Station



April 2017

Process Description

ATTACHMENT E: PROCESS DESCRIPTION

M3 Appalachia Gathering, LLC is proposing to install additional compression, dehydration and ancillary equipment at the existing Hamilton Compressor Station.

The Hamilton Compressor Station compresses and dehydrates natural gas from production wells prior to transmission along the pipeline system. Reciprocating compressors utilize the power created by reciprocating internal combustion engines (RICE) to compress (raise the pressure of) the incoming gas stream. Subsequently, the gas stream passes through triethylene glycol (TEG) dehydration units, which will introduce TEG to the stream in a contact tower to absorb water vapor from the gas to meet customer specifications. The TEG is then sent to the natural gas-fired reboiler, which uses heat to evaporate entrained water from the TEG. The TEG is then discharged back to the contact tower for reuse. The natural gas stream from the contact tower flows into the pipeline to be transported further along the pipeline system. The compressor engines' exhaust streams are controlled by oxidation catalysts. Electrical power is provided to the facility via a microturbine generator and generator engines.


A process flow diagram is included as Attachment D.

Plot Plan


NOTE: This diagram is not to scale.
Locations and distances between surface
equipment are not known at this time.




Miscellaneous Tanks
T01 to T25
(Various Sizes)




Tri-ethylene Glycol Dehys
TEG-1 to TEG-2 (75 MMSCFD)
REB-1 to REB-2 (1.50 MMbtu/hr)




Generator Engine
GE-1
304 HP



Generator Engine
GE-2
85 HP



Microturbine
MT-1
335 HP



Compressor Engines
CE-1 to CE-6
1,775 HP

Entrance to facility

ATTACHMENT G

Area Map

ATTACHMENT G: AREA MAP



Figure 1 - Map of Location

UTM Northing (KM): 4,388.319

UTM Easting (KM): 568.190

Elevation: ~1,600 ft

G35-D Section Applicability Form

ATTACHMENT H – G35-D SECTION APPLICABILITY FORM

**General Permit G35-D Registration
Section Applicability Form**

General Permit G35-D was developed to allow qualified applicants to seek registration for a variety of sources. These sources include storage vessels, gas production units, in-line heaters, heater treaters, glycol dehydration units and associated reboilers, pneumatic controllers, centrifugal compressors, reciprocating compressors, reciprocating internal combustion engines (RICES), tank truck loading, fugitive emissions, completion combustion devices, flares, enclosed combustion devices, and vapor recovery systems. All registered facilities will be subject to Sections 1.0, 2.0, 3.0, and 4.0.

General Permit G35-D allows the registrant to choose which sections of the permit they are seeking registration under. Therefore, please mark which additional sections that you are applying for registration under. If the applicant is seeking registration under multiple sections, please select all that apply. Please keep in mind, that if this registration is approved, the issued registration will state which sections will apply to your affected facility.

GENERAL PERMIT G35-D APPLICABLE SECTIONS	
<input checked="" type="checkbox"/> Section 5.0	Storage Vessels Containing Condensate and/or Produced Water ¹
<input type="checkbox"/> Section 6.0	Storage Vessel Affected Facility (NSPS, Subpart OOOO/OOOOa)
<input checked="" type="checkbox"/> Section 7.0	Control Devices and Emission Reduction Devices not subject to NSPS Subpart OOOO/OOOOa and/or NESHAP Subpart HH
<input checked="" type="checkbox"/> Section 8.0	Small Heaters and Reboilers not subject to 40CFR60 Subpart Dc
<input type="checkbox"/> Section 9.0	Pneumatic Controllers Affected Facility (NSPS, Subpart OOOO/OOOOa)
<input type="checkbox"/> Section 10.0	Centrifugal Compressor Affected Facility (NSPS, Subpart OOOO/OOOOa) ²
<input checked="" type="checkbox"/> Section 11.0	Reciprocating Compressor Affected Facility (NSPS, Subpart OOOO/OOOOa) ²
<input checked="" type="checkbox"/> Section 12.0	Reciprocating Internal Combustion Engines, Generator Engines. Microturbine Generators
<input checked="" type="checkbox"/> Section 13.0	Tanker Truck Loading ³
<input checked="" type="checkbox"/> Section 14.0	Glycol Dehydration Units ⁴
<input checked="" type="checkbox"/> Section 15.0	Blowdown and Pigging Operations
<input checked="" type="checkbox"/> Section 16.0	Fugitive Emission Components (NSPS, Subpart OOOOa)

- 1 Applicants that are subject to Section 5 may also be subject to Section 6 if the applicant is subject to the NSPS, Subpart OOOO/OOOOa control requirements or the applicable control device requirements of Section 7.*
- 2 Applicants that are subject to Section 10 and 11 may also be subject to the applicable RICE requirements of Section 12.*
- 3 Applicants that are subject to Section 13 may also be subject to control device and emission reduction device requirements of Section 7.*
- 4 Applicants that are subject to Section 14 may also be subject to the requirements of Section 8 (reboilers). Applicants that are subject to Section 14 may also be subject to control device and emission reduction device requirements of Section 7.*

Emission Units/ERD Table

ATTACHMENT I – EMISSION UNITS / EMISSION REDUCTION DEVICES (ERD) TABLE

Include ALL emission units and air pollution control devices/ERDs that will be part of this permit application review. Do not include fugitive emission sources in this table. Deminimis storage tanks shall be listed in the Attachment K table. This information is required for all sources regardless of whether it is a construction, modification, or administrative update.

Emission Unit ID ¹	Emission Point ID ²	Emission Unit Description	Year Installed	Manufac. Date ³	Design Capacity	Type ⁴ and Date of Change	Control Device(s) ⁵	ERD(s) ⁶
CE-1	CE-1	Caterpillar G3606 Compressor Engine	TBD	TBD	1,775 HP	New*	C1	---
CE-2	CE-2	Caterpillar G3606 Compressor Engine	TBD	TBD	1,775 HP	New*	C2	---
CE-3	CE-3	Caterpillar G3606 Compressor Engine	TBD	TBD	1,775 HP	New*	C3	---
CE-4	CE-4	Caterpillar G3606 Compressor Engine	TBD	TBD	1,775 HP	New	C4	---
CE-5	CE-5	Caterpillar G3606 Compressor Engine	TBD	TBD	1,775 HP	New	C5	---
CE-6	CE-6	Caterpillar G3606 Compressor Engine	TBD	TBD	1,775 HP	New	C6	---
GE-1	GE-1	Cummins 14.2 L Generator Engine	TBD	TBD	304 HP	New	None	---
GE-2	GE-2	PSI 5.7 L Generator Engine	2014	2014-15	85 HP	Existing	None	---
MT-1	MT-1	Flex Energy GT250S Microturbine	TBD	TBD	250 kW	New	None	---
TEG-1	TEG-1	Dehydration Unit	2014	---	75 MMSCFD	Existing	None**	---
TEG-2	TEG-2	Dehydration Unit	TBD	---	75 MMSCFD	New	None	---
REB-1	REB-1	Reboiler	2014	---	1.5 MMbtu/hr	Existing	None	---
REB-2	REB-2	Reboiler	TBD	---	1.5 MMbtu/hr	New	None	---
T01	T01	Coolant (EG) Tank	TBD	---	1,260 Gallons	New	None	---
T02	T02	Coolant (EG) Tank	TBD	---	1,260 Gallons	New	None	---
T03	T03	Methanol Tank***	TBD	---	335 Gallons	New	None	---
T04	T04	Methanol Tank	TBD	---	335 Gallons	New	None	---
T05	T05	Methanol Tank	TBD	---	335 Gallons	New	None	---
T06	T06	Methanol Tank	TBD	---	335 Gallons	New	None	---
T07	T07	Methanol Tank	TBD	---	335 Gallons	New	None	---
T08	T08	Methanol Tank	TBD	---	335 Gallons	New	None	---
T10	T10	Waste Fluids Tank	TBD	---	8,820 Gallons	New	None	---
T11	T11	Waste Fluids Tank	2014	---	16,800 Gallons	Existing	None	---
T12	T12	Triethylene Glycol Tank	2014	---	500 Gallon	Existing	None	---
T13	T13	Triethylene Glycol Tank	TBD	---	500 Gallon	New	None	---

T14	T14	Engine Oil Tank	TBD	---	500 Gallon	New	None	---
T15	T15	Engine Oil Tank	TBD	---	500 Gallon	New	None	---
T16	T16	Engine Oil Tank	TBD	---	500 Gallon	New	None	---
T17	T17	Engine Oil Tank	TBD	---	500 Gallon	New	None	---
T18	T18	Engine Oil Tank	TBD	---	500 Gallon	New	None	---
T19	T19	Engine Oil Tank	TBD	---	500 Gallon	New	None	---
T20	T20	Compressor Oil Tank	TBD	---	500 Gallon	New	None	---
T21	T21	Compressor Oil Tank	TBD	---	500 Gallon	New	None	---
T22	T22	Compressor Oil Tank	TBD	---	500 Gallon	New	None	---
T23	T23	Compressor Oil Tank	TBD	---	500 Gallon	New	None	---
T24	T24	Compressor Oil Tank	TBD	---	500 Gallon	New	None	---
T25	T25	Compressor Oil Tank	TBD	---	500 Gallon	New	None	---
L01	L01	Liquid Loading	---	---	307,440 Gallons	Existing	None	---
---	---	Fugitives	---	---	---	Existing	None	---
---	---	Haul Roads	---	---	---	Existing	None	---

¹ For Emission Units (or Sources) use the following numbering system: 1S, 2S, 3S,... or other appropriate designation.

² For Emission Points use the following numbering system: 1E, 2E, 3E, ... or other appropriate designation.

³ When required by rule

⁴ New, modification, removal, existing

⁵ For Control Devices use the following numbering system: 1C, 2C, 3C,... or other appropriate designation.

⁶ For ERDs use the following numbering system: 1D, 2D, 3D,... or other appropriate designation.

*** Several of the sources currently listed in the permit have yet to be installed. Therefore, since this application seeks a new permit, their status is noted as 'New'.**

**** The existing dehydration unit (TEG-1) is permitted with a condenser. However, this control device has negligible impact on emissions, as there is no detectable level of heavy hydrocarbons (ex. benzene, toluene, etc.) in the gas. Therefore, the applicant is requesting the removal of this control device from the issued permit, as it provides minimal environmental benefit at high cost. A GRI-GLYCalc run showing the ineffectiveness of the condenser is included for reference.**

***** The current permit includes a source called 'Methanol Unloading'; this source should not be included in the issued permit as the 'methanol tanks' sources include all emissions associated with methanol.**

Fugitive Emission Summary Sheet(s)

ATTACHMENT J – FUGITIVE EMISSIONS SUMMARY SHEET

Sources of fugitive emissions may include loading operations, equipment leaks, blowdown emissions, etc.
Use extra pages for each associated source or equipment if necessary.

Source/Equipment: Fugitive Emissions

Leak Detection Method Used	<input type="checkbox"/> Audible, visual, and olfactory (AVO) inspections	<input type="checkbox"/> Infrared (FLIR) cameras	<input type="checkbox"/> Other (please describe)	<input type="checkbox"/> None required
----------------------------	---	--	--	--

Is the facility subject to quarterly LDAR monitoring under 40CFR60 Subpart OOOOa? Yes No. If no, why?

Component Type	Closed Vent System	Count	Source of Leak Factors (EPA, other (specify))	Stream type (gas, liquid, etc.)	Estimated Emissions (tpy)		
					VOC	HAP	GHG (CO _{2e})
Pumps	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	3	U.S. EPA. Office of Air Quality Planning and Standards. Protocol for Equipment Leak Emission Estimates. Table 2-1. (EPA-453/R-95-017, 1995).	<input type="checkbox"/> Gas <input checked="" type="checkbox"/> Liquid <input type="checkbox"/> Both	0.58	<0.01	0.13
Valves	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	204	U.S. EPA. Office of Air Quality Planning and Standards. Protocol for Equipment Leak Emission Estimates. Table 2-1. (EPA-453/R-95-017, 1995).	<input checked="" type="checkbox"/> Gas <input type="checkbox"/> Liquid <input type="checkbox"/> Both	0.04	<0.01	24.70
Safety Relief Valves	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	10	U.S. EPA. Office of Air Quality Planning and Standards. Protocol for Equipment Leak Emission Estimates. Table 2-1. (EPA-453/R-95-017, 1995).	<input checked="" type="checkbox"/> Gas <input type="checkbox"/> Liquid <input type="checkbox"/> Both	0.04	<0.01	1.79
Open Ended Lines	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6	U.S. EPA. Office of Air Quality Planning and Standards. Protocol for Equipment Leak Emission Estimates. Table 2-1. (EPA-453/R-95-017, 1995).	<input type="checkbox"/> Gas <input type="checkbox"/> Liquid <input checked="" type="checkbox"/> Both	3.7E-04	<0.01	1.64
Sampling Connections	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	---	N/A	<input type="checkbox"/> Gas <input type="checkbox"/> Liquid <input type="checkbox"/> Both	---	---	---
Connections (Not sampling)	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	887	U.S. EPA. Office of Air Quality Planning and Standards. Protocol for Equipment Leak Emission Estimates. Table 2-1. (EPA-453/R-95-017, 1995).	<input type="checkbox"/> Gas <input type="checkbox"/> Liquid <input checked="" type="checkbox"/> Both	0.06	<0.01	11.92
Compressors	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	6	U.S. EPA. Office of Air Quality Planning and Standards. Protocol for Equipment Leak Emission Estimates. Table 2-1. (EPA-453/R-95-017, 1995).	<input checked="" type="checkbox"/> Gas <input type="checkbox"/> Liquid <input type="checkbox"/> Both	0.05	<0.01	112.19
Flanges	<input type="checkbox"/> Yes <input type="checkbox"/> No	---	(included in connections)	<input type="checkbox"/> Gas <input type="checkbox"/> Liquid <input type="checkbox"/> Both	---	---	---
Other ¹	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	40	40 CFR 98 Subpart W	<input checked="" type="checkbox"/> Gas <input type="checkbox"/> Liquid <input type="checkbox"/> Both	0.39	<0.01	358.71

¹ Other equipment types may include compressor seals, relief valves, diaphragms, drains, meters, etc.

Please indicate if there are any closed vent bypasses (include component):

Specify all equipment used in the closed vent system (e.g. VRU, ERD, thief hatches, tanker truck loading, etc.)

Storage Vessel Data Sheet(s)

ATTACHMENT K – STORAGE VESSEL DATA SHEET

Complete this data sheet if you are the owner or operator of a storage vessel that contains condensate and/or produced water. This form must be completed for *each* new or modified bulk liquid storage vessel(s) that contains condensate and/or produced water. (If you have more than one (1) identical tank (i.e. 4-400 bbl condensate tanks), then you can list all on one (1) data sheet). **Include gas sample analysis, flashing emissions, working and breathing losses, USEPA Tanks, simulation software (ProMax, E&P Tanks, HYSYS, etc.), and any other supporting documents where applicable.**

The following information is REQUIRED:

- Composition of the representative sample used for the simulation
- For each stream that contributes to flashing emissions:
 - Temperature and pressure (inlet and outlet from separator(s))
 - Simulation-predicted composition
 - Molecular weight
 - Flow rate
- Resulting flash emission factor or flashing emissions from simulation
- Working/breathing loss emissions from tanks and/or loading emissions if simulation is used to quantify those emissions

Additional information may be requested if necessary.

GENERAL INFORMATION

1. Bulk Storage Area Name Hamilton Compressor Station	2. Tank Name Waste Fluids Tank(s)
3. Emission Unit ID number T10 & T11	4. Emission Point ID number T10 & T11
5. Date Installed , Modified or Relocated (<i>for existing tanks</i>) 2014 (T011) Was the tank manufactured after August 23, 2011? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	6. Type of change: <input checked="" type="checkbox"/> New construction (T10) <input type="checkbox"/> New stored material <input type="checkbox"/> Other <input type="checkbox"/> Relocation
7A. Description of Tank Modification (<i>if applicable</i>) N/A	
7B. Will more than one material be stored in this tank? <i>If so, a separate form must be completed for each material.</i> <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	
7C. Was USEPA Tanks simulation software utilized? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	

If Yes, please provide the appropriate documentation and items 8-42 below are not required.

TANK CONSTRUCTION AND OPERATION INFORMATION			
21. Tank Shell Construction: <input checked="" type="checkbox"/> Riveted <input type="checkbox"/> Gunitite lined <input type="checkbox"/> Epoxy-coated rivets <input type="checkbox"/> Other (describe)			
21A. Shell Color:	21B. Roof Color:	21C. Year Last Painted:	
22. Shell Condition (if metal and unlined): <input type="checkbox"/> No Rust <input checked="" type="checkbox"/> Light Rust <input type="checkbox"/> Dense Rust <input type="checkbox"/> Not applicable			
22A. Is the tank heated? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	22B. If yes, operating temperature:	22C. If yes, how is heat provided to tank?	
23. Operating Pressure Range (psig): TBD Must be listed for tanks using VRUs with closed vent system.			
24. Is the tank a Vertical Fixed Roof Tank ? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	24A. If yes, for dome roof provide radius (ft):	24B. If yes, for cone roof, provide slop (ft/ft):	
25. Complete item 25 for Floating Roof Tanks <input type="checkbox"/> Does not apply <input checked="" type="checkbox"/>			
25A. Year Internal Floaters Installed:			
25B. Primary Seal Type (<i>check one</i>): <input type="checkbox"/> Metallic (mechanical) shoe seal <input type="checkbox"/> Liquid mounted resilient seal <input type="checkbox"/> Vapor mounted resilient seal <input type="checkbox"/> Other (describe):			
25C. Is the Floating Roof equipped with a secondary seal? <input type="checkbox"/> Yes <input type="checkbox"/> No			
25D. If yes, how is the secondary seal mounted? (<i>check one</i>) <input type="checkbox"/> Shoe <input type="checkbox"/> Rim <input type="checkbox"/> Other (describe):			
25E. Is the floating roof equipped with a weather shield? <input type="checkbox"/> Yes <input type="checkbox"/> No			
25F. Describe deck fittings:			
26. Complete the following section for Internal Floating Roof Tanks <input checked="" type="checkbox"/> Does not apply			
26A. Deck Type: <input type="checkbox"/> Bolted <input type="checkbox"/> Welded	26B. For bolted decks, provide deck construction:		
26C. Deck seam. Continuous sheet construction: <input type="checkbox"/> 5 ft. wide <input type="checkbox"/> 6 ft. wide <input type="checkbox"/> 7 ft. wide <input type="checkbox"/> 5 x 7.5 ft. wide <input type="checkbox"/> 5 x 12 ft. wide <input type="checkbox"/> other (describe)			
26D. Deck seam length (ft.):	26E. Area of deck (ft ²):	26F. For column supported tanks, # of columns:	26G. For column supported tanks, diameter of column:
27. Closed Vent System with VRU? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
28. Closed Vent System with Enclosed Combustor? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No			
SITE INFORMATION - Not Applicable: Tank calculations performed using E&P TANK software			
29. Provide the city and state on which the data in this section are based:			
30. Daily Avg. Ambient Temperature (°F):		31. Annual Avg. Maximum Temperature (°F):	
32. Annual Avg. Minimum Temperature (°F):		33. Avg. Wind Speed (mph):	
34. Annual Avg. Solar Insulation Factor (BTU/ft ² -day):		35. Atmospheric Pressure (psia):	
LIQUID INFORMATION - Not Applicable: Tank calculations performed using E&P TANK software			
36. Avg. daily temperature range of bulk liquid (°F):	36A. Minimum (°F):	36B. Maximum (°F):	
37. Avg. operating pressure range of tank (psig):	37A. Minimum (psig):	37B. Maximum (psig):	
38A. Minimum liquid surface temperature (°F):		38B. Corresponding vapor pressure (psia):	
39A. Avg. liquid surface temperature (°F):		39B. Corresponding vapor pressure (psia):	
40A. Maximum liquid surface temperature (°F):		40B. Corresponding vapor pressure (psia):	
41. Provide the following for each liquid or gas to be stored in the tank. Add additional pages if necessary.			
41A. Material name and composition:			
41B. CAS number:			
41C. Liquid density (lb/gal):			
41D. Liquid molecular weight (lb/lb-mole):			
41E. Vapor molecular weight (lb/lb-mole):			
41F. Maximum true vapor pressure (psia):			
41G. Maximum Reid vapor pressure (psia):			
41H. Months Storage per year. From: To:			
42. Final maximum gauge pressure and temperature prior to transfer into tank used as inputs into flashing emission calculations.			

STORAGE TANK DATA TABLE

List all deminimis storage tanks (i.e. lube oil, glycol, diesel etc.)

Source ID # ¹	Status ²	Content ³	Volume ⁴
T01	New	Coolant (EG)	1,260 gallons
T02	New	Coolant (EG)	1,260 gallons
T03	New	Methanol	335 gallons
T04	New	Methanol	335 gallons
T05	New	Methanol	335 gallons
T06	New	Methanol	335 gallons
T07	New	Methanol	335 gallons
T08	New	Methanol	335 gallons
T12	Existing	Triethylene Glycol	500 gallons
T13	New	Triethylene Glycol	500 gallons
T14	New	Engine Oil	500 gallons
T15	New	Engine Oil	500 gallons
T16	New	Engine Oil	500 gallons
T17	New	Engine Oil	500 gallons
T18	New	Engine Oil	500 gallons
T19	New	Engine Oil	500 gallons
T20	New	Compressor Oil	500 gallons
T21	New	Compressor Oil	500 gallons
T22	New	Compressor Oil	500 gallons
T23	New	Compressor Oil	500 gallons
T24	New	Compressor Oil	500 gallons
T25	New	Compressor Oil	500 gallons

1. Enter the appropriate Source Identification Numbers (Source ID #) for each storage tank located at the compressor station. Tanks should be designated T01, T02, T03, etc.
2. Enter storage tank Status using the following:
 EXIST Existing Equipment
 NEW Installation of New Equipment
 REM Equipment Removed
3. Enter storage tank content such as condensate, pipeline liquids, glycol (DEG or TEG), lube oil, diesel, mercaptan etc.
4. Enter the maximum design storage tank volume in gallons.

Natural Gas Fired Fuel Burning Unit Data Sheet(s)

**ATTACHMENT L – SMALL HEATERS AND REBOILERS NOT SUBJECT TO
40CFR60 SUBPART DC
DATA SHEET**

Complete this data sheet for each small heater and reboiler not subject to 40CFR60 Subpart Dc at the facility. *The Maximum Design Heat Input (MDHI) must be less than 10 MMBTU/hr.*

Emission Unit ID# ¹	Emission Point ID# ²	Emission Unit Description (manufacturer, model #)	Year Installed/ Modified	Type ³ and Date of Change	Maximum Design Heat Input (MMBTU/hr) ⁴	Fuel Heating Value (BTU/scf) ⁵
REB-1	REB-1	Reboiler	2014	Existing	1.5	1,031
REB-2	REB-2	Reboiler	TBD	New	1.5	1,031

- ¹ Enter the appropriate Emission Unit (or Source) identification number for each fuel burning unit located at the production pad. Gas Producing Unit Burners should be designated GPU-1, GPU-2, etc. Heater Treaters should be designated HT-1, HT-2, etc. Heaters or Line Heaters should be designated LH-1, LH-2, etc. For sources, use 1S, 2S, 3S...or other appropriate designation. Enter glycol dehydration unit Reboiler Vent data on the Glycol Dehydration Unit Data Sheet.
- ² Enter the appropriate Emission Point identification numbers for each fuel burning unit located at the production pad. Gas Producing Unit Burners should be designated GPU-1, GPU-2, etc. Heater Treaters should be designated HT-1, HT-2, etc. Heaters or Line Heaters should be designated LH-1, LH-2, etc. For emission points, use 1E, 2E, 3E...or other appropriate designation.
- ³ New, modification, removal
- ⁴ Enter design heat input capacity in MMBtu/hr.
- ⁵ Enter the fuel heating value in BTU/standard cubic foot.

Internal Combustion Engine Data Sheet(s)

ATTACHMENT M – INTERNAL COMBUSTION ENGINE DATA SHEET

Complete this data sheet for each internal combustion engine at the facility. Include manufacturer performance data sheet(s) or any other supporting document if applicable. Use extra pages if necessary. *Generator(s) and microturbine generator(s) shall also use this form.*

Emission Unit ID# ¹		CE-1 to CE-6		GE-1		GE-2		MT-1	
Engine Manufacturer/Model		Caterpillar G3606TALE		Cummins 14.2 L		Power Solutions, Inc. (PSI) Vortec 5.7 L		Flex Energy GT250S	
Manufacturers Rated bhp/rpm		1,775		304		85		335	
Source Status ²		New		New		Existing		New	
Date Installed/ Modified/Removed/Relocated ³		TBD		TBD		2014		TBD	
Engine Manufactured /Reconstruction Date ⁴		TBD		TBD		2014-15		TBD	
Check all applicable Federal Rules for the engine (include EPA Certificate of Conformity if applicable) ⁵		<input checked="" type="checkbox"/> 40CFR60 Subpart JJJJ <input type="checkbox"/> JJJJ Certified? <input type="checkbox"/> 40CFR60 Subpart IIII <input type="checkbox"/> IIII Certified? <input type="checkbox"/> 40CFR63 Subpart ZZZZ <input type="checkbox"/> NESHAP ZZZZ/ NSPS JJJJ Window <input type="checkbox"/> NESHAP ZZZZ Remote Sources		<input checked="" type="checkbox"/> 40CFR60 Subpart JJJJ <input checked="" type="checkbox"/> JJJJ Certified? <input type="checkbox"/> 40CFR60 Subpart IIII <input type="checkbox"/> IIII Certified? <input type="checkbox"/> 40CFR63 Subpart ZZZZ <input type="checkbox"/> NESHAP ZZZZ/ NSPS JJJJ Window <input type="checkbox"/> NESHAP ZZZZ Remote Sources		<input checked="" type="checkbox"/> 40CFR60 Subpart JJJJ <input checked="" type="checkbox"/> JJJJ Certified? <input type="checkbox"/> 40CFR60 Subpart IIII <input type="checkbox"/> IIII Certified? <input type="checkbox"/> 40CFR63 Subpart ZZZZ <input type="checkbox"/> NESHAP ZZZZ/ NSPS JJJJ Window <input type="checkbox"/> NESHAP ZZZZ Remote Sources		<input type="checkbox"/> 40CFR60 Subpart JJJJ <input type="checkbox"/> JJJJ Certified? <input type="checkbox"/> 40CFR60 Subpart IIII <input type="checkbox"/> IIII Certified? <input type="checkbox"/> 40CFR63 Subpart ZZZZ <input type="checkbox"/> NESHAP ZZZZ/ NSPS JJJJ Window <input type="checkbox"/> NESHAP ZZZZ Remote Sources	
Engine Type ⁶		4SLB		4SRB		4SRB		Turbine	
APCD Type ⁷		OxCat		LEC		LEC		LEC	
Fuel Type ⁸		PQ		PQ		PQ		PQ	
H ₂ S (gr/100 scf)		Neg.		Neg.		Neg.		Neg.	
Operating bhp/rpm		1,775		304		85		335	
BSFC (BTU/bhp-hr)		7,609		N/A		N/A		N/A	
Hourly Fuel Throughput		13,101 ft ³ /hr		2,571 ft ³ /hr		720 ft ³ /hr		3,172 ft ³ /hr	
Annual Fuel Throughput (Must use 8,760 hrs/yr unless emergency generator)		114.8 MMft ³ /yr		1.3 MMft ³ /yr		6.3 MMft ³ /yr		27.8 MMft ³ /yr	
Fuel Usage or Hours of Operation Metered		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>		Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>	
Calculation Methodology⁹	Pollutant¹⁰	Hourly PTE (lb/hr)¹¹	Annual PTE (tpy)¹¹	Hourly PTE (lb/hr)¹¹	Annual PTE (tpy)¹¹	Hourly PTE (lb/hr)¹¹	Annual PTE (tpy)¹¹	Hourly PTE (lb/hr)¹¹	0.49
See Emissions Calculations	NO _x	1.96	8.58	1.35	0.34	0.19	0.82	0.11	1.23
See Emissions Calculations	CO	0.54	2.37	2.70	0.67	0.37	1.64	0.28	0.27
See Emissions Calculations	VOC	0.99	4.34	0.70	0.18	0.15	0.64	0.06	4.87 E-02
See Emissions Calculations	SO ₂	0.01	0.03	1.56E-03	3.90E-04	4.36 E-04	1.91 E-03	1.11 E-02	0.09
See Emissions Calculations	PM ₁₀	0.13	0.59	0.05	0.01	0.01	0.06	0.02	0.01
See Emissions Calculations	Formaldehyde	0.20	0.88	0.05	0.01	0.02	0.07	2.32 E-03	0.01
See Emissions Calculations	Total HAPs	0.46	2.02	0.09	0.02	0.02	0.11	3.36 E-03	1,677
See Emissions Calculations	GHG (CO ₂ e)	2,251	9,859	310	78	87	381	383	

1 Enter the appropriate Source Identification Number for each natural gas-fueled reciprocating internal combustion compressor/generator engine located at the compressor station. Multiple compressor engines should be designated CE-1, CE-2, CE-3 etc. Generator engines should be designated GE-1, GE-2, GE-3 etc. Microturbine generator engines should be designated MT-1, MT-2, MT-3 etc. If more than three (3) engines exist, please use additional sheets.

2 Enter the Source Status using the following codes:

NS	Construction of New Source (installation)	ES	Existing Source
MS	Modification of Existing Source	RS	Relocated Source
REM	Removal of Source		

3 Enter the date (or anticipated date) of the engine's installation (construction of source), modification, relocation or removal.

4 Enter the date that the engine was manufactured, modified or reconstructed.

5 Is the engine a certified stationary spark ignition internal combustion engine according to 40CFR60 Subpart IIII/JJJJ? If so, the engine and control device must be operated and maintained in accordance with the manufacturer's emission-related written instructions. You must keep records of conducted maintenance to demonstrate compliance, but no performance testing is required. If the certified engine is not operated and maintained in accordance with the manufacturer's emission-related written instructions, the engine will be considered a non-certified engine and you must demonstrate compliance as appropriate.

Provide a manufacturer's data sheet for all engines being registered.

6 Enter the Engine Type designation(s) using the following codes:

2SLB	Two Stroke Lean Burn	4SRB	Four Stroke Rich Burn
4SLB	Four Stroke Lean Burn		

7 Enter the Air Pollution Control Device (APCD) type designation(s) using the following codes:

A/F	Air/Fuel Ratio	IR	Ignition Retard
HEIS	High Energy Ignition System	SIPC	Screw-in Precombustion Chambers
PSC	Prestratified Charge	LEC	Low Emission Combustion
NSCR	Rich Burn & Non-Selective Catalytic Reduction	OxCat	Oxidation Catalyst
SCR	Lean Burn & Selective Catalytic Reduction		

8 Enter the Fuel Type using the following codes:

PQ	Pipeline Quality Natural Gas	RG	Raw Natural Gas /Production Gas	D	Diesel
----	------------------------------	----	---------------------------------	---	--------

9 Enter the Potential Emissions Data Reference designation using the following codes. Attach all reference data used.

MD	Manufacturer's Data	AP	AP-42	
GR	GRI-HAPCalc™	OT	Other	(please list)

10 Enter each engine's Potential to Emit (PTE) for the listed regulated pollutants in pounds per hour and tons per year. PTE shall be calculated at manufacturer's rated brake horsepower and may reflect reduction efficiencies of listed Air Pollution Control Devices. Emergency generator engines may use 500 hours of operation when calculating PTE. PTE data from this data sheet shall be incorporated in the *Emissions Summary Sheet*.

11 PTE for engines shall be calculated from manufacturer's data unless unavailable.

Engine Air Pollution Control Device
(Emission Unit ID# CE-1 to CE-6, use extra pages as necessary)

Air Pollution Control Device Manufacturer's Data Sheet included?
 Yes No

NSCR SCR Oxidation Catalyst

Provide details of process control used for proper mixing/control of reducing agent with gas stream:
 N/A

Manufacturer: DCL (or equivalent)	Model #: DC64AL2-16 (or equivalent)
Design Operating Temperature: 847 °F	Design gas volume: 12,213 acfm
Service life of catalyst: 1 year or 8,000 hours	Provide manufacturer data? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
Volume of gas handled: 12,213 acfm at 847 °F	Operating temperature range for NSCR/Ox Cat: From TBD °F to TBD °F
Reducing agent used, if any: N/A	Ammonia slip (ppm): N/A

Pressure drop against catalyst bed (delta P): TBD inches of H₂O

Provide description of warning/alarm system that protects unit when operation is not meeting design conditions:
 TBD

Is temperature and pressure drop of catalyst required to be monitored per 40CFR63 Subpart ZZZZ?
 Yes No

How often is catalyst recommended or required to be replaced (hours of operation)?
 TBD

How often is performance test required?
 Initial
 Annual
 Every 8,760 hours of operation
 Field Testing Required
 No performance test required. If so, why (please list any maintenance required and the applicable sections in NSPS/GACT,

Tanker Truck Loading Data Sheet(s)

ATTACHMENT N – TANKER TRUCK LOADING DATA SHEET

Complete this data sheet for each new or modified bulk liquid transfer area or loading rack at the facility. This is to be used for bulk liquid transfer operations to tanker trucks. Use extra pages if necessary.

Truck Loadout Collection Efficiencies

The following applicable capture efficiencies of a truck loadout are allowed:

- For tanker trucks passing the MACT level annual leak test – 99.2%
- For tanker trucks passing the NSPS level annual leak test – 98.7%
- For tanker trucks not passing one of the annual leak tests listed above – 70%

Compliance with this requirement shall be demonstrated by keeping records of the applicable MACT or NSPS Annual Leak Test certification for *every* truck and railcar loaded/unloaded. This requirement can be satisfied if the trucking company provided certification that its entire fleet was compliant. This certification must be submitted in writing to the Director of the DAQ. These additional requirements must be noted in the Registration Application and will be noted on the issued G35-D Registration.

Emission Unit ID#: L01	Emission Point ID#: L01	Year Installed/Modified: N/A		
Emission Unit Description: Liquid loading of waste fluids				
Loading Area Data				
Number of Pumps: 2	Number of Liquids Loaded: 1	Max number of trucks loading at one (1) time: 1		
Are tanker trucks pressure tested for leaks at this or any other location? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No <input checked="" type="checkbox"/> Not Required				
If Yes, Please describe:				
Provide description of closed vent system and any bypasses. N/A				
Are any of the following truck loadout systems utilized?				
<input type="checkbox"/> Closed System to tanker truck passing a MACT level annual leak test?				
<input type="checkbox"/> Closed System to tanker truck passing a NSPS level annual leak test?				
<input type="checkbox"/> Closed System to tanker truck not passing an annual leak test and has vapor return?				
Projected Maximum Operating Schedule (for rack or transfer point as a whole)				
Time	Jan – Mar	Apr - Jun	Jul – Sept	Oct - Dec
Hours/day	2	2	2	2
Days/week	5	5	5	5
Bulk Liquid Data (use extra pages as necessary)				
Liquid Name	Waste Fluids			
Max. Daily Throughput (1000 gal/day)	0.84			
Max. Annual Throughput (1000 gal/yr)	307.44			
Loading Method ¹	SP			
Max. Fill Rate (gal/min)	TBD			
Average Fill Time (min/loading)	TBD			
Max. Bulk Liquid Temperature (°F)	52.14			
True Vapor Pressure ²	0.3240			
Cargo Vessel Condition ³	U			
Control Equipment or Method ⁴	None			

Max. Collection Efficiency (%)		0		
Max. Control Efficiency (%)		0		
Max.VOC Emission Rate	Loading (lb/hr)	See attached emissions calculations		
	Annual (ton/yr)			
Max.HAP Emission Rate	Loading (lb/hr)			
	Annual (ton/yr)			
Estimation Method ⁵		EPA		

- 1 BF Bottom Fill SP Splash Fill SUB Submerged Fill
- 2 At maximum bulk liquid temperature
- 3 B Ballasted Vessel C Cleaned U Uncleaned (dedicated service)
- O Other (describe)
- 4 List as many as apply (complete and submit appropriate Air Pollution Control Device Sheets)
- CA Carbon Adsorption VB Dedicated Vapor Balance (closed system)
- ECD Enclosed Combustion Device F Flare
- TO Thermal Oxidization or Incineration
- 5 EPA EPA Emission Factor in AP-42 MB Material Balance
- TM Test Measurement based upon test data submittal O Other (describe)

Glycol Dehydration Unit Data Sheet(s)

ATTACHMENT O – GLYCOL DEHYDRATION UNIT DATA SHEET

Complete this data sheet for each Glycol Dehydration Unit, Reboiler, Flash Tank and/or Regenerator at the facility. Include gas sample analysis and GRI- GLYCalc™ input and aggregate report. Use extra pages if necessary.

Manufacturer: Source Designation TEG-1 & TEG-2	Model: 75 MMSCFD
Max. Dry Gas Flow Rate: 75 mmscf/day	Reboiler Design Heat Input: 1.5 MMBTU/hr
Design Type: <input checked="" type="checkbox"/> TEG <input type="checkbox"/> DEG <input type="checkbox"/> EG	Source Status ¹ : Existing & New
Date Installed/Modified/Removed ² : 2014 & TBD	Regenerator Still Vent APCD/ERD ³ : N/A (see notes below)
Control Device/ERD ID# ³ : N/A (see notes below)	Fuel HV (BTU/scf): 1,031
H ₂ S Content (gr/100 scf): neg.	Operation (hours/year): 8,760
Pump Rate (scfm): 15 gpm glycol	
Water Content (wt %) in: Wet Gas: Saturated Dry Gas: 7.0 lbs/MMscf	
<p>Is the glycol dehydration unit exempt from 40CFR63 Section 764(d)? <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No: If Yes, answer the following:</p> <p>The actual annual average flowrate of natural gas to the glycol dehydration unit is less than 85 thousand standard cubic meters per day, as determined by the procedures specified in §63.772(b)(1) of this subpart. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>The actual average emissions of benzene from the glycol dehydration unit process vent to the atmosphere are less than 0.90 megagram per year (1 ton per year), as determined by the procedures specified in §63.772(b)(2) of this subpart. <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No</p>	
<p>Is the glycol dehydration unit located within an Urbanized Area (UA) or Urban Cluster (UC)? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>	
<p>Is a lean glycol pump optimization plan being utilized? <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>	
<p>Recycling the glycol dehydration unit back to the flame zone of the reboiler. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p> <p>If yes: Is the reboiler configured to accept flash drum vapors (straight from the glycol dehydrator)? <input type="checkbox"/> Yes <input type="checkbox"/> No Is the reboiler configured to accept still vent vapors (after a condenser)? <input type="checkbox"/> Yes <input type="checkbox"/> No Is the reboiler configured to accept both in the same operation? <input type="checkbox"/> Yes <input type="checkbox"/> No</p> <p>Recycling the glycol dehydration unit back to the flame zone of the reboiler and mixed with fuel. <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No</p>	
<p>What happens when temperature controller shuts off fuel to the reboiler? <input checked="" type="checkbox"/> Still vent emissions to the atmosphere. <input type="checkbox"/> Still vent emissions stopped with valve. <input type="checkbox"/> Still vent emissions to glow plug.</p>	
<p>Please indicate if the following equipment is present. <input checked="" type="checkbox"/> Flash Tank <input type="checkbox"/> Burner management system that continuously burns condenser or flash tank vapors</p>	
Control Device Technical Data	
Pollutants Controlled	Manufacturer's Guaranteed Control Efficiency (%)
<p>Both dehydration units will utilize flash tanks, which recover the gas entrained in the rich glycol for use as fuel in the reboiler burner.</p> <p>The existing dehydration unit (TEG-1) is permitted with a condenser. However, this control device has negligible impact on emissions, as there is no detectable level of heavy hydrocarbons (ex. benzene, toluene, etc.) in the gas. Therefore, the applicant is requesting the removal of this control device from the issued permit, as it provides minimal environmental benefit at high cost. A GRI-GLYCalc run showing the ineffectiveness of the condenser is included for reference.</p>	

Emissions Data					
Emission Unit ID / Emission Point ID ⁴	Description	Calculation Methodology ⁵	PTE ⁶	Controlled Maximum Hourly Emissions (lb/hr)	Controlled Maximum Annual Emissions (tpy)
REB-1 & REB-2	Reboiler Vent	AP	NO _x	0.15	0.64
		AP	CO	0.12	0.54
		AP	VOC	0.01	0.04
		AP	SO ₂	8.7E-04	3.8E-03
		AP	PM ₁₀	0.01	0.05
		40 CFR 98	GHG (CO ₂ e)	175.68	769.47
TEG-1 & TEG-2	Glycol Regenerator Still Vent	GRI-GlyCalc™	VOC	0.25	1.11
		GRI-GlyCalc™	Benzene	<0.01	<0.01
		GRI-GlyCalc™	Toluene	<0.01	<0.01
		GRI-GlyCalc™	Ethylbenzene	<0.01	<0.01
		GRI-GlyCalc™	Xylenes	<0.01	<0.01
		GRI-GlyCalc™	n-Hexane	<0.01	<0.01
TEG-1 & TEG-2	Glycol Flash Tank	GRI-GlyCalc™	VOC	0.57	2.50
		GRI-GlyCalc™	Benzene	<0.01	<0.01
		GRI-GlyCalc™	Toluene	<0.01	<0.01
		GRI-GlyCalc™	Ethylbenzene	<0.01	<0.01
		GRI-GlyCalc™	Xylenes	<0.01	<0.01
		GRI-GlyCalc™	n-Hexane	<0.01	<0.01

- 1 Enter the Source Status using the following codes:
NS Construction of New Source ES Existing Source
MS Modification of Existing Source
- 2 Enter the date (or anticipated date) of the glycol dehydration unit's installation (construction of source), modification or removal.
- 3 Enter the Air Pollution Control Device (APCD)/Emission Reduction Device (ERD) type designation using the following codes and the device ID number:
NA None CD Condenser FL Flare
CC Condenser/Combustion Combination TO Thermal Oxidizer O Other (please list)
- 4 Enter the appropriate Emission Unit ID Numbers and Emission Point ID Numbers for the glycol dehydration unit reboiler vent and glycol regenerator still vent. The glycol dehydration unit reboiler vent and glycol regenerator still vent should be designated RBV-1 and RSV-1, respectively. If the compressor station incorporates multiple glycol dehydration units, a Glycol Dehydration Emission Unit Data Sheet shall be completed for each, using Source Identification RBV-2 and RSV-2, RBV-3 and RSV-3, etc.
- 5 Enter the Potential Emissions Data Reference designation using the following codes:
MD Manufacturer's Data AP AP-42
GR GRI-GLYCalc™ OT Other (please list)
- 6 Enter the Reboiler Vent and Glycol Regenerator Still Vent Potential to Emit (PTE) for the listed regulated pollutants in lbs per hour and tons per year. The Glycol Regenerator Still Vent potential emissions may be determined using the most recent version of the thermodynamic software model GRI-GLYCalc™ (Radian International LLC & Gas Research Institute). **Attach all referenced Potential Emissions Data (or calculations) and the GRI-GLYCalc™ Aggregate Calculations Report (shall include emissions reports, equipment reports, and stream reports) to this Glycol Dehydration Emission Unit Data Sheet(s). Backup pumps do not have to be considered as operating for purposes of PTE.** This PTE data shall be incorporated in the Emissions Summary Sheet.

Pneumatic Controller Data Sheet(s)

**ATTACHMENT P – PNEUMATIC CONTROLLERS
DATA SHEET**

Are there any continuous bleed natural gas driven pneumatic controllers at this facility that commenced construction, modification or reconstruction after August 23, 2011, and on or before September 18, 2015?

Yes No

Please list approximate number.

Are there any continuous bleed natural gas driven pneumatic controllers at this facility that commenced construction, modification or reconstruction after September 18, 2015?

Yes No

Please list approximate number.

Are there any continuous bleed natural gas driven pneumatic controllers at this facility with a bleed rate greater than 6 standard cubic feet per hour that are required based on functional needs, including but not limited to response time, safety and positive actuation that commenced construction, modification or reconstruction after August 23, 2011, and on or before September 18, 2015?

Yes No

Please list approximate number.

Are there any continuous bleed natural gas driven pneumatic controllers at this facility with a bleed rate greater than 6 standard cubic feet per hour that are required based on functional needs, including but not limited to response time, safety and positive actuation that commenced construction, modification or reconstruction after September 18, 2015?

Yes No

Please list approximate number.

Centrifugal Compressor Data Sheet(s)

**ATTACHMENT Q – CENTRIFUGAL COMPRESSOR
DATA SHEET**

Are there any centrifugal compressors at this facility that commenced construction, modification or reconstruction after August 23, 2011, and on or before September 18, 2015?

Yes No

Please list:

Emission Unit ID#	Compressor Description

Are there any centrifugal compressors at this facility that commenced construction, modification or reconstruction after September 18, 2015?

Yes No

Please list:

Emission Unit ID#	Compressor Description

Reciprocating Compressor Data Sheet(s)

**ATTACHMENT R – RECIPROCATING COMPRESSOR
DATA SHEET**

Are there any reciprocating compressors at this facility that commenced construction, modification or reconstruction after August 23, 2011, and on or before September 18, 2015?

Yes No

Please list:

Emission Unit ID#	Compressor Description

Are there any reciprocating compressors at this facility that commenced construction, modification or reconstruction after September 18, 2015?

Yes No

Please list:

Emission Unit ID#	Compressor Description
CE-1	Reciprocating Compressor #1
CE-2	Reciprocating Compressor #2
CE-3	Reciprocating Compressor #3
CE-4	Reciprocating Compressor #4
CE-5	Reciprocating Compressor #5
CE-6	Reciprocating Compressor #6

Blowdown and Pigging Operation Data Sheet(s)

**ATTACHMENT S – BLOWDOWN AND PIGGING OPERATIONS
DATA SHEET**

Will there be any blowdown and pigging operations that occur at this facility?

Yes No

Please list:

Type of Event	# of Events (event/yr)	Amount Vented per event (scf/event)	MW of vented gas (lb/lb-mol)	Total Emissions (ton/yr)	VOC weight fraction	VOC emissions (ton/yr)
Compressor Blowdown						
Compressor Startup						
Plant Shutdown						
Low Pressure Pig Venting						
High Pressure Pig Venting						

These emissions are accounted for in the emissions calculations in the ‘Miscellaneous Gas Venting’ calculations, which include all facility blowdowns and pigging operations.

Type of Event	# of Events (event/yr)	Amount Vented per event (scf/event)	MW of vented gas (lb/lb-mol)	Total Emissions (ton/yr)	HAP weight fraction	HAP emissions (ton/yr)
Compressor Blowdown						
Compressor Startup						
Plant Shutdown						
Low Pressure Pig Venting						
High Pressure Pig Venting						

These emissions are accounted for in the emissions calculations in the ‘Miscellaneous Gas Venting’ calculations, which include all facility blowdowns and pigging operations.

Air Pollution Control Device Data Sheet(s)

**ATTACHMENT T – AIR POLLUTION CONTROL DEVICE /
EMISSION REDUCTION DEVICE SHEETS**

Complete the applicable air pollution control device sheets for each flare, vapor combustor, thermal oxidizer, condenser, adsorption system, vapor recovery unit, BTEX Eliminator, Reboiler with and without Glow Plug, etc. at the facility. Use extra pages if necessary.

Emissions calculations must be performed using the most conservative control device efficiency.

The following five (5) rows are only to be completed if registering an alternative air pollution control device.

Emission Unit ID: N/A	Make/Model:
Primary Control Device ID:	Make/Model:
Control Efficiency (%):	APCD/ERD Data Sheet Completed: <input type="checkbox"/> Yes <input type="checkbox"/> No
Secondary Control Device ID:	Make/Model:
Control Efficiency (%):	APCD/ERD Data Sheet Completed: <input type="checkbox"/> Yes <input type="checkbox"/> No

VAPOR COMBUSTION (Including Enclosed Combustors)

General Information

Control Device ID#: N/A	Installation Date: <input type="checkbox"/> New <input type="checkbox"/> Modified <input type="checkbox"/> Relocated	
Maximum Rated Total Flow Capacity scfh scfd	Maximum Design Heat Input (from mfg. spec sheet) MMBTU/hr	Design Heat Content BTU/scf

Control Device Information

Type of Vapor Combustion Control?		
<input type="checkbox"/> Enclosed Combustion Device	<input type="checkbox"/> Elevated Flare	<input type="checkbox"/> Ground Flare
<input type="checkbox"/> Thermal Oxidizer		

Manufacturer: Model:	Hours of operation per year?
-------------------------	------------------------------

List the emission units whose emissions are controlled by this vapor control device (Emission Point ID# _____)

Emission Unit ID#	Emission Source Description	Emission Unit ID#	Emission Source Description

If this vapor combustor controls emissions from more than six (6) emission units, please attach additional pages.

Assist Type (Flares only)	Flare Height	Tip Diameter	Was the design per §60.18?
<input type="checkbox"/> Steam <input type="checkbox"/> Air <input type="checkbox"/> Pressure <input type="checkbox"/> Non	feet	feet	<input type="checkbox"/> Yes <input type="checkbox"/> No Provide determination.

Waste Gas Information

Maximum Waste Gas Flow Rate (scfm)	Heat Value of Waste Gas Stream BTU/ft ³	Exit Velocity of the Emissions Stream (ft/s)
------------------------------------	--	--

Provide an attachment with the characteristics of the waste gas stream to be burned.

Pilot Gas Information

Number of Pilot Lights	Fuel Flow Rate to Pilot Flame per Pilot scfh	Heat Input per Pilot BTU/hr	Will automatic re-ignition be used? <input type="checkbox"/> Yes <input type="checkbox"/> No
------------------------	--	-----------------------------	---

If automatic re-ignition is used, please describe the method.

Is pilot flame equipped with a monitor to detect the presence of the flame? <input type="checkbox"/> Yes <input type="checkbox"/> No	If Yes, what type? <input type="checkbox"/> Thermocouple <input type="checkbox"/> Infrared <input type="checkbox"/> Ultraviolet <input type="checkbox"/> Camera <input type="checkbox"/> Other:
--	--

Describe all operating ranges and maintenance procedures required by the manufacturer to maintain the warranty. *(If unavailable, please indicate).*

Additional information attached? <input type="checkbox"/> Yes <input type="checkbox"/> No	Please attach copies of manufacturer's data sheets, drawings, flame demonstration per §60.18 or §63.11(b) and performance testing.
---	--

CONDENSER

General Information

Control Device ID#: N/A	Installation Date: <input type="checkbox"/> New <input type="checkbox"/> Modified <input type="checkbox"/> Relocated	
Manufacturer:	Model:	Control Device Name:
Control Efficiency (%):		
Manufacturer's required temperature range for control efficiency. °F		
Describe the warning and/or alarm system that protects against operation when unit is not meeting the design requirements:		
Describe all operating ranges and maintenance procedures required by the manufacturer to maintain the warranty.		
Additional information attached? <input type="checkbox"/> Yes <input type="checkbox"/> No Please attach copies of manufacturer's data sheets.		
Is condenser routed to a secondary APCD or ERD? <input type="checkbox"/> Yes <input type="checkbox"/> No		

ADSORPTION SYSTEM

General Information

Control Device ID#: N/A	Installation Date: <input type="checkbox"/> New <input type="checkbox"/> Modified <input type="checkbox"/> Relocated	
Manufacturer:	Model:	Control Device Name:
Design Inlet Volume: scfm	Adsorbent charge per adsorber vessel and number of adsorber vessels:	
Length of Mass Transfer Zone supplied by the manufacturer:	Adsorber diameter: ft	Adsorber area: ft ²
Adsorbent type and physical properties:	Overall Control Efficiency (%):	
Working Capacity of Adsorbent (%):		

Operating Parameters

Inlet volume: scfm @ °F	
Adsorption time per adsorption bed (life expectancy):	Breakthrough Capacity (lbs of VOC/100 lbs of adsorbent):
Temperature range of carbon bed adsorber. °F - °F	

Control Device Technical Data

Pollutants Controlled	Manufacturer's Guaranteed Control Efficiency (%)

Describe the warning and/or alarm system that protects against operation when unit is not meeting the design requirements:

Has the control device been tested by the manufacturer and certified?

Describe all operating ranges and maintenance procedures required by the manufacturer to maintain the warranty.

Additional information attached? Yes No

Please attach copies of manufacturer's data sheets, drawings, and performance testing.

VAPOR RECOVERY UNIT

General Information

Emission Unit ID#: N/A

Installation Date:

New Modified Relocated

Device Information

Manufacturer:

Model:

List the emission units whose emissions are controlled by this vapor recovery unit (Emission Point ID#)

Emission Unit ID#	Emission Source Description	Emission Unit ID#	Emission Source Description

If this vapor recovery unit controls emissions from more than six (6) emission units, please attach additional pages.

Additional information attached? Yes No

Please attach copies of manufacturer's data sheets, drawings, and performance testing.

The registrant may claim a capture and control efficiency of 95 % (which accounts for 5% downtime) for the vapor recovery unit.

The registrant may claim a capture and control efficiency of 98% if the VRU has a backup flare that meet the requirements of Section 8.1.2 of this general permit.

The registrant may claim a capture and control efficiency of 98% if the VRU has a backup VRU.

Emission Calculations

Company Name: **M3 Appalachia Gathering, LLC**
 Facility Name: **Hamilton Compressor Station**
 Project Description: **G3SD Application**

Facility-Wide Emission Summary - Controlled

Storage Tanks: 2 per site
 Line Heaters: 0 per site
 TEGs: 0 per site
 Dehy Reboilers: 2 per site
 Glycol Dehydrators: 2 per site
 Dehy Drip Tanks: 0 per site
 Dehy Combustors: 0 per site
 Compressors: 6 per site
 High Pressure Separators: 4 per site
 Length of lease road: 6,100 feet

Carbon equivalent emissions (CO₂e) are based on the following Global Warming Potentials (GWP) from 40 CFR Part 98, Table A-1:
 CH₄ 25
 N₂O 298

Emission Point ID #	Emission Source ID#s	Emission Source Description	NO _x		CO		VOC		SO ₂		PM ₁₀		PM _{2.5}		CH ₄		CO ₂ e	
			lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
CE-1	CE-1	Caterpillar G3606 Comp. Engine	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	20.97	91.87	2,250.99	9,859.35
CE-2	CE-2	Caterpillar G3606 Comp. Engine	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	20.97	91.87	2,250.99	9,859.35
CE-3	CE-3	Caterpillar G3606 Comp. Engine	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	20.97	91.87	2,250.99	9,859.35
CE-4	CE-4	Caterpillar G3606 Comp. Engine	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	20.97	91.87	2,250.99	9,859.35
CE-5	CE-5	Caterpillar G3606 Comp. Engine	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	20.97	91.87	2,250.99	9,859.35
CE-6	CE-6	Caterpillar G3606 Comp. Engine	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	20.97	91.87	2,250.99	9,859.35
GE-1	GE-1	Generac 14.2 L Generator Engine	1.35	0.34	2.70	0.67	0.70	0.18	1.6E-03	3.9E-04	0.05	0.01	0.05	0.01	0.01	0.00	310.42	77.61
GE-2	GE-2	PSI 5.7 L Generator Engine	0.19	0.82	0.37	1.64	0.15	0.64	4.4E-04	1.9E-03	0.01	0.06	0.01	0.06	0.00	0.01	86.93	380.77
MT-1	MT-1	Flex Energy GT250S Microturbine	0.11	0.49	0.28	1.23	0.06	0.27	0.01	0.05	0.02	0.09	0.02	0.09	0.01	0.03	382.98	1,677.44
TEG-1	TEG-1	75 MMSCFD Dehydration Unit	---	---	---	---	0.99	4.34	---	---	---	---	---	---	176.97	775.12	4,424.21	19,378.05
TEG-2	TEG-2	75 MMSCFD Dehydration Unit	---	---	---	---	0.99	4.34	---	---	---	---	---	---	176.97	775.12	4,424.21	19,378.05
REB-1	REB-1	1.5 MMbtu/hr Reboiler	0.15	0.64	0.12	0.54	0.01	0.04	8.7E-04	3.8E-03	0.01	0.05	0.01	0.05	3.3E-03	0.01	175.68	769.47
REB-2	REB-2	1.5 MMbtu/hr Reboiler	0.15	0.64	0.12	0.54	0.01	0.04	8.7E-04	3.8E-03	0.01	0.05	0.01	0.05	3.3E-03	0.01	175.68	769.47
T10	T10	Waste Fluids Tank	---	---	---	---	0.05	0.23	---	---	---	---	---	---	1.4E-03	0.01	0.03	0.15
T11	T11	Waste Fluids Tank	---	---	---	---	0.05	0.23	---	---	---	---	---	---	1.4E-03	0.01	0.03	0.15
---	---	De minimis storage tanks	---	---	---	---	2.5E-03	0.01	---	---	---	---	---	---	---	---	---	---
L01	L01	Liquid Loading	---	---	---	---	0.05	0.01	---	---	---	---	---	---	---	---	---	---
---	---	Fugitives	---	---	---	---	---	1.57	---	---	---	---	---	---	---	122.78	---	3,069.47
---	---	Haul Roads	---	---	---	---	---	---	---	---	0.19	---	0.02	---	---	---	---	---
Facility Total			13.70	54.43	6.84	18.80	9.01	37.91	0.06	0.27	0.92	4.00	0.92	3.83	479.81	2,224.32	23,486.13	104,656.68
Facility Total (excluding fugitive emissions)			13.70	54.43	6.84	18.80	9.01	36.34	0.06	0.27	0.92	3.81	0.92	3.81	479.81	2,101.55	23,486.13	101,587.21

Emission Point ID #	Emission Source ID#s	Emission Source Description	Formaldehyde		Benzene		Toluene		Ethylbenzene		Xylenes		n-Hexane		Total BTEX		Total HAP	
			lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
CE-1	CE-1	Caterpillar G3606 Comp. Engine	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.01	0.06	0.46	2.02
CE-2	CE-2	Caterpillar G3606 Comp. Engine	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.01	0.06	0.46	2.02
CE-3	CE-3	Caterpillar G3606 Comp. Engine	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.01	0.06	0.46	2.02
CE-4	CE-4	Caterpillar G3606 Comp. Engine	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.01	0.06	0.46	2.02
CE-5	CE-5	Caterpillar G3606 Comp. Engine	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.01	0.06	0.46	2.02
CE-6	CE-6	Caterpillar G3606 Comp. Engine	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.01	0.06	0.46	2.02
GE-1	GE-1	Generac 14.2 L Generator Engine	0.05	0.01	6.6E-05	1.6E-05	3.4E-05	1.5E-04	5.2E-04	1.3E-04	<0.01	<0.01	<0.01	<0.01	6.2E-04	3.0E-04	0.09	0.02
GE-2	GE-2	PSI 5.7 L Generator Engine	0.02	0.07	1.8E-05	8.1E-05	9.6E-06	4.2E-05	1.4E-04	6.3E-04	<0.01	<0.01	<0.01	<0.01	1.7E-04	7.6E-04	0.02	0.11
MT-1	MT-1	Flex Energy GT250S Microturbine	2.3E-03	0.01	3.9E-05	1.7E-04	4.3E-04	1.9E-03	1.0E-04	4.6E-04	2.1E-04	9.2E-04	---	---	7.8E-04	3.4E-03	3.4E-03	0.01
TEG-1	TEG-1	75 MMSCFD Dehydration Unit	---	---	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01
TEG-2	TEG-2	75 MMSCFD Dehydration Unit	---	---	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01
REB-1	REB-1	1.5 MMbtu/hr Reboiler	1.1E-04	4.8E-04	3.1E-06	1.3E-05	4.9E-06	2.2E-05	---	---	---	---	2.6E-03	0.01	8.0E-06	3.5E-05	2.7E-03	0.01
REB-2	REB-2	1.5 MMbtu/hr Reboiler	1.1E-04	4.8E-04	3.1E-06	1.3E-05	4.9E-06	2.2E-05	---	---	---	---	2.6E-03	0.01	8.0E-06	3.5E-05	2.7E-03	0.01
T10	T10	Waste Fluids Tank	---	---	4.6E-04	2.0E-03	2.3E-04	1.0E-03	<0.01	<0.01	<0.01	<0.01	3.0E-03	0.01	6.8E-04	3.0E-03	4.6E-03	0.02
T11	T11	Waste Fluids Tank	---	---	4.6E-04	2.0E-03	2.3E-04	1.0E-03	<0.01	<0.01	<0.01	<0.01	3.0E-03	0.01	6.8E-04	3.0E-03	4.6E-03	0.02
---	---	De minimis storage tanks	---	---	---	---	---	---	---	---	---	---	---	---	---	---	2.5E-03	0.01
L01	L01	Liquid Loading	---	---	---	---	---	---	---	---	---	---	---	---	---	---	0.01	1.4E-03
---	---	Fugitives	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
---	---	Haul Roads	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Facility Total			1.27	5.35	0.04	0.16	0.03	0.15	4.0E-03	0.02	0.02	0.07	0.10	0.44	0.09	0.39	2.91	12.36
Facility Total (excluding fugitive emissions)			1.27	5.35	0.04	0.16	0.03	0.15	4.0E-03	0.02	0.02	0.07	0.10	0.44	0.09	0.39	2.91	12.36

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Compressor Engines

Engine Information:

Source Designation:	CE-1 to CE-6
Manufacturer:	Caterpillar
Model No.:	G3606TALE
Stroke Cycle:	4-stroke
Type of Burn:	Lean
Rated Horsepower (bhp):	1,775

Engine Fuel Information:

Fuel Type:	Natural Gas
Higher Heating Value (HHV) (Btu/scf):	1,031
Specific Fuel Consumption (Btu/bhp-hr):	7,609
Maximum Fuel Consumption at 100% Load (scf/hr):	13,101
Heat Input (MMBtu/hr):	13.51
Potential Fuel Consumption (MMBtu/yr):	118,312
Max. Fuel Consumption at 100% (MMscf/hr):	0.0131
Max. Fuel Consumption (MMscf/yr):	114.8
Max. Annual Hours of Operation (hr/yr):	8,760

Engine Emissions Data:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
NO _x	1.96	lb/hr	1.96	8.58	Manufacturer
VOC (excludes HCHO)	0.79	lb/hr	0.79	3.46	Manufacturer
VOC (includes HCHO)	---	---	0.99	4.34	VOC + HCHO
CO	0.54	lb/hr	0.54	2.37	Manufacturer
SO _x	0.001	lb/MMBtu	0.01	0.03	AP-42, Table 3.2-2 (Jul-2000)
PM ₁₀	0.01	lb/MMBtu	0.13	0.59	AP-42, Table 3.2-2 (Jul-2000)
PM _{2.5}	0.01	lb/MMBtu	0.13	0.59	AP-42, Table 3.2-2 (Jul-2000)
Formaldehyde (HCHO)	0.20	lb/hr	0.20	0.88	Manufacturer
GHG (CO ₂ e)	See Table Below		2,251	9,859	40 CFR 98, Tables C-1 & C-2
Other (Total HAP)	See Table Below		0.46	2.02	AP-42, Table 3.2-2 (Jul-2000)

Notes:

1. PM₁₀ and PM_{2.5} are total values (filterable + condensable).
2. GHG (CO₂e) is carbon dioxide equivalent, which is the summation of CO₂ (GWP = 1) + CH₄ (GWP = 25) + N₂O (GWP = 298).
3. Total HAP is the summation of all hazardous air pollutants for which there is a published emission factor for this source type.

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Compressor Engines

Greenhouse Gas (GHG) & Hazardous Air Pollutant (HAP) Emissions Calculations:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
GHGs:					
CO ₂	441	g/bhp-hr	1,725.73	7,558.71	Manufacturer
CH ₄	5.36	g/bhp-hr	20.97	91.87	Manufacturer (THC - NMHC)
N ₂ O	0.0001	kg/MMBtu	0.00	0.01	40 CFR 98, Table C-2
GHG (CO₂e)			2,251	9,859	
Organic HAPs:					
1,1,2,2-Tetrachloroethane	4.00E-05	lb/MMBtu	5.4E-04	2.4E-03	AP-42, Table 3.2-2 (Jul-2000)
1,1,2-Trichloroethane	3.18E-05	lb/MMBtu	4.3E-04	1.9E-03	AP-42, Table 3.2-2 (Jul-2000)
1,3-Butadiene	2.67E-04	lb/MMBtu	3.6E-03	1.6E-02	AP-42, Table 3.2-2 (Jul-2000)
1,3-Dichloropropene	2.64E-05	lb/MMBtu	3.6E-04	1.6E-03	AP-42, Table 3.2-2 (Jul-2000)
2-Methylnaphthalene	3.32E-05	lb/MMBtu	4.5E-04	2.0E-03	AP-42, Table 3.2-2 (Jul-2000)
2,2,4-Trimethylpentane	2.50E-04	lb/MMBtu	3.4E-03	1.5E-02	AP-42, Table 3.2-2 (Jul-2000)
Acenaphthene	1.25E-06	lb/MMBtu	1.7E-05	7.4E-05	AP-42, Table 3.2-2 (Jul-2000)
Acenaphthylene	5.53E-06	lb/MMBtu	7.5E-05	3.3E-04	AP-42, Table 3.2-2 (Jul-2000)
Acetaldehyde	8.36E-03	lb/MMBtu	1.1E-01	4.9E-01	AP-42, Table 3.2-2 (Jul-2000)
Acrolein	5.14E-03	lb/MMBtu	6.9E-02	3.0E-01	AP-42, Table 3.2-2 (Jul-2000)
Benzene	4.40E-04	lb/MMBtu	5.9E-03	2.6E-02	AP-42, Table 3.2-2 (Jul-2000)
Benzo(b)fluoranthene	1.66E-07	lb/MMBtu	2.2E-06	9.8E-06	AP-42, Table 3.2-2 (Jul-2000)
Benzo(e)pyrene	4.15E-07	lb/MMBtu	5.6E-06	2.5E-05	AP-42, Table 3.2-2 (Jul-2000)
Benzo(g,h,i)perylene	4.14E-07	lb/MMBtu	5.6E-06	2.4E-05	AP-42, Table 3.2-2 (Jul-2000)
Biphenyl	2.12E-04	lb/MMBtu	2.9E-03	1.3E-02	AP-42, Table 3.2-2 (Jul-2000)
Carbon Tetrachloride	3.67E-05	lb/MMBtu	5.0E-04	2.2E-03	AP-42, Table 3.2-2 (Jul-2000)
Chlorobenzene	3.04E-05	lb/MMBtu	4.1E-04	1.8E-03	AP-42, Table 3.2-2 (Jul-2000)
Chloroform	2.85E-05	lb/MMBtu	3.8E-04	1.7E-03	AP-42, Table 3.2-2 (Jul-2000)
Chrysene	6.93E-07	lb/MMBtu	9.4E-06	4.1E-05	AP-42, Table 3.2-2 (Jul-2000)
Ethylbenzene	3.97E-05	lb/MMBtu	5.4E-04	2.3E-03	AP-42, Table 3.2-2 (Jul-2000)
Ethylene Dibromide	4.43E-05	lb/MMBtu	6.0E-04	2.6E-03	AP-42, Table 3.2-2 (Jul-2000)
Fluoranthene	1.11E-06	lb/MMBtu	1.5E-05	6.6E-05	AP-42, Table 3.2-2 (Jul-2000)
Fluorene	5.67E-06	lb/MMBtu	7.7E-05	3.4E-04	AP-42, Table 3.2-2 (Jul-2000)
Methanol	2.50E-03	lb/MMBtu	3.4E-02	1.5E-01	AP-42, Table 3.2-2 (Jul-2000)
Methylene Chloride	2.00E-05	lb/MMBtu	2.7E-04	1.2E-03	AP-42, Table 3.2-2 (Jul-2000)
n-Hexane	1.11E-03	lb/MMBtu	1.5E-02	6.6E-02	AP-42, Table 3.2-2 (Jul-2000)
Naphthalene	7.44E-05	lb/MMBtu	1.0E-03	4.4E-03	AP-42, Table 3.2-2 (Jul-2000)
PAH	2.69E-05	lb/MMBtu	3.6E-04	1.6E-03	AP-42, Table 3.2-2 (Jul-2000)
Phenanthrene	1.04E-05	lb/MMBtu	1.4E-04	6.2E-04	AP-42, Table 3.2-2 (Jul-2000)
Phenol	2.40E-05	lb/MMBtu	3.2E-04	1.4E-03	AP-42, Table 3.2-2 (Jul-2000)
Pyrene	1.36E-06	lb/MMBtu	1.8E-05	8.0E-05	AP-42, Table 3.2-2 (Jul-2000)
Styrene	2.36E-05	lb/MMBtu	3.2E-04	1.4E-03	AP-42, Table 3.2-2 (Jul-2000)
Tetrachloroethane	2.48E-06	lb/MMBtu	3.3E-05	1.5E-04	AP-42, Table 3.2-2 (Jul-2000)
Toluene	4.08E-04	lb/MMBtu	5.5E-03	2.4E-02	AP-42, Table 3.2-2 (Jul-2000)
Vinyl Chloride	1.49E-05	lb/MMBtu	2.0E-04	8.8E-04	AP-42, Table 3.2-2 (Jul-2000)
Xylene	1.84E-04	lb/MMBtu	2.5E-03	1.1E-02	AP-42, Table 3.2-2 (Jul-2000)
Total HAP (including HCHO)			0.46	2.02	

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Emergency Generator Engine

Engine Information:

Source Designation:	GE-1
Manufacturer:	Generac
Model No.:	14.2 L
Stroke Cycle:	4-stroke
Type of Burn:	Rich
Rated Horsepower (bhp):	304
Rated Power (kW):	227

Engine Fuel Information:

Fuel Type:	Natural Gas
Higher Heating Value (HHV) (Btu/scf):	1,031
Maximum Fuel Consumption at 100% Load (scf/hr):	2,571
Heat Input (MMBtu/hr):	2.65
Potential Fuel Consumption (MMBtu/yr):	1,325
Max. Fuel Consumption at 100% (MMscf/hr):	0.0026
Max. Fuel Consumption (MMscf/yr):	1.3
Max. Annual Hours of Operation (hr/yr):	500

Engine Emissions Data:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
NO _x	2.7	g/kW-hr	1.35	0.34	EPA Certificate of Conformity
VOC (excludes HCHO)	1.3	g/kW-hr	0.65	0.16	EPA Certificate of Conformity
VOC (includes HCHO)	---	---	0.70	0.18	VOC + HCHO
CO	5.4	g/kW-hr	2.70	0.67	EPA Certificate of Conformity
SO _x	0.001	lb/MMBtu	1.56E-03	3.90E-04	AP-42, Table 3.2-3 (Aug-2000)
PM ₁₀	0.02	lb/MMBtu	0.05	0.01	AP-42, Table 3.2-3 (Aug-2000)
PM _{2.5}	0.02	lb/MMBtu	0.05	0.01	AP-42, Table 3.2-3 (Aug-2000)
Formaldehyde (HCHO)	0.02	lb/MMBtu	0.05	0.01	AP-42, Table 3.2-3 (Aug-2000)
GHG (CO ₂ e)	See Table Below		310	78	40 CFR 98, Tables C-1 & C-2
Other (Total HAP)	See Table Below		0.09	0.02	AP-42, Table 3.2-3 (Aug-2000)

Notes:

1. PM₁₀ and PM_{2.5} are total values (filterable + condensable).
2. GHG (CO₂e) is carbon dioxide equivalent, which is the summation of CO₂ (GWP = 1) + CH₄ (GWP = 25) + N₂O (GWP = 298).
3. Total HAP is the summation of all hazardous air pollutants for which there is a published emission factor for this source type.

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Emergency Generator Engine

Greenhouse Gas (GHG) & Hazardous Air Pollutant (HAP) Emissions Calculations:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
GHGs:					
CO ₂	53.06	kg/MMBtu	310.10	77.53	40 CFR 98, Table C-1
CH ₄	0.001	kg/MMBtu	5.8E-03	1.5E-03	40 CFR 98, Table C-2
N ₂ O	0.0001	kg/MMBtu	5.8E-04	1.5E-04	40 CFR 98, Table C-2
GHG (CO₂e)			310	78	
Organic HAPs:					
1,1,2,2-Tetrachloroethane	2.53E-05	lb/MMBtu	6.7E-05	1.7E-05	AP-42, Table 3.2-3 (Aug-2000)
1,1,2-Trichloroethane	1.53E-05	lb/MMBtu	4.1E-05	1.0E-05	AP-42, Table 3.2-3 (Aug-2000)
1,3-Butadiene	6.63E-04	lb/MMBtu	1.8E-03	4.4E-04	AP-42, Table 3.2-3 (Aug-2000)
1,3-Dichloropropene	1.27E-05	lb/MMBtu	3.4E-05	8.4E-06	AP-42, Table 3.2-3 (Aug-2000)
Acetaldehyde	2.79E-03	lb/MMBtu	7.4E-03	1.8E-03	AP-42, Table 3.2-3 (Aug-2000)
Acrolein	2.63E-03	lb/MMBtu	7.0E-03	1.7E-03	AP-42, Table 3.2-3 (Aug-2000)
Benzene	1.58E-03	lb/MMBtu	4.2E-03	1.0E-03	AP-42, Table 3.2-3 (Aug-2000)
Carbon Tetrachloride	1.77E-05	lb/MMBtu	4.7E-05	1.2E-05	AP-42, Table 3.2-3 (Aug-2000)
Chlorobenzene	1.29E-05	lb/MMBtu	3.4E-05	8.5E-06	AP-42, Table 3.2-3 (Aug-2000)
Chloroform	1.37E-05	lb/MMBtu	3.6E-05	9.1E-06	AP-42, Table 3.2-3 (Aug-2000)
Ethylbenzene	2.48E-05	lb/MMBtu	6.6E-05	1.6E-05	AP-42, Table 3.2-3 (Aug-2000)
Ethylene Dibromide	2.13E-05	lb/MMBtu	5.6E-05	1.4E-05	AP-42, Table 3.2-3 (Aug-2000)
Methanol	3.06E-03	lb/MMBtu	8.1E-03	2.0E-03	AP-42, Table 3.2-3 (Aug-2000)
Methylene Chloride	4.12E-05	lb/MMBtu	1.1E-04	2.7E-05	AP-42, Table 3.2-3 (Aug-2000)
Naphthalene	9.71E-05	lb/MMBtu	2.6E-04	6.4E-05	AP-42, Table 3.2-3 (Aug-2000)
PAH	1.41E-04	lb/MMBtu	3.7E-04	9.3E-05	AP-42, Table 3.2-3 (Aug-2000)
Styrene	1.19E-05	lb/MMBtu	3.2E-05	7.9E-06	AP-42, Table 3.2-3 (Aug-2000)
Toluene	5.58E-04	lb/MMBtu	1.5E-03	3.7E-04	AP-42, Table 3.2-3 (Aug-2000)
Vinyl Chloride	7.18E-06	lb/MMBtu	1.9E-05	4.8E-06	AP-42, Table 3.2-3 (Aug-2000)
Xylene	1.95E-04	lb/MMBtu	5.2E-04	1.3E-04	AP-42, Table 3.2-3 (Aug-2000)
Total HAP (including HCHO)			0.09	0.02	

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Generator Engine

Engine Information:

Source Designation:	GE-2
Manufacturer:	Power Solutions, Inc. (PSI)
Model No.:	Vortec 5.7L
Stroke Cycle:	4-stroke
Type of Burn:	Rich
Rated Horsepower (bhp):	85

Engine Fuel Information:

Fuel Type:	Natural Gas
Higher Heating Value (HHV) (Btu/scf):	1,031
Maximum Fuel Consumption at 100% Load (scf/hr):	720
Heat Input (MMBtu/hr):	0.74
Potential Fuel Consumption (MMBtu/yr):	6,502
Max. Fuel Consumption at 100% (MMscf/hr):	0.0007
Max. Fuel Consumption (MMscf/yr):	6.3
Max. Annual Hours of Operation (hr/yr):	8,760

Engine Emissions Data:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
NO _x	1.00	g/bhp-hr	0.19	0.82	EPA Certificate of Conformity
VOC (excludes HCHO)	0.70	g/bhp-hr	0.13	0.57	EPA Certificate of Conformity
VOC (includes HCHO)	---	---	0.15	0.64	VOC + HCHO
CO	2.00	g/bhp-hr	0.37	1.64	EPA Certificate of Conformity
SO _x	0.001	lb/MMBtu	4.36E-04	1.91E-03	AP-42, Table 3.2-3 (Aug-2000)
PM ₁₀	0.02	lb/MMBtu	0.01	0.06	AP-42, Table 3.2-3 (Aug-2000)
PM _{2.5}	0.02	lb/MMBtu	0.01	0.06	AP-42, Table 3.2-3 (Aug-2000)
Formaldehyde (HCHO)	0.02	lb/MMBtu	0.02	0.07	AP-42, Table 3.2-3 (Aug-2000)
GHG (CO ₂ e)	See Table Below		87	381	40 CFR 98, Tables C-1 & C-2
Other (Total HAP)	See Table Below		0.02	0.11	AP-42, Table 3.2-3 (Aug-2000)

Notes:

1. PM₁₀ and PM_{2.5} are total values (filterable + condensable).
2. GHG (CO₂e) is carbon dioxide equivalent, which is the summation of CO₂ (GWP = 1) + CH₄ (GWP = 25) + N₂O (GWP = 298).
3. Total HAP is the summation of all hazardous air pollutants for which there is a published emission factor for this source type.

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Generator Engine

Greenhouse Gas (GHG) & Hazardous Air Pollutant (HAP) Emissions Calculations:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
GHGs:					
CO ₂	53.06	kg/MMBtu	86.84	380.37	40 CFR 98, Table C-1
CH ₄	0.001	kg/MMBtu	1.6E-03	7.2E-03	40 CFR 98, Table C-2
N ₂ O	0.0001	kg/MMBtu	1.6E-04	7.2E-04	40 CFR 98, Table C-2
GHG (CO₂e)			87	381	
Organic HAPs:					
1,1,2,2-Tetrachloroethane	2.53E-05	lb/MMBtu	1.9E-05	8.2E-05	AP-42, Table 3.2-3 (Aug-2000)
1,1,2-Trichloroethane	1.53E-05	lb/MMBtu	1.1E-05	5.0E-05	AP-42, Table 3.2-3 (Aug-2000)
1,3-Butadiene	6.63E-04	lb/MMBtu	4.9E-04	2.2E-03	AP-42, Table 3.2-3 (Aug-2000)
1,3-Dichloropropene	1.27E-05	lb/MMBtu	9.4E-06	4.1E-05	AP-42, Table 3.2-3 (Aug-2000)
Acetaldehyde	2.79E-03	lb/MMBtu	2.1E-03	9.1E-03	AP-42, Table 3.2-3 (Aug-2000)
Acrolein	2.63E-03	lb/MMBtu	2.0E-03	8.6E-03	AP-42, Table 3.2-3 (Aug-2000)
Benzene	1.58E-03	lb/MMBtu	1.2E-03	5.1E-03	AP-42, Table 3.2-3 (Aug-2000)
Carbon Tetrachloride	1.77E-05	lb/MMBtu	1.3E-05	5.8E-05	AP-42, Table 3.2-3 (Aug-2000)
Chlorobenzene	1.29E-05	lb/MMBtu	9.6E-06	4.2E-05	AP-42, Table 3.2-3 (Aug-2000)
Chloroform	1.37E-05	lb/MMBtu	1.0E-05	4.5E-05	AP-42, Table 3.2-3 (Aug-2000)
Ethylbenzene	2.48E-05	lb/MMBtu	1.8E-05	8.1E-05	AP-42, Table 3.2-3 (Aug-2000)
Ethylene Dibromide	2.13E-05	lb/MMBtu	1.6E-05	6.9E-05	AP-42, Table 3.2-3 (Aug-2000)
Methanol	3.06E-03	lb/MMBtu	2.3E-03	9.9E-03	AP-42, Table 3.2-3 (Aug-2000)
Methylene Chloride	4.12E-05	lb/MMBtu	3.1E-05	1.3E-04	AP-42, Table 3.2-3 (Aug-2000)
Naphthalene	9.71E-05	lb/MMBtu	7.2E-05	3.2E-04	AP-42, Table 3.2-3 (Aug-2000)
PAH	1.41E-04	lb/MMBtu	1.0E-04	4.6E-04	AP-42, Table 3.2-3 (Aug-2000)
Styrene	1.19E-05	lb/MMBtu	8.8E-06	3.9E-05	AP-42, Table 3.2-3 (Aug-2000)
Toluene	5.58E-04	lb/MMBtu	4.1E-04	1.8E-03	AP-42, Table 3.2-3 (Aug-2000)
Vinyl Chloride	7.18E-06	lb/MMBtu	5.3E-06	2.3E-05	AP-42, Table 3.2-3 (Aug-2000)
Xylene	1.95E-04	lb/MMBtu	1.4E-04	6.3E-04	AP-42, Table 3.2-3 (Aug-2000)
Total HAP (including HCHO)			0.02	0.11	

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Microturbine Generator

Engine Information:

Source Designation:	MT-1
Manufacturer:	Flex Energy
Model No.:	GT250S
Engine Type:	Microturbine
Rated Horsepower (bhp):	335
Rated Electrical Power Output (kW):	250
Rated Electrical Power Output (MW):	0.3
Number of Units:	1

Engine Fuel Information:

Fuel Type:	Natural Gas
Higher Heating Value (HHV) (Btu/scf):	1,031
Maximum Fuel Consumption at 100% Load (scf/hr):	3,172
Heat Input (MMBtu/hr):	3.27
Potential Fuel Consumption (MMBtu/yr):	28,645
Max. Fuel Consumption at 100% (MMscf/hr):	0.0032
Max. Fuel Consumption (MMscf/yr):	27.8
Max. Annual Hours of Operation (hr/yr):	8,760

Engine Emissions Data:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
NO _x	0.45	lb/MWhe	0.11	0.49	Manufacturer's Specifications
VOC	0.25	lb/MWhe	0.06	0.27	Manufacturer's Specifications
CO	1.12	lb/MWhe	0.28	1.23	Manufacturer's Specifications
SO _x	0.003	lb/MMBtu	1.11E-02	4.87E-02	AP-42, Table 3.1-2a (Apr-2000)
PM ₁₀	0.01	lb/MMBtu	0.02	0.09	AP-42, Table 3.1-2a (Apr-2000)
PM _{2.5}	0.01	lb/MMBtu	0.02	0.09	AP-42, Table 3.1-2a (Apr-2000)
Formaldehyde (HCHO)	0.001	lb/MMBtu	2.32E-03	0.01	AP-42, Table 3.1-3 (Apr-2000)
GHG (CO ₂ e)	See Table Below		383	1,677	40 CFR 98, Tables C-1 & C-2
Other (Total HAP)	See Table Below		3.36E-03	0.01	AP-42, Table 3.1-3 (Apr-2000)

Notes:

1. PM₁₀ and PM_{2.5} are total values (filterable + condensable).
2. GHG (CO₂e) is carbon dioxide equivalent, which is the summation of CO₂ (GWP = 1) + CH₄ (GWP = 25) + N₂O (GWP = 298).
3. Total HAP is the summation of all hazardous air pollutants for which there is a published emission factor for this source type.

Company Name:
 Facility Name:
 Project Description:

M3 Appalachia Gathering, LLC
Hamilton Compressor Station
G35D Application

Microturbine Generator

Greenhouse Gas (GHG) & Hazardous Air Pollutant (HAP) Emissions Calculations:

Pollutant	Emission Factor	Units	Maximum Potential Emissions		Estimation Basis / Emission Factor Source
			lbs/hr	tpy	
GHGs:					
CO ₂	53.06	kg/MMBtu	383	1,676	40 CFR 98, Table C-1
CH ₄	0.001	kg/MMBtu	7.2E-03	3.2E-02	40 CFR 98, Table C-2
N ₂ O	0.0001	kg/MMBtu	7.2E-04	3.2E-03	40 CFR 98, Table C-2
GHG (CO₂e)			383	1,677	
Organic HAPs:					
1,3-Butadiene	4.30E-07	lb/MMBtu	1.4E-06	6.2E-06	AP-42, Table 3.1-3 (Apr-2000)
Acetaldehyde	4.00E-05	lb/MMBtu	1.3E-04	5.7E-04	AP-42, Table 3.1-3 (Apr-2000)
Acrolein	6.40E-06	lb/MMBtu	2.1E-05	9.2E-05	AP-42, Table 3.1-3 (Apr-2000)
Benzene	1.20E-05	lb/MMBtu	3.9E-05	1.7E-04	AP-42, Table 3.1-3 (Apr-2000)
Ethylbenzene	3.20E-05	lb/MMBtu	1.0E-04	4.6E-04	AP-42, Table 3.1-3 (Apr-2000)
Naphthalene	1.30E-06	lb/MMBtu	4.3E-06	1.9E-05	AP-42, Table 3.1-3 (Apr-2000)
PAH	2.20E-06	lb/MMBtu	7.2E-06	3.2E-05	AP-42, Table 3.1-3 (Apr-2000)
Propylene oxide	2.90E-05	lb/MMBtu	9.5E-05	4.2E-04	AP-42, Table 3.1-3 (Apr-2000)
Toluene	1.30E-04	lb/MMBtu	4.3E-04	1.9E-03	AP-42, Table 3.1-3 (Apr-2000)
Xylene	6.40E-05	lb/MMBtu	2.1E-04	9.2E-04	AP-42, Table 3.1-3 (Apr-2000)
Total HAP (including HCHO)			0.00	0.01	

Company Name: M3 Appalachia Gathering, LLC
 Facility Name: Hamilton Compressor Station
 Project Description: G35D Application

Glycol Dehydrators

Source Designation:	TEG-1 to TEG-2
Throughput Rating (MMSCFD):	75
Tower Temperature (deg F):	80
Tower Pressure (psig):	1,250
Glycol Pump Rate (gpm):	15
Flash Tank Temperature (deg F):	80
Flash Tank Pressure (psig):	40
Potential Annual Hours of Operation (hr/yr):	8,760

GRI-GLYCalc Version 4.0 - EMISSIONS SUMMARY ¹			
Uncontrolled Regenerator Emissions			
Pollutant	(lbs/hr)	(lbs/day)	(tons/yr)
Methane	38.4344	922.426	168.3428
Ethane	2.3194	55.665	10.1588
Propane	0.2064	4.954	0.9041
Isobutane	0.0081	0.194	0.0355
n-Butane	0.0337	0.809	0.1477
Isopentane	0.0025	0.061	0.0111
n-Pentane	0.0033	0.079	0.0143
n-Hexane*	0.0000	0.000	0.0000
Heptanes	0.0000	0.000	0.0000
Benzene*	0.0000	0.000	0.0000
Toluene*	0.0000	0.000	0.0000
Ethylbenzene*	0.0000	0.000	0.0000
Xylenes*	0.0000	0.000	0.0000
C8 + Heavier Hydrocarbons	0.0000	0.000	0.0000
Total Emissions	41.0078	984.188	179.6144
Total Hydrocarbon Emissions	41.0078	984.188	179.6144
Total VOC Emissions	0.2540	6.097	1.1127
Total HAP Emissions	0.0000	0.000	0.0000

GRI-GLYCalc Version 4.0 - EMISSIONS SUMMARY ¹			
Flash Gas Emissions			
Pollutant	(lbs/hr)	(lbs/day)	(tons/yr)
Methane	109.0393	2616.943	477.5921
Ethane	6.6720	160.127	29.2232
Propane	0.4921	11.811	2.1555
Isobutane	0.0157	0.376	0.0686
n-Butane	0.0560	1.343	0.2451
Isopentane	0.0035	0.085	0.0155
n-Pentane	0.0039	0.093	0.0170
n-Hexane*	0.0000	0.000	0.0000
Heptanes	0.0000	0.000	0.0000
Benzene*	0.0000	0.000	0.0000
Toluene*	0.0000	0.000	0.0000
Ethylbenzene*	0.0000	0.000	0.0000
Xylenes*	0.0000	0.000	0.0000
C8 + Heavier Hydrocarbons	0.0000	0.000	0.0000
Total Emissions	116.2824	2790.778	509.3170
Total Hydrocarbon Emissions	116.2824	2790.778	509.3170
Total VOC Emissions	0.5712	13.708	2.5017
Total HAP Emissions	0.0000	0.000	0.0000

Total Emission Rate ²			
Regenerator + Flash Tank			
Pollutant	(lbs/hr)	(lbs/day)	(tons/yr)
Methane	176.9684	4247.243	775.1219
Ethane	10.7897	258.950	47.2584
Propane	0.8382	20.118	3.6715
Isobutane	0.0286	0.684	0.1249
n-Butane	0.1076	2.582	0.4714
Isopentane	0.0072	0.175	0.0319
n-Pentane	0.0086	0.206	0.0376
n-Hexane*	0.0000	0.000	0.0000
Heptanes	0.0000	0.000	0.0000
Benzene*	0.0000	0.000	0.0000
Toluene*	0.0000	0.000	0.0000
Ethylbenzene*	0.0000	0.000	0.0000
Xylenes*	0.0000	0.000	0.0000
C8 + Heavier Hydrocarbons	0.0000	0.000	0.0000
Total Emissions	188.7482	4529.959	826.7177
Total Hydrocarbon Emissions	188.7482	4529.959	826.7177
Total VOC Emissions	0.9902	23.766	4.3373
Total HAP Emissions	0.0000	0.000	0.0000

* HAPs

- Based on GRI-GLYCalc 4.0 run at maximum operating conditions. The unit utilizes energy-exchange glycol pumps and sparging (stripping) gas.
- Totals conservatively include a 20% compliance margin to account for minor variations in inlet gas composition that may occur periodically.
- The existing dehydration unit (TEG-1) is permitted with a condenser. However, this control device has negligible impact on emissions, as there is no detectable level of heavy hydrocarbons (ex. benzene, toluene, etc.) in the gas. Therefore, the applicant is requesting the removal of this control device from the issued permit, as it provides minimal environmental benefit at high cost. A GRI-GLYCalc run showing the ineffectiveness of the condenser is included for reference.**

Company Name: M3 Appalachia Gathering, LLC
Facility Name: Hamilton Compressor Station
Project Description: G35D Application

Reboilers

Source Designation:	REB-1 to REB-2
Fuel Used:	Natural Gas
Higher Heating Value (HHV) (Btu/scf):	1,031
Heat Input (MMBtu/hr):	1.50
Fuel Consumption (MMscf/hr):	1.45E-03
Potential Annual Hours of Operation (hr/yr):	8,760

Criteria and Manufacturer Specific Pollutant Emission Rates:

Pollutant	Emission Factor (lb/MMscf) ¹	Potential Emissions	
		(lb/hr) ²	(tons/yr) ³
NO _x	100	0.15	0.64
CO	84	0.12	0.54
VOC	5.5	8.0E-03	0.04
SO ₂	0.6	8.7E-04	3.8E-03
PM Total	7.6	0.01	0.05
PM Condensable	5.7	8.3E-03	0.04
PM ₁₀ (Filterable)	1.9	2.8E-03	0.01
PM _{2.5} (Filterable)	1.9	2.8E-03	0.01
Lead	5.00E-04	7.3E-07	3.2E-06
CO ₂ ⁴	117.0	175.50	768.67
CH ₄ ⁴	2.21E-03	3.3E-03	1.4E-02
N ₂ O ⁴	2.21E-04	3.3E-04	1.4E-03

Company Name: M3 Appalachia Gathering, LLC
 Facility Name: Hamilton Compressor Station
 Project Description: G35D Application

Reboilers

Hazardous Air Pollutant (HAP) Potential Emissions:

Pollutant	Emission Factor (lb/MMscf) ¹	Potential Emissions	
		(lb/hr) ²	(tons/yr) ³
HAPs:			
Methylnaphthalene (2-)	2.4E-05	3.5E-08	1.5E-07
3-Methylchloranthrene	1.8E-06	2.6E-09	1.1E-08
7,12-Dimethylbenz(a)anthracene	1.6E-05	2.3E-08	1.0E-07
Acenaphthene	1.8E-06	2.6E-09	1.1E-08
Acenaphthylene	1.8E-06	2.6E-09	1.1E-08
Anthracene	2.4E-06	3.5E-09	1.5E-08
Benz(a)anthracene	1.8E-06	2.6E-09	1.1E-08
Benzene	2.1E-03	3.1E-06	1.3E-05
Benzo(a)pyrene	1.2E-06	1.7E-09	7.6E-09
Benzo(b)fluoranthene	1.8E-06	2.6E-09	1.1E-08
Benzo(g,h,i)perylene	1.2E-06	1.7E-09	7.6E-09
Benzo(k)fluoranthene	1.8E-06	2.6E-09	1.1E-08
Chrysene	1.8E-06	2.6E-09	1.1E-08
Dibenzo(a,h) anthracene	1.2E-06	1.7E-09	7.6E-09
Dichlorobenzene	1.2E-03	1.7E-06	7.6E-06
Fluoranthene	3.0E-06	4.4E-09	1.9E-08
Fluorene	2.8E-06	4.1E-09	1.8E-08
Formaldehyde	7.5E-02	1.1E-04	4.8E-04
Hexane	1.8E+00	2.6E-03	1.1E-02
Indo(1,2,3-cd)pyrene	1.8E-06	2.6E-09	1.1E-08
Naphthalene	6.1E-04	8.9E-07	3.9E-06
Phenanthrene	1.7E-05	2.5E-08	1.1E-07
Pyrene	5.0E-06	7.3E-09	3.2E-08
Toluene	3.4E-03	4.9E-06	2.2E-05
Arsenic	2.0E-04	2.9E-07	1.3E-06
Beryllium	1.2E-05	1.7E-08	7.6E-08
Cadmium	1.1E-03	1.6E-06	7.0E-06
Chromium	1.4E-03	2.0E-06	8.9E-06
Cobalt	8.4E-05	1.2E-07	5.4E-07
Manganese	3.8E-04	5.5E-07	2.4E-06
Mercury	2.6E-04	3.8E-07	1.7E-06
Nickel	2.1E-03	3.1E-06	1.3E-05
Selenium	2.4E-05	3.5E-08	1.5E-07
Total HAP		2.7E-03	1.2E-02

¹ Emission factors from AP-42 Section 1.4 "Natural Gas Combustion" Tables 1.4-1, 1.4-2, & 1.4-3

² Emission Rate (lb/hr) = Rated Capacity (MMscf/hr) × Emission Factor (lb/MMscf).

³ Annual Emissions (tons/yr)_{potential} = (lb/hr)_{Emissions} × (Maximum Allowable Operating Hours, 8760 hr/yr) × (1 ton/2000 lb).

⁴ GHG Emission factors from Tables C-1 and C-2, 40 CFR 98, Subpart C.

Company Name: M3 Appalachia Gathering, LLC
 Facility Name: Hamilton Compressor Station
 Project Description: G35D Application

Storage Vessels

Operational Hours 8,760 hrs/yr

Storage Tanks - Uncontrolled^{1,2,3}

Source Designation: Contents: Number: Capacity: Throughput: Condensate Throughput:	T01 to T02 Coolant (Ethylene Glycol)		T03 to T08 Methanol		T10 Waste Fluids		T11 Waste Fluids		T12 to T13 Triethylene Glycol		T14 to T19 Engine Oil		T20 to T25 Compressor Oil	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
	2 tank(s)	6 tank(s)	1 tank(s)	1 tank(s)	2 tank(s)	6 tank(s)	6 tank(s)	6 tank(s)	6 tank(s)	6 tank(s)	6 tank(s)	6 tank(s)	6 tank(s)	6 tank(s)
	1,260 gal (each)	335 gal (each)	8,820 gal (each)	16,800 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)	500 gal (each)
	15,120 gal (each)	4,020 gal (each)	105,840 gal (each)	201,600 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)	6,000 gal (each)
	---	---	0.1 bbl/day (each)	0.1 bbl/day (each)	---	---	---	---	---	---	---	---	---	---
Emissions (per tank)	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
VOC	6.8E-06	3.0E-05	0.002	0.010	0.052	0.229	0.052	0.229	6.8E-06	3.0E-05	4.5E-05	2.0E-04	4.5E-05	2.0E-04
HAP	6.8E-06	3.0E-05	0.002	0.010	0.005	0.020	0.005	0.020	6.8E-06	3.0E-05	4.5E-05	2.0E-04	4.5E-05	2.0E-04
Benzene	---	---	---	---	4.6E-04	0.002	4.6E-04	0.002	---	---	---	---	---	---
Toluene	---	---	---	---	2.3E-04	0.001	2.3E-04	0.001	---	---	---	---	---	---
Ethylbenzene	---	---	---	---	<0.001	<0.001	<0.001	<0.001	---	---	---	---	---	---
Xylene	---	---	---	---	<0.001	<0.001	<0.001	<0.001	---	---	---	---	---	---
n-Hexane	---	---	---	---	0.003	0.013	0.003	0.013	---	---	---	---	---	---
Methane	---	---	---	---	0.001	0.006	0.001	0.006	---	---	---	---	---	---

¹ Uncontrolled emissions calculation using E&P TANK v2.0 for tanks with flashing; emissions include working, breathing and flashing losses. Conservatively assumes 1% condensate in waste fluids.

² Uncontrolled emissions calculation using EPA Tanks 4.0.9d for tanks without flashing; emissions include working and breathing losses.

³ Conservatively assumes one turnover per month, per tank.

Company Name: M3 Appalachia Gathering, LLC
 Facility Name: Hamilton Compressor Station
 Project Description: G35D Application

Liquid Loading

Throughput 307,440 gal/yr
 Capture Efficiency 0% non-tested tanker trucks
 Control Efficiency 0% Combustor destruction efficiency

Liquid Loading Emissions

Source ID:	L01
------------	-----

Uncontrolled Loading Losses: L_u (lb/10³ gal) = 12.46 (SPM)/T
 Controlled Loading Losses: L_c (lb/10³ gal) = 12.46 (SPM)/T * (1 - Capture Efficiency * Control Efficiency)

Parameter	Value	Description
S	0.60	Saturation factor for "Submerged Loading: dedicated normal service" (AP-42 Table 5.2-1)
Capture Efficiency	0%	Capture Efficiency
Control Efficiency	0%	Control Efficiency
P	0.3240	true vapor pressure of liquid loaded (psia) - from EPA TANKS run
M	19.3610	molecular weight of vapors (lb/lb-mol) - from EPA TANKS run
T	511.81	bulk liquid temperature of liquids loaded (deg R) - from EPA TANKS run

Description	Uncontrolled Loading Losses (lb/10 ³ gal)	Maximum Throughput ¹ (gal/yr)	VOC Emissions		HAP Emissions	
			(tpy)	(lb/hr) ²	(tpy)	(lb/hr) ²
Truck Loading of Produced Fluids	0.09	307,440	0.01	0.05	0.00	0.01

¹ Total estimated maximum annual throughput for the waste fluid tanks.
¹ Lb/hr values assume two (2) hours of loading per day, five (5) days per week.

Company Name: M3 Appalachia Gathering, LLC
 Facility Name: Hamilton Compressor Station
 Project Description: G35D Application

Fugitive Emissions

Fugitive Emissions from Component Leaks

Facility Equipment Type ¹	Valves	Connectors	Open-Ended Lines	Pressure Relief Devices
Wellhead	8	38	0.5	0
Separators	1	6	0	0
Meters/Piping	12	45	0	0
Compressors	12	57	0	0
In-line heaters	14	65	2	1
Dehydrators	24	90	2	2

¹ Table W-1B to Subpart W of Part 98 —Default Average Component Counts for Major Onshore Natural Gas Production

Fugitive VOC/Total Emissions from Component Leaks

Equipment Type	Service	Emission Factors ¹ (kg/hr/source)	Facility Equipment Count ² (units)	TOC Annual Fugitive Emissions (tpy)	Weight Fraction VOC	Weight Fraction HAP	VOC Emissions ³ (tpy)	HAP Emissions ³ (tpy)
Pumps	Light Liquid	0.01990	3	0.58	1.00	0.0E+00	0.58	0.0E+00
Compressor	Gas	0.22800	6	13	0.00	0.0E+00	0.05	0.0E+00
Valves	Gas	0.00597	204	11.76	0.00	0.0E+00	0.04	0.0E+00
Pressure Relief Valves	Gas	0.10400	10	10.04	0.00	0.0E+00	0.04	0.0E+00
Open-Ended Lines	All	0.00170	6	0.10	0.00	0.0E+00	3.7E-04	0.0E+00
Connectors	All	0.00183	887	15.67	0.00	0.0E+00	0.06	0.0E+00
Intermittent Pneumatic Devices ⁴	Gas	13.5	40	---	---	---	0.39	0.0E+00
Emission Totals:				51.35	---	---	1.16	0.0E+00

¹ U.S. EPA. Office of Air Quality Planning and Standards. *Protocol for Equipment Leak Emission Estimates*. Table 2-1. (Research Triangle Park, NC: U.S. EPA EPA-453/R-95-017, 1995). SOCMI factors were used as it was representative of natural gas extraction. The pneumatic controller value is from 40 CFR 98 Subpart W, Table W-1A (units of scf/hr-component).

² Assumes one pump for each tank and one meter. Pressure relief valves count includes two for each storage tank. Pneumatic controllers operate on air (no gas emissions). A 50% compliance margin is added to the component counts based on Subpart W count

³ Potential emissions VOC/HAP (tpy) = Emission factor (kg/hr/source) * Number of Sources * Weight % VOC/HAP x 2.2046 (lb/kg) x 8,760 (hr/yr) ÷ 2,000 (lb/ton)

⁴ Potential emissions VOC/HAP (tpy) = Gas volume vented (scf/yr) * Molar weight of natural gas (lb/lb-mol) * Weight % VOC/HAP ÷ 100 ÷ 379 (scf/lb-mol) ÷ 2,000 (lb/ton)

Company Name: M3 Appalachia Gathering, LLC
 Facility Name: Hamilton Compressor Station
 Project Description: G35D Application

Fugitive Emissions

Fugitive Emissions from Venting

Source	Volume (scf/yr)	VOC Emissions (tpy)	Benzene Emissions (tpy)	Toluene Emissions (tpy)	Ethylbenzene Emissions (tpy)	Xylene Emissions (tpy)	n-Hexane Emissions (tpy)	HAP Emissions (tpy)	CH ₄ Emissions (tpy)	CO ₂ Emissions (tpy)	CO ₂ e Emissions (tpy)
Miscellaneous Gas Venting	5,000,000	0.41	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	102.34	0.76	2559.30
Total		0.41	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	102.34	0.76	2,559.30

¹ VOC and HAP emissions are based on sum of the fractions of the pollutants in the site-specific gas analysis in those classifications, and are calculated in accordance with standard conversion methodology and factors.

² CH₄ and CO₂ emissions are based on fractions of these pollutants in the site-specific gas analysis, and are calculated in accordance with Equations W-35 and W-36 in Subpart W of 40 CFR 98.

³ GHG (CO₂e) is carbon dioxide equivalent, which is the summation of CO₂ (GWP = 1) + CH₄ (GWP = 25) + N₂O (GWP = 298).

⁴ Total gas volume emitted (and thus subsequent emissions values) is estimated based on engineering judgement and is conservative.

⁵ Total gas volume emitted includes blowdowns and other venting activities, such as pigging.

⁶ Potential emissions VOC/HAP (tpy) = Gas volume vented (scf/yr) * Molar weight of natural gas (lb/lb-mol) * Weight % VOC/HAP ÷ 100 ÷ 379 (scf/lb-mol) ÷ 2,000 (lb/ton)

⁷ Potential emissions CH₄/CO₂ (tpy) = Gas volume vented (scf/yr) * Mole % CH₄/CO₂ ÷ 100 * Density CH₄/CO₂ (kg/scf) * 1,000 (g/kg) ÷ 453.6 (g/lb) ÷ 2,000 (lb/ton)

Company Name: M3 Appalachia Gathering, LLC
Facility Name: Hamilton Compressor Station
Project Description: G35D Application

Haul Roads

Estimated Potential Road Fugitive Emissions

Unpaved Road Emissions

Unpaved Roads: $E \text{ (lb/VMT)} = k(s/12)^a(W/3)^b * [(365-p)/365]$

	PM	PM₁₀	PM_{2.5}	
k Factor (lb/VMT)	4.9	1.5	0.15	AP-42 Table 13.2.2-2 (Final, 11/06)
Silt content, s	4.8	%		AP-42 Table 13.2.2-1 (11/06), for Sand and Gravel Processing
Number of Rain Days, p	150			AP-42 Figure 13.2.1-2
a	0.7	0.9	0.9	AP-42 Table 13.2.2-2 (Final, 11/06)
b	0.45	0.45	0.45	AP-42 Table 13.2.2-2 (Final, 11/06)

Description	Weight of Empty Truck (tons)	Weight of Truck w/ Max Load (tons)	Mean Vehicle Weight (tons)	Length of Unpaved Road Traveled (mile)	Trips Per Year	Mileage Per Year	Control (%)	Emissions (tpy)		
								PM	PM ₁₀	PM _{2.5}
Liquids Hauling	20	40	30	1.16	77	178	0	0.38	0.10	0.01
Employee Vehicles	3	3	3	1.16	200	462	0	0.35	0.09	0.01
Total Potential Emissions								0.73	0.19	0.02

Company Name: M3 Appalachia Gathering, LLC
 Facility Name: Hamilton Compressor Station
 Project Description: G35D Application

Gas Analysis

Sample Location: Hamilton Compressor Station
 HHV (Btu/scf): 1,031

Constituent	Natural Gas Stream Speciation (Mole %)	Molecular Weight	Molar Weight	Average Weight Fraction	Natural Gas Stream Speciation (Wt. %)
Carbon Dioxide	0.2633	44.01	0.12	0.01	0.700
Nitrogen	0.2418	28.01	0.07	0.00	0.409
Methane	96.7125	16.04	15.51	0.94	93.709
Ethane	2.6452	30.07	0.80	0.05	4.805
Propane	0.1242	44.10	0.05	0.00	0.331
Isobutane	0.0028	58.12	0.00	0.00	0.010
n-Butane	0.0092	58.12	0.01	0.00	0.032
Isopentane	0.0005	72.15	0.00	0.00	0.002
n-Pentane	0.0005	72.15	0.00	0.00	0.002
Cyclopentane	<0.001	70.1	0.0	0.0	0.000
n-Hexane	<0.001	86.18	0.00	0.00	0.000
Cyclohexane	<0.001	84.16	0.00	0.00	0.000
Other Hexanes	<0.001	86.18	0.00	0.00	0.000
Heptanes	<0.001	100.21	0.00	0.00	0.000
Methylcyclohexane	<0.001	98.19	0.00	0.00	0.000
2,2,4-Trimethylpentane	<0.001	114.23	0.00	0.00	0.000
Benzene*	<0.001	78.11	0.00	0.00	0.000
Toluene*	<0.001	92.14	0.00	0.00	0.000
Ethylbenzene*	<0.001	106.17	0.00	0.00	0.000
Xylenes*	<0.001	106.16	0.00	0.00	0.000
C8 + Heavies	<0.001	130.80	0.00	0.00	0.000
Totals	100.000		16.55	1.00	100

TOC (Total)	99.49	98.89
VOC (Total)	0.14	0.38
HAP (Total)	0.00	0.00

Case Name: Hamilton Compressor Station: TEG-1 & TEG-2

File Name: Z:\Client\DTE\West Virginia\Hamilton\Projects\173901.0082 Hamilton Permit Mod\04 Draft\2017-0306 Draft G35D Application\Attach R - Emission Calcs\02 GRI-GLYCalc\2017-0308 M3 Hamilton_G35D_DehyEmissions.ddf

Date: March 08, 2017

DESCRIPTION:

Description: Potential-to-emit calculations.

Annual Hours of Operation: 8760.0 hours/yr

WET GAS:

Temperature: 80.00 deg. F
Pressure: 1250.00 psig
Wet Gas Water Content: Saturated

Component	Conc. (vol %)
Carbon Dioxide	0.2633
Nitrogen	0.2418
Methane	96.7125
Ethane	2.6452
Propane	0.1242
Isobutane	0.0028
n-Butane	0.0092
Isopentane	0.0005
n-Pentane	0.0005

DRY GAS:

Flow Rate: 75.0 MMSCF/day
Water Content: 7.0 lbs. H2O/MMSCF

LEAN GLYCOL:

Glycol Type: TEG
Water Content: 1.5 wt% H2O
Flow Rate: 15.0 gpm

PUMP:

Glycol Pump Type: Gas Injection
Gas Injection Pump Volume Ratio: 0.080 acfm gas/gpm glycol

FLASH TANK:

Flash Control: Combustion device
Flash Control Efficiency: 65.00 %
Temperature: 80.0 deg. F
Pressure: 40.0 psig

STRIPPING GAS:

Source of Gas: Dry Gas
Gas Flow Rate: 15.000 scfm

Potential-to-Emit
GLYCalc Run
(Aggregate Report)

Case Name: Hamilton Compressor Station: TEG-1 & TEG-2

File Name: Z:\Client\DTE\West Virginia\Hamilton\Projects\173901.0082 Hamilton Permit Mod\04 Draft\2017-0306 Draft G35D Application\Attach R - Emission Calcs\02 GRI-GLYCalc\2017-0308 M3 Hamilton_G35D_DehyEmissions.ddf

Date: March 08, 2017

DESCRIPTION:

Description: Potential-to-emit calculations.

Annual Hours of Operation: 8760.0 hours/yr

EMISSIONS REPORTS:

UNCONTROLLED REGENERATOR EMISSIONS

Component	lbs/hr	lbs/day	tons/yr
Methane	38.4344	922.426	168.3428
Ethane	2.3194	55.665	10.1588
Propane	0.2064	4.954	0.9041
Isobutane	0.0081	0.194	0.0355
n-Butane	0.0337	0.809	0.1477
Isopentane	0.0025	0.061	0.0111
n-Pentane	0.0033	0.079	0.0143
Total Emissions	41.0078	984.188	179.6144
Total Hydrocarbon Emissions	41.0078	984.188	179.6144
Total VOC Emissions	0.2540	6.097	1.1127

FLASH GAS EMISSIONS

Component	lbs/hr	lbs/day	tons/yr
Methane	109.0393	2616.943	477.5921
Ethane	6.6720	160.127	29.2232
Propane	0.4921	11.811	2.1555
Isobutane	0.0157	0.376	0.0686
n-Butane	0.0560	1.343	0.2451
Isopentane	0.0035	0.085	0.0155
n-Pentane	0.0039	0.093	0.0170
Total Emissions	116.2824	2790.778	509.3170
Total Hydrocarbon Emissions	116.2824	2790.778	509.3170
Total VOC Emissions	0.5712	13.708	2.5017

FLASH TANK OFF GAS

Component	lbs/hr	lbs/day	tons/yr
Methane	311.5409	7476.981	1364.5490
Ethane	19.0627	457.505	83.4947
Propane	1.4061	33.746	6.1586
Isobutane	0.0448	1.075	0.1961
n-Butane	0.1599	3.837	0.7002

Isopentane	0.0101	0.242	0.0443
n-Pentane	0.0111	0.266	0.0485

Total Emissions	332.2355	7973.651	1455.1914
Total Hydrocarbon Emissions	332.2355	7973.651	1455.1914
Total VOC Emissions	1.6319	39.165	7.1477

EQUIPMENT REPORTS:

ABSORBER

NOTE: Because the Calculated Absorber Stages was below the minimum allowed, GRI-GLYCalc has set the number of Absorber Stages to 1.25 and has calculated a revised Dry Gas Dew Point.

Calculated Absorber Stages: 1.25
 Calculated Dry Gas Dew Point: 1.07 lbs. H2O/MMSCF

Temperature: 80.0 deg. F
 Pressure: 1250.0 psig
 Dry Gas Flow Rate: 75.0000 MMSCF/day
 Glycol Losses with Dry Gas: 0.7820 lb/hr
 Wet Gas Water Content: Saturated
 Calculated Wet Gas Water Content: 27.57 lbs. H2O/MMSCF
 Calculated Lean Glycol Recirc. Ratio: 10.87 gal/lb H2O

Component	Remaining in Dry Gas	Absorbed in Glycol

Water	3.89%	96.11%
Carbon Dioxide	99.62%	0.38%
Nitrogen	99.97%	0.03%
Methane	99.97%	0.03%
Ethane	99.92%	0.08%
Propane	99.89%	0.11%
Isobutane	99.85%	0.15%
n-Butane	99.81%	0.19%
Isopentane	99.82%	0.18%
n-Pentane	99.77%	0.23%

FLASH TANK

Flash Control: Combustion device
 Flash Control Efficiency: 65.00 %
 Flash Temperature: 80.0 deg. F
 Flash Pressure: 40.0 psig

Component	Left in Glycol	Removed in Flash Gas

Water	99.91%	0.09%
Carbon Dioxide	8.42%	91.58%
Nitrogen	0.51%	99.49%
Methane	0.52%	99.48%
Ethane	2.22%	97.78%

Propane	5.17%	94.83%
Isobutane	8.66%	91.34%
n-Butane	11.64%	88.36%
Isopentane	14.40%	85.60%
n-Pentane	18.17%	81.83%

REGENERATOR

 Dry Product Gas Regenerator Stripping Gas:
 Stripping Gas Flow Rate: 15.0000 scfm

Component	Remaining in Glycol	Distilled Overhead
Water	60.45%	39.55%
Carbon Dioxide	0.00%	100.00%
Nitrogen	0.00%	100.00%
Methane	0.00%	100.00%
Ethane	0.00%	100.00%
Propane	0.00%	100.00%
Isobutane	0.00%	100.00%
n-Butane	0.00%	100.00%
Isopentane	1.56%	98.44%
n-Pentane	1.43%	98.57%

STREAM REPORTS:

WET GAS STREAM

 Temperature: 80.00 deg. F
 Pressure: 1264.70 psia
 Flow Rate: 3.13e+006 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	5.81e-002	8.62e+001
Carbon Dioxide	2.63e-001	9.55e+002
Nitrogen	2.42e-001	5.58e+002
Methane	9.67e+001	1.28e+005
Ethane	2.64e+000	6.55e+003
Propane	1.24e-001	4.51e+002
Isobutane	2.80e-003	1.34e+001
n-Butane	9.19e-003	4.40e+001
Isopentane	5.00e-004	2.97e+000
n-Pentane	5.00e-004	2.97e+000
Total Components	100.00	1.36e+005

DRY GAS STREAM

 Temperature: 80.00 deg. F
 Pressure: 1264.70 psia
 Flow Rate: 3.13e+006 scfh

Component	Conc.	Loading
-----------	-------	---------

	(vol%)	(lb/hr)
Water	2.26e-003	3.36e+000
Carbon Dioxide	2.62e-001	9.51e+002
Nitrogen	2.42e-001	5.58e+002
Methane	9.67e+001	1.28e+005
Ethane	2.64e+000	6.55e+003
Propane	1.24e-001	4.51e+002
Isobutane	2.80e-003	1.34e+001
n-Butane	9.18e-003	4.40e+001
Isopentane	4.99e-004	2.97e+000
n-Pentane	4.99e-004	2.96e+000
Total Components	100.00	1.36e+005

LEAN GLYCOL STREAM

Temperature: 80.00 deg. F
Flow Rate: 1.50e+001 gpm

Component	Conc. (wt%)	Loading (lb/hr)
TEG	9.85e+001	8.32e+003
Water	1.50e+000	1.27e+002
Carbon Dioxide	4.29e-012	3.63e-010
Nitrogen	2.03e-013	1.72e-011
Methane	1.31e-017	1.10e-015
Ethane	2.86e-008	2.42e-006
Propane	2.38e-010	2.01e-008
Isobutane	6.97e-012	5.89e-010
n-Butane	2.48e-011	2.09e-009
Isopentane	3.13e-007	2.65e-005
n-Pentane	4.15e-007	3.51e-005
Total Components	100.00	8.45e+003

RICH GLYCOL AND PUMP GAS STREAM

Temperature: 80.00 deg. F
Pressure: 1264.70 psia
Flow Rate: 1.59e+001 gpm
NOTE: Stream has more than one phase.

Component	Conc. (wt%)	Loading (lb/hr)
TEG	9.38e+001	8.32e+003
Water	2.36e+000	2.10e+002
Carbon Dioxide	6.45e-002	5.72e+000
Nitrogen	1.57e-002	1.40e+000
Methane	3.53e+000	3.13e+002
Ethane	2.20e-001	1.95e+001
Propane	1.67e-002	1.48e+000
Isobutane	5.53e-004	4.90e-002
n-Butane	2.04e-003	1.81e-001
Isopentane	1.33e-004	1.18e-002
n-Pentane	1.52e-004	1.35e-002
Total Components	100.00	8.87e+003

FLASH TANK OFF GAS STREAM

 Temperature: 80.00 deg. F
 Pressure: 54.70 psia
 Flow Rate: 7.69e+003 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	4.90e-002	1.79e-001
Carbon Dioxide	5.87e-001	5.24e+000
Nitrogen	2.45e-001	1.39e+000
Methane	9.58e+001	3.12e+002
Ethane	3.13e+000	1.91e+001
Propane	1.57e-001	1.41e+000
Isobutane	3.80e-003	4.48e-002
n-Butane	1.36e-002	1.60e-001
Isopentane	6.91e-004	1.01e-002
n-Pentane	7.57e-004	1.11e-002
Total Components	100.00	3.39e+002

FLASH TANK GLYCOL STREAM

 Temperature: 80.00 deg. F
 Flow Rate: 1.52e+001 gpm

Component	Conc. (wt%)	Loading (lb/hr)
TEG	9.75e+001	8.32e+003
Water	2.46e+000	2.10e+002
Carbon Dioxide	5.65e-003	4.82e-001
Nitrogen	8.33e-005	7.10e-003
Methane	1.92e-002	1.64e+000
Ethane	5.08e-003	4.34e-001
Propane	8.98e-004	7.66e-002
Isobutane	4.98e-005	4.25e-003
n-Butane	2.47e-004	2.11e-002
Isopentane	1.99e-005	1.70e-003
n-Pentane	2.88e-005	2.46e-003
Total Components	100.00	8.53e+003

FLASH GAS EMISSIONS

 Flow Rate: 1.80e+004 scfh
 Control Method: Combustion Device
 Control Efficiency: 65.00

Component	Conc. (vol%)	Loading (lb/hr)
Water	5.62e+001	4.79e+002
Carbon Dioxide	2.88e+001	6.00e+002
Nitrogen	1.05e-001	1.39e+000
Methane	1.44e+001	1.09e+002
Ethane	4.69e-001	6.67e+000
Propane	2.36e-002	4.92e-001
Isobutane	5.70e-004	1.57e-002

n-Butane	2.03e-003	5.60e-002
Isopentane	1.04e-004	3.54e-003
n-Pentane	1.13e-004	3.87e-003

Total Components	100.00	1.20e+003
------------------	--------	-----------

 REGENERATOR OVERHEADS STREAM

Temperature: 212.00 deg. F
 Pressure: 14.70 psia
 Flow Rate: 2.70e+003 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	6.48e+001	8.29e+001
Carbon Dioxide	2.42e-001	7.56e-001
Nitrogen	8.43e-002	1.68e-001
Methane	3.37e+001	3.84e+001
Ethane	1.09e+000	2.32e+000
Propane	6.59e-002	2.06e-001
Isobutane	1.96e-003	8.10e-003
n-Butane	8.17e-003	3.37e-002
Isopentane	4.93e-004	2.53e-003
n-Pentane	6.39e-004	3.28e-003
Total Components	100.00	1.25e+002

Potential-to-Emit
GLYCalc Run:
WITH CONDENSER
(FOR REFERENCE)

Case Name: Hamilton Compressor Station: TEG-1 & TEG-2
 File Name: Z:\Client\DTE\West Virginia\Hamilton\Projects\173901.0082 H
 Mod\04 Draft\2017-0306 Draft G35D Application\Attach R - Emission Calc\02
 GRI-GLYCalc\2017-0308 M3 Hamilton_G35D_DehyEmissions.ddf
 Date: March 08, 2017

DESCRIPTION:

Description: Potential-to-emit calculations.

Annual Hours of Operation: 8760.0 hours/yr

EMISSIONS REPORTS:

CONTROLLED REGENERATOR EMISSIONS

Component	lbs/hr	lbs/day	tons/yr
Methane	38.4333	922.398	168.3377
Ethane	2.3193	55.663	10.1585
Propane	0.2064	4.954	0.9040
Isobutane	0.0081	0.194	0.0355
n-Butane	0.0337	0.809	0.1477
Isopentane	0.0025	0.061	0.0111
n-Pentane	0.0033	0.079	0.0143
Total Emissions	41.0066	984.158	179.6089
Total Hydrocarbon Emissions	41.0066	984.158	179.6089
Total VOC Emissions	0.2540	6.097	1.1126

UNCONTROLLED REGENERATOR EMISSIONS

Component	lbs/hr	lbs/day	tons/yr
Methane	38.4344	922.426	168.3428
Ethane	2.3194	55.665	10.1588
Propane	0.2064	4.954	0.9041
Isobutane	0.0081	0.194	0.0355
n-Butane	0.0337	0.809	0.1477
Isopentane	0.0025	0.061	0.0111
n-Pentane	0.0033	0.079	0.0143
Total Emissions	41.0078	984.188	179.6144
Total Hydrocarbon Emissions	41.0078	984.188	179.6144
Total VOC Emissions	0.2540	6.097	1.1127

FLASH GAS EMISSIONS

Component	lbs/hr	lbs/day	tons/yr
Methane	109.0393	2616.943	477.5921
Ethane	6.6720	160.127	29.2232
Propane	0.4921	11.811	2.1555
Isobutane	0.0157	0.376	0.0686
n-Butane	0.0560	1.343	0.2451

Isopentane	0.0035	0.085	0.0155
n-Pentane	0.0039	0.093	0.0170

Total Emissions	116.2824	2790.778	509.3170
Total Hydrocarbon Emissions	116.2824	2790.778	509.3170
Total VOC Emissions	0.5712	13.708	2.5017

FLASH TANK OFF GAS

Component	lbs/hr	lbs/day	tons/yr

Methane	311.5409	7476.981	1364.5490
Ethane	19.0627	457.505	83.4947
Propane	1.4061	33.746	6.1586
Isobutane	0.0448	1.075	0.1961
n-Butane	0.1599	3.837	0.7002
Isopentane	0.0101	0.242	0.0443
n-Pentane	0.0111	0.266	0.0485

Total Emissions	332.2355	7973.651	1455.1914
Total Hydrocarbon Emissions	332.2355	7973.651	1455.1914
Total VOC Emissions	1.6319	39.165	7.1477

EQUIPMENT REPORTS:

CONDENSER

Condenser Outlet Temperature: 110.00 deg. F
Condenser Pressure: 14.70 psia
Condenser Duty: 5.57e-002 MM BTU/hr
Produced Water: 5.38 bbls/day
VOC Control Efficiency: 0.00 %
HAP Control Efficiency: 0.00 %
BTEX Control Efficiency: 0.00 %
Dissolved Hydrocarbons in Water: 15.99 mg/L

Component	Emitted	Condensed

Water	5.23%	94.77%
Carbon Dioxide	99.94%	0.06%
Nitrogen	100.00%	0.00%
Methane	100.00%	0.00%
Ethane	100.00%	0.00%
Propane	100.00%	0.00%
Isobutane	100.00%	0.00%
n-Butane	100.00%	0.00%
Isopentane	100.00%	0.00%
n-Pentane	100.00%	0.00%

ABSORBER

NOTE: Because the Calculated Absorber Stages was below the minimum allowed, GRI-GLYCalc has set the number of Absorber Stages to 1.25

and has calculated a revised Dry Gas Dew Point.

Calculated Absorber Stages: 1.25
 Calculated Dry Gas Dew Point: 1.07 lbs. H2O/MMSCF
 Temperature: 80.0 deg. F
 Pressure: 1250.0 psig
 Dry Gas Flow Rate: 75.0000 MMSCF/day
 Glycol Losses with Dry Gas: 0.7820 lb/hr
 Wet Gas Water Content: Saturated
 Calculated Wet Gas Water Content: 27.57 lbs. H2O/MMSCF
 Calculated Lean Glycol Recirc. Ratio: 10.87 gal/lb H2O

Component	Remaining in Dry Gas	Absorbed in Glycol
Water	3.89%	96.11%
Carbon Dioxide	99.62%	0.38%
Nitrogen	99.97%	0.03%
Methane	99.97%	0.03%
Ethane	99.92%	0.08%
Propane	99.89%	0.11%
Isobutane	99.85%	0.15%
n-Butane	99.81%	0.19%
Isopentane	99.82%	0.18%
n-Pentane	99.77%	0.23%

FLASH TANK

Flash Control: Combustion device
 Flash Control Efficiency: 65.00 %
 Flash Temperature: 80.0 deg. F
 Flash Pressure: 40.0 psig

Component	Left in Glycol	Removed in Flash Gas
Water	99.91%	0.09%
Carbon Dioxide	8.42%	91.58%
Nitrogen	0.51%	99.49%
Methane	0.52%	99.48%
Ethane	2.22%	97.78%
Propane	5.17%	94.83%
Isobutane	8.66%	91.34%
n-Butane	11.64%	88.36%
Isopentane	14.40%	85.60%
n-Pentane	18.17%	81.83%

REGENERATOR

Regenerator Stripping Gas:
 Dry Product Gas Stripping Gas Flow Rate: 15.0000 scfm

Component	Remaining in Glycol	Distilled Overhead
Water	60.45%	39.55%
Carbon Dioxide	0.00%	100.00%
Nitrogen	0.00%	100.00%
Methane	0.00%	100.00%
Ethane	0.00%	100.00%

Propane	0.00%	100.00%
Isobutane	0.00%	100.00%
n-Butane	0.00%	100.00%
Isopentane	1.56%	98.44%
n-Pentane	1.43%	98.57%

STREAM REPORTS:

WET GAS STREAM

Temperature: 80.00 deg. F
 Pressure: 1264.70 psia
 Flow Rate: 3.13e+006 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	5.81e-002	8.62e+001
Carbon Dioxide	2.63e-001	9.55e+002
Nitrogen	2.42e-001	5.58e+002
Methane	9.67e+001	1.28e+005
Ethane	2.64e+000	6.55e+003
Propane	1.24e-001	4.51e+002
Isobutane	2.80e-003	1.34e+001
n-Butane	9.19e-003	4.40e+001
Isopentane	5.00e-004	2.97e+000
n-Pentane	5.00e-004	2.97e+000
Total Components	100.00	1.36e+005

DRY GAS STREAM

Temperature: 80.00 deg. F
 Pressure: 1264.70 psia
 Flow Rate: 3.13e+006 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	2.26e-003	3.36e+000
Carbon Dioxide	2.62e-001	9.51e+002
Nitrogen	2.42e-001	5.58e+002
Methane	9.67e+001	1.28e+005
Ethane	2.64e+000	6.55e+003
Propane	1.24e-001	4.51e+002
Isobutane	2.80e-003	1.34e+001
n-Butane	9.18e-003	4.40e+001
Isopentane	4.99e-004	2.97e+000
n-Pentane	4.99e-004	2.96e+000
Total Components	100.00	1.36e+005

LEAN GLYCOL STREAM

Temperature: 80.00 deg. F
 Flow Rate: 1.50e+001 gpm

Component	Conc. (wt%)	Loading (lb/hr)
TEG	9.85e+001	8.32e+003
Water	1.50e+000	1.27e+002
Carbon Dioxide	4.29e-012	3.63e-010
Nitrogen	2.03e-013	1.72e-011
Methane	1.31e-017	1.10e-015
Ethane	2.86e-008	2.42e-006
Propane	2.38e-010	2.01e-008
Isobutane	6.97e-012	5.89e-010
n-Butane	2.48e-011	2.09e-009
Isopentane	3.13e-007	2.65e-005
n-Pentane	4.15e-007	3.51e-005
Total Components	100.00	8.45e+003

RICH GLYCOL AND PUMP GAS STREAM

Temperature: 80.00 deg. F
 Pressure: 1264.70 psia
 Flow Rate: 1.59e+001 gpm
 NOTE: Stream has more than one phase.

Component	Conc. (wt%)	Loading (lb/hr)
TEG	9.38e+001	8.32e+003
Water	2.36e+000	2.10e+002
Carbon Dioxide	6.45e-002	5.72e+000
Nitrogen	1.57e-002	1.40e+000
Methane	3.53e+000	3.13e+002
Ethane	2.20e-001	1.95e+001
Propane	1.67e-002	1.48e+000
Isobutane	5.53e-004	4.90e-002
n-Butane	2.04e-003	1.81e-001
Isopentane	1.33e-004	1.18e-002
n-Pentane	1.52e-004	1.35e-002
Total Components	100.00	8.87e+003

FLASH TANK OFF GAS STREAM

Temperature: 80.00 deg. F
 Pressure: 54.70 psia
 Flow Rate: 7.69e+003 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	4.90e-002	1.79e-001
Carbon Dioxide	5.87e-001	5.24e+000
Nitrogen	2.45e-001	1.39e+000
Methane	9.58e+001	3.12e+002
Ethane	3.13e+000	1.91e+001
Propane	1.57e-001	1.41e+000
Isobutane	3.80e-003	4.48e-002
n-Butane	1.36e-002	1.60e-001
Isopentane	6.91e-004	1.01e-002
n-Pentane	7.57e-004	1.11e-002

Total Components 100.00 3.39e+002

FLASH TANK GLYCOL STREAM

Temperature: 80.00 deg. F
 Flow Rate: 1.52e+001 gpm

Component	Conc. (wt%)	Loading (lb/hr)
TEG	9.75e+001	8.32e+003
Water	2.46e+000	2.10e+002
Carbon Dioxide	5.65e-003	4.82e-001
Nitrogen	8.33e-005	7.10e-003
Methane	1.92e-002	1.64e+000
Ethane	5.08e-003	4.34e-001
Propane	8.98e-004	7.66e-002
Isobutane	4.98e-005	4.25e-003
n-Butane	2.47e-004	2.11e-002
Isopentane	1.99e-005	1.70e-003
n-Pentane	2.88e-005	2.46e-003
Total Components	100.00	8.53e+003

FLASH GAS EMISSIONS

Flow Rate: 1.80e+004 scfh
 Control Method: Combustion Device
 Control Efficiency: 65.00

Component	Conc. (vol%)	Loading (lb/hr)
Water	5.62e+001	4.79e+002
Carbon Dioxide	2.88e+001	6.00e+002
Nitrogen	1.05e-001	1.39e+000
Methane	1.44e+001	1.09e+002
Ethane	4.69e-001	6.67e+000
Propane	2.36e-002	4.92e-001
Isobutane	5.70e-004	1.57e-002
n-Butane	2.03e-003	5.60e-002
Isopentane	1.04e-004	3.54e-003
n-Pentane	1.13e-004	3.87e-003
Total Components	100.00	1.20e+003

REGENERATOR OVERHEADS STREAM

Temperature: 212.00 deg. F
 Pressure: 14.70 psia
 Flow Rate: 2.70e+003 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	6.48e+001	8.29e+001
Carbon Dioxide	2.42e-001	7.56e-001
Nitrogen	8.43e-002	1.68e-001
Methane	3.37e+001	3.84e+001
Ethane	1.09e+000	2.32e+000

Propane	6.59e-002	2.06e-001
Isobutane	1.96e-003	8.10e-003
n-Butane	8.17e-003	3.37e-002
Isopentane	4.93e-004	2.53e-003
n-Pentane	6.39e-004	3.28e-003

Total Components	100.00	1.25e+002
------------------	--------	-----------

CONDENSER VENT GAS STREAM

Temperature: 110.00 deg. F
 Pressure: 14.70 psia
 Flow Rate: 1.04e+003 scfh

Component	Conc. (vol%)	Loading (lb/hr)
Water	8.77e+000	4.33e+000
Carbon Dioxide	6.26e-001	7.55e-001
Nitrogen	2.18e-001	1.68e-001
Methane	8.74e+001	3.84e+001
Ethane	2.81e+000	2.32e+000
Propane	1.71e-001	2.06e-001
Isobutane	5.08e-003	8.10e-003
n-Butane	2.12e-002	3.37e-002
Isopentane	1.28e-003	2.53e-003
n-Pentane	1.66e-003	3.28e-003
Total Components	100.00	4.63e+001

CONDENSER PRODUCED WATER STREAM

Temperature: 110.00 deg. F
 Flow Rate: 1.57e-001 gpm

Component	Conc. (wt%)	Loading (lb/hr)	(ppm)
Water	1.00e+002	7.85e+001	999978.
Carbon Dioxide	6.07e-004	4.77e-004	6.
Nitrogen	3.27e-006	2.57e-006	0.
Methane	1.48e-003	1.17e-003	15.
Ethane	1.05e-004	8.24e-005	1.
Propane	8.89e-006	6.98e-006	0.
Isobutane	1.93e-007	1.51e-007	0.
n-Butane	1.08e-006	8.45e-007	0.
Isopentane	5.78e-008	4.54e-008	0.
n-Pentane	8.12e-008	6.38e-008	0.
Total Components	100.00	7.85e+001	1000000.

CONDENSER RECOVERED OIL STREAM

Temperature: 110.00 deg. F

The calculated flow rate is less than 0.000001 #mol/hr.
 The stream flow rate and composition are not reported.

2017-0308_M3_Hamilton_G35D_WasteTanks

* Project Setup Information

*

Project File : Z:\Client\DTE\West
 Virginia\Hamilton\Projects\173901.0082 Hamilton Permit Mod\04 Draft\2017-0306 Draft
 G35D Application\Attach R - Emission Calcs\2017-0308_M3_Hamilton_G35D_WasteTanks.ept
 Flowsheet Selection : Oil Tank with Separator
 Calculation Method : RVP Distillation
 Control Efficiency : 100.0%
 Known Separator Stream : Geographical Region
 Geographical Region : All Regions in US
 Entering Air Composition : No

Filed Name : Hamilton Compressor Station
 Well Name : Waste Fluid Tanks (T01 & T02)
 Date : 2016.10.31

* Data Input

*

Separator Pressure : 50.00[psi g]
 Separator Temperature : 125.00[F]
 Ambient Pressure : 14.70[psi a]
 Ambient Temperature : 125.00[F]
 C10+ SG : 0.8420
 C10+ MW : 287.00

-- Low Pressure Oil

No.	Component	mol %
1	H2S	1.2800
2	O2	0.0000
3	CO2	0.0300
4	N2	0.0000
5	C1	1.2700
6	C2	2.0800
7	C3	4.5700
8	i-C4	1.8900
9	n-C4	6.4800
10	i-C5	3.8800
11	n-C5	7.0400
12	C6	3.0500
13	C7	6.8200
14	C8	7.7800
15	C9	7.2300
16	C10+	37.9300
17	Benzene	0.8300
18	Toluene	1.0200
19	E-Benzene	0.0700
20	Xylenes	0.6500
21	n-C6	6.1000
22	2,2,4-Trimethyl p	0.0000

-- Sales Oil

2017-0308_M3_Hamilton_G35D_WasteTanks

 Production Rate : 0.1 [bbl/day]
 Days of Annual Operation : 365 [days/year]
 API Gravity : 49.0
 Reid Vapor Pressure : 8.90 [psi a]

 * Calculation Results
 *

-- Emission Summary

Item	Uncontrolled [ton/yr]	Uncontrolled [lb/hr]	
Page 1			E&P TANK
Total HAPs	0.020	0.005	
Total HC	0.254	0.058	
VOCs, C2+	0.247	0.056	
VOCs, C3+	0.229	0.052	

Uncontrolled Recovery Info.

Vapor	10.6600 x1E-3	[MSCFD]
HC Vapor	9.9100 x1E-3	[MSCFD]
GOR	106.60	[SCF/bbl]

-- Emission Composition

No	Component	Uncontrolled [ton/yr]	Uncontrolled [lb/hr]
1	H2S	0.012	0.003
2	O2	0.000	0.000
3	CO2	0.000	0.000
4	N2	0.000	0.000
5	C1	0.006	0.001
6	C2	0.018	0.004
7	C3	0.049	0.011
8	i-C4	0.020	0.005
9	n-C4	0.059	0.013
10	i-C5	0.026	0.006
11	n-C5	0.039	0.009
12	C6	0.008	0.002
13	C7	0.008	0.002
14	C8	0.004	0.001
15	C9	0.002	0.000
16	C10+	0.000	0.000
17	Benzene	0.002	0.000
18	Toluene	0.001	0.000
19	E-Benzene	0.000	0.000
20	Xylenes	0.000	0.000
21	n-C6	0.013	0.003
22	2,2,4-Triethyl p	0.000	0.000
	Total	0.267	0.061

-- Stream Data

No.	Component	MW	LP Oil	Flash Oil	Sale Oil	Flash Gas	W&S Gas
Total	Emissions						

2017-0308_M3_Hamilton_G35D_WasteTanks

	mol %	mol %	mol %	mol %	mol %
1 H2S	34.80	1.2800	0.2130	0.2130	6.8990
6.8990					
2 O2	32.00	0.0000	0.0000	0.0000	0.0000
0.0000					
3 CO2	44.01	0.0300	0.0021	0.0021	0.1768
0.1768					
4 N2	28.01	0.0000	0.0000	0.0000	0.0000
0.0000					
5 C1	16.04	1.2700	0.0369	0.0369	7.7635
7.7635					
6 C2	30.07	2.0800	0.2466	0.2466	11.7345
11.7345					
7 C3	44.10	4.5700	1.3445	1.3445	21.5554
21.5554					
8 i-C4	58.12	1.8900	0.9750	0.9750	6.7085
6.7085					
9 n-C4	58.12	6.4800	3.9279	3.9279	19.9192
19.9192					
10 i-C5	72.15	3.8800	3.2983	3.2983	6.9431
6.9431					
11 n-C5	72.15	7.0400	6.3906	6.3906	10.4595
10.4595					
12 C6	86.16	3.0500	3.2895	3.2895	1.7886
1.7886					
13 C7	100.20	6.8200	7.8112	7.8112	1.6004
1.6004					
14 C8	114.23	7.7800	9.1297	9.1297	0.6724
0.6724					
15 C9	128.28	7.2300	8.5561	8.5561	0.2466
0.2466					
16 C10+	166.00	37.9300	45.1329	45.1329	0.0000
0.0000					
17 Benzene	78.11	0.8300	0.9150	0.9150	0.3821
0.3821					
18 Toluene	92.13	1.0200	1.1834	1.1834	0.1596
0.1596					
19 E-Benzene	106.17	0.0700	0.0825	0.0825	0.0041
0.0041					
20 Xylenes	106.17	0.6500	0.7670	0.7670	0.0341
0.0341					
21 n-C6	86.18	6.1000	6.6977	6.6977	2.9524
2.9524					
22 2,2,4-Trimethyl p	114.24	0.0000	0.0000	0.0000	0.0000
0.0000					
MW	159.21	179.60	179.60	51.88	0.00
51.88					
Stream Mole Ratio	1.0000	0.8404	0.8404	0.1596	0.0000
0.1596					
Heating Value [BTU/SCF]				2822.40	0.00
2822.40					
Gas Gravity [Gas/Air]				1.79	0.00
1.79					
Bubble Pt. @ 100F [psi a]	76.98	12.70	12.70		

Page 2-----E&P TANK

RVP @ 100F [psi a]	27.72	8.66	8.66
Spec. Gravity @ 100F	0.690	0.698	0.698

2017-0308_M3_Hamilton_G35D_WasteTanks

TANKS 4.0.9d
Emissions Report - Detail Format
Tank Identification and Physical Characteristics

Identification

User Identification: Hamilton Station (Liquid Loading)
City:
State: West Virginia
Company:
Type of Tank: Vertical Fixed Roof Tank
Description: Liquid loading parameter calculations for truck loading of produced fluids

Tank Dimensions

Shell Height (ft): 14.00
Diameter (ft): 10.00
Liquid Height (ft) : 14.00
Avg. Liquid Height (ft): 7.00
Volume (gallons): 8,820.00
Turnovers: 34.86
Net Throughput(gal/yr): 307,440.00
Is Tank Heated (y/n): N

Paint Characteristics

Shell Color/Shade: Gray/Medium
Shell Condition: Good
Roof Color/Shade: Gray/Medium
Roof Condition: Good

Roof Characteristics

Type: Cone
Height (ft): 0.00
Slope (ft/ft) (Cone Roof): 0.00

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Elkins, West Virginia (Avg Atmospheric Pressure = 13.73 psia)

TANKS 4.0.9d
Emissions Report - Detail Format
Liquid Contents of Storage Tank

Hamilton Station (Liquid Loading) - Vertical Fixed Roof Tank

Mixture/Component	Month	Daily Liquid Surf. Temperature (deg F)			Liquid Bulk Temp (deg F)	Vapor Pressure (psia)			Vapor Mol. Weight.	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Produced Water	All	57.20	47.16	67.23	52.14	0.2365	0.1708	0.3240	19.3610	0.0001	0.0004	18.17	
Benzene						1.0800	0.8090	1.4225	78.1100	0.0001	0.0004	78.11	Option 2: A=6.905, B=1211.033, C=220.79
Butane (-n)						0.4772	0.3937	0.5736	58.1200	0.0005	0.0009	58.12	Option 2: A=5.09536, B=935.86, C=238.73
Decane (-n)						0.0313	0.0249	0.0394	142.2900	0.0045	0.0006	142.29	Option 1: VP50 = .026411 VP60 = .033211
Ethylbenzene						0.0984	0.0684	0.1390	106.1700	0.0000	0.0000	106.17	Option 2: A=6.975, B=1424.255, C=213.21
Heptane (-n)						0.5620	0.4123	0.7572	100.2000	0.0008	0.0017	100.20	Option 3: A=37358, B=8.2585
Hexane (-n)						1.7780	1.3561	2.3024	86.1700	0.0010	0.0071	86.17	Option 2: A=6.876, B=1171.17, C=224.41
Isopentane						9.4118	7.3180	11.8312	72.1500	0.0003	0.0123	72.15	Option 1: VP50 = 7.889 VP60 = 10.005
Nonane (-n)						0.0614	0.0482	0.0782	128.2600	0.0009	0.0002	128.26	Option 1: VP50 = .051285 VP60 = .065278
Octane (-n)						0.1362	0.1051	0.1764	114.2300	0.0009	0.0005	114.23	Option 1: VP50 = .112388 VP60 = .145444
Pentane (-n)						6.4211	5.1036	8.0084	72.1500	0.0006	0.0163	72.15	Option 3: A=27691, B=7.558
Propane (-n)						103.5663	88.7398	120.2028	44.0956	0.0002	0.0657	44.10	Option 2: A=7.340862493, B=1104.2267744, C=291.70993941
Toluene						0.3024	0.2186	0.4120	92.1300	0.0001	0.0001	92.13	Option 2: A=6.954, B=1344.8, C=219.48
Water						0.2277	0.1634	0.3135	18.0150	0.9900	0.8941	18.02	Option 1: VP50 = .178 VP60 = .247
Xylene (-m)						0.0818	0.0567	0.1160	106.1700	0.0001	0.0000	106.17	Option 2: A=7.009, B=1462.266, C=215.11

TANKS 4.0.9d
Emissions Report - Detail Format
Detail Calculations (AP-42)

Hamilton Station (Liquid Loading) - Vertical Fixed Roof Tank

Annual Emission Calculations

Standing Losses (lb):	12.8805
Vapor Space Volume (cu ft):	549.7787
Vapor Density (lb/cu ft):	0.0008
Vapor Space Expansion Factor:	0.0846
Vented Vapor Saturation Factor:	0.9193
Tank Vapor Space Volume:	
Vapor Space Volume (cu ft):	549.7787
Tank Diameter (ft):	10.0000
Vapor Space Outage (ft):	7.0000
Tank Shell Height (ft):	14.0000
Average Liquid Height (ft):	7.0000
Roof Outage (ft):	0.0000
Roof Outage (Cone Roof)	
Roof Outage (ft):	0.0000
Roof Height (ft):	0.0000
Roof Slope (ft/ft):	0.0000
Shell Radius (ft):	5.0000
Vapor Density	
Vapor Density (lb/cu ft):	0.0008
Vapor Molecular Weight (lb/lb-mole):	19.3610
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.2365
Daily Avg. Liquid Surface Temp. (deg. R):	516.8667
Daily Average Ambient Temp. (deg. F):	49.0583
Ideal Gas Constant R (psia cuft / (lb-mol-deg R)):	10.731
Liquid Bulk Temperature (deg. R):	511.8083
Tank Paint Solar Absorptance (Shell):	0.6800
Tank Paint Solar Absorptance (Roof):	0.6800
Daily Total Solar Insulation Factor (Btu/sqft day):	1,193.8870
Vapor Space Expansion Factor	
Vapor Space Expansion Factor:	0.0846
Daily Vapor Temperature Range (deg. R):	40.1436
Daily Vapor Pressure Range (psia):	0.1531
Breather Vent Press. Setting Range(psia):	0.0600
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.2365
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):	0.1708
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):	0.3240
Daily Avg. Liquid Surface Temp. (deg R):	516.8667
Daily Min. Liquid Surface Temp. (deg R):	506.8308
Daily Max. Liquid Surface Temp. (deg R):	526.9026
Daily Ambient Temp. Range (deg. R):	24.1833
Vented Vapor Saturation Factor	
Vented Vapor Saturation Factor:	0.9193
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.2365
Vapor Space Outage (ft):	7.0000
Working Losses (lb):	33.5192
Vapor Molecular Weight (lb/lb-mole):	19.3610
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.2365
Annual Net Throughput (gal/yr.):	307,440.0000
Annual Turnovers:	34.8571
Turnover Factor:	1.0000
Maximum Liquid Volume (gal):	8,820.0000
Maximum Liquid Height (ft):	14.0000
Tank Diameter (ft):	10.0000
Working Loss Product Factor:	1.0000
Total Losses (lb):	46.3997

TANKS 4.0.9d
Emissions Report - Detail Format
Individual Tank Emission Totals

Emissions Report for: Annual**Hamilton Station (Liquid Loading) - Vertical Fixed Roof Tank**

Components	Losses(lbs)		
	Working Loss	Breathing Loss	Total Emissions
Produced Water	33.52	12.88	46.40
Decane (-n)	0.02	0.01	0.03
Nonane (-n)	0.01	0.00	0.01
Ethylbenzene	0.00	0.00	0.00
Octane (-n)	0.02	0.01	0.02
Toluene	0.00	0.00	0.01
Heptane (-n)	0.06	0.02	0.08
Benzene	0.01	0.00	0.02

Hexane (-n)	0.24	0.09	0.33
Isopentane	0.41	0.16	0.57
Pentane (-n)	0.55	0.21	0.76
Water	29.97	11.52	41.49
Propane (-n)	2.20	0.85	3.05
Butane (-n)	0.03	0.01	0.04
Xylene (-m)	0.00	0.00	0.00

TANKS 4.0.9d
Emissions Report - Detail Format
Tank Identification and Physical Characteristics

Identification

User Identification: Hamilton Station (Glycol Tanks)
City: West Virginia
State: West Virginia
Company:
Type of Tank: Horizontal Tank
Description: Triethylene Glycol and Coolant (Monoethylene Glycol) Tanks

Tank Dimensions

Shell Length (ft): 8.00
Diameter (ft): 6.00
Volume (gallons): 1,260.00
Turnovers: 12.00
Net Throughput(gal/yr): 15,120.00
Is Tank Heated (y/n): N
Is Tank Underground (y/n): N

Paint Characteristics

Shell Color/Shade: Gray/Medium
Shell Condition: Good

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Elkins, West Virginia (Avg Atmospheric Pressure = 13.73 psia)

TANKS 4.0.9d
Emissions Report - Detail Format
Liquid Contents of Storage Tank

Hamilton Station (Glycol Tanks) - Horizontal Tank

Mixture/Component	Month	Daily Liquid Surf. Temperature (deg F)			Liquid Bulk Temp (deg F)	Vapor Pressure (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Propylene glycol	All	57.20	47.16	67.23	52.14	0.0008	0.0005	0.0014	76.1100			76.11	Option 2: A=8.2082, B=2085.9, C=203.54

TANKS 4.0.9d
Emissions Report - Detail Format
Detail Calculations (AP-42)

Hamilton Station (Glycol Tanks) - Horizontal Tank**Annual Emission Calculations**

Standing Losses (lb): 0.0426
Vapor Space Volume (cu ft): 144.0730
Vapor Density (lb/cu ft): 0.0000
Vapor Space Expansion Factor: 0.0734
Vented Vapor Saturation Factor: 0.9999

Tank Vapor Space Volume:
Vapor Space Volume (cu ft): 144.0730
Tank Diameter (ft): 6.0000
Effective Diameter (ft): 7.8196
Vapor Space Outage (ft): 3.0000
Tank Shell Length (ft): 8.0000

Vapor Density
Vapor Density (lb/cu ft): 0.0000
Vapor Molecular Weight (lb/lb-mole): 76.1100
Vapor Pressure at Daily Average Liquid Surface Temperature (psia): 0.0008
Daily Avg. Liquid Surface Temp. (deg. R): 516.8667
Daily Average Ambient Temp. (deg. F): 49.0583
Ideal Gas Constant R (psia cu ft / (lb-mol-deg R)): 10.731
Liquid Bulk Temperature (deg. R): 511.8083
Tank Paint Solar Absorbance (Shell): 0.6800
Daily Total Solar Insulation Factor (Btu/sqft day): 1,193.8870

Vapor Space Expansion Factor	0.0734
Vapor Space Expansion Factor:	0.0734
Daily Vapor Temperature Range (deg. R):	40.1436
Daily Vapor Pressure Range (psia):	0.0009
Breather Vent Press. Setting Range(psia):	0.0600
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0008
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):	0.0005
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):	0.0014
Daily Avg. Liquid Surface Temp. (deg R):	516.8667
Daily Min. Liquid Surface Temp. (deg R):	506.8308
Daily Max. Liquid Surface Temp. (deg R):	526.9026
Daily Ambient Temp. Range (deg. R):	24.1833
Vented Vapor Saturation Factor	0.9999
Vented Vapor Saturation Factor:	0.9999
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0008
Vapor Space Outage (ft):	3.0000
Working Losses (lb):	0.0221
Vapor Molecular Weight (lb/lb-mole):	76.1100
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0008
Annual Net Throughput (gal/yr.):	15,120.0000
Annual Turnovers:	12.0000
Turnover Factor:	1.0000
Tank Diameter (ft):	6.0000
Working Loss Product Factor:	1.0000
Total Losses (lb):	0.0647

TANKS 4.0.9d
Emissions Report - Detail Format
Individual Tank Emission Totals

Emissions Report for: Annual

Hamilton Station (Glycol Tanks) - Horizontal Tank

Components	Losses(lbs)		
	Working Loss	Breathing Loss	Total Emissions
Propylene glycol	0.02	0.04	0.06

TANKS 4.0.9d
Emissions Report - Detail Format
Tank Identification and Physical Characteristics

Identification

User Identification: Hamilton Station (Methanol Tanks)
City:
State: West Virginia
Company:
Type of Tank: Horizontal Tank
Description: Methanol Tanks

Tank Dimensions

Shell Length (ft): 6.00
Diameter (ft): 4.00
Volume (gallons): 335.00
Turnovers: 12.00
Net Throughput(gal/yr): 4,020.00
Is Tank Heated (y/n): N
Is Tank Underground (y/n): N

Paint Characteristics

Shell Color/Shade: Gray/Medium
Shell Condition: Good

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Elkins, West Virginia (Avg Atmospheric Pressure = 13.73 psia)

TANKS 4.0.9d
Emissions Report - Detail Format
Liquid Contents of Storage Tank

Hamilton Station (Methanol Tanks) - Horizontal Tank

Mixture/Component	Month	Daily Liquid Surf. Temperature (deg F)			Liquid Bulk Temp (deg F)	Vapor Pressure (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Methyl alcohol	All	57.20	47.16	67.23	52.14	1.3195	0.9508	1.8044	32.0400			32.04	Option 2: A=7.897, B=1474.08, C=229.13

TANKS 4.0.9d
Emissions Report - Detail Format
Detail Calculations (AP-42)

Hamilton Station (Methanol Tanks) - Horizontal Tank**Annual Emission Calculations**

Standing Losses (lb): 16.5979
Vapor Space Volume (cu ft): 48.0243
Vapor Density (lb/cu ft): 0.0076
Vapor Space Expansion Factor: 0.1416
Vented Vapor Saturation Factor: 0.8773

Tank Vapor Space Volume:
Vapor Space Volume (cu ft): 48.0243
Tank Diameter (ft): 4.0000
Effective Diameter (ft): 5.5293
Vapor Space Outage (ft): 2.0000
Tank Shell Length (ft): 6.0000

Vapor Density
Vapor Density (lb/cu ft): 0.0076
Vapor Molecular Weight (lb/lb-mole): 32.0400
Vapor Pressure at Daily Average Liquid Surface Temperature (psia): 1.3195
Daily Avg. Liquid Surface Temp. (deg. R): 516.8667
Daily Average Ambient Temp. (deg. F): 49.0583
Ideal Gas Constant R (psia cuft / (lb-mol-deg R)): 10.731
Liquid Bulk Temperature (deg. R): 511.8083
Tank Paint Solar Absorptance (Shell): 0.6800
Daily Total Solar Insulation Factor (Btu/sqft day): 1,193.8870

Vapor Space Expansion Factor	0.1416
Vapor Space Expansion Factor (deg. R):	40.1436
Daily Vapor Pressure Range (psia):	0.8536
Breather Vent Press. Setting Range(psia):	0.0600
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	1.3195
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):	0.9508
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):	1.8044
Daily Avg. Liquid Surface Temp. (deg R):	516.8667
Daily Min. Liquid Surface Temp. (deg R):	506.8308
Daily Max. Liquid Surface Temp. (deg R):	526.9026
Daily Ambient Temp. Range (deg. R):	24.1833
Vented Vapor Saturation Factor	0.8773
Vented Vapor Saturation Factor:	0.8773
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	1.3195
Vapor Space Outage (ft):	2.0000
Working Losses (lb):	4.0465
Vapor Molecular Weight (lb/lb-mole):	32.0400
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	1.3195
Annual Net Throughput (gal/yr.):	4,020.0000
Annual Turnovers:	12.0000
Turnover Factor:	1.0000
Tank Diameter (ft):	4.0000
Working Loss Product Factor:	1.0000
Total Losses (lb):	20.6444

TANKS 4.0.9d
Emissions Report - Detail Format
Individual Tank Emission Totals

Emissions Report for: Annual

Hamilton Station (Methanol Tanks) - Horizontal Tank

Components	Losses(lbs)		
	Working Loss	Breathing Loss	Total Emissions
Methyl alcohol	4.05	16.60	20.64

TANKS 4.0.9d
Emissions Report - Detail Format
Tank Identification and Physical Characteristics

Identification

User Identification: Hamilton Station (Oil Tanks)
City:
State: West Virginia
Company:
Type of Tank: Horizontal Tank
Description: Compressor and Engine Lube Oil Tanks

Tank Dimensions

Shell Length (ft): 8.00
Diameter (ft): 4.00
Volume (gallons): 500.00
Turnovers: 12.00
Net Throughput(gal/yr): 6,000.00
Is Tank Heated (y/n): N
Is Tank Underground (y/n): N

Paint Characteristics

Shell Color/Shade: Gray/Medium
Shell Condition: Good

Breather Vent Settings

Vacuum Settings (psig): -0.03
Pressure Settings (psig): 0.03

Meteorological Data used in Emissions Calculations: Elkins, West Virginia (Avg Atmospheric Pressure = 13.73 psia)

TANKS 4.0.9d
Emissions Report - Detail Format
Liquid Contents of Storage Tank

Hamilton Station (Oil Tanks) - Horizontal Tank

Mixture/Component	Month	Daily Liquid Surf. Temperature (deg F)			Liquid Bulk Temp (deg F)	Vapor Pressure (psia)			Vapor Mol. Weight	Liquid Mass Fract.	Vapor Mass Fract.	Mol. Weight	Basis for Vapor Pressure Calculations
		Avg.	Min.	Max.		Avg.	Min.	Max.					
Distillate fuel oil no. 2	All	57.20	47.16	67.23	52.14	0.0066	0.0041	0.0086	130.0000			188.00	Option 1: VP50 = .0045 VP60 = .0074

TANKS 4.0.9d
Emissions Report - Detail Format
Detail Calculations (AP-42)

Hamilton Station (Oil Tanks) - Horizontal Tank**Annual Emission Calculations**

Standing Losses (lb): 0.2655
Vapor Space Volume (cu ft): 64.0325
Vapor Density (lb/cu ft): 0.0002
Vapor Space Expansion Factor: 0.0736
Vented Vapor Saturation Factor: 0.9993

Tank Vapor Space Volume:
Vapor Space Volume (cu ft): 64.0325
Tank Diameter (ft): 4.0000
Effective Diameter (ft): 6.3847
Vapor Space Outage (ft): 2.0000
Tank Shell Length (ft): 8.0000

Vapor Density
Vapor Density (lb/cu ft): 0.0002
Vapor Molecular Weight (lb/lb-mole): 130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia): 0.0066
Daily Avg. Liquid Surface Temp. (deg. R): 516.8667
Daily Average Ambient Temp. (deg. F): 49.0583
Ideal Gas Constant R (psia cuft / (lb-mol-deg R)): 10.731
Liquid Bulk Temperature (deg. R): 511.8083
Tank Paint Solar Absorbance (Shell): 0.6800
Daily Total Solar Insulation Factor (Btu/sqft day): 1,193.8870

Vapor Space Expansion Factor	0.0736
Vapor Space Expansion Factor:	0.0736
Daily Vapor Temperature Range (deg. R):	40.1436
Daily Vapor Pressure Range (psia):	0.0045
Breather Vent Press. Setting Range(psia):	0.0600
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0066
Vapor Pressure at Daily Minimum Liquid Surface Temperature (psia):	0.0041
Vapor Pressure at Daily Maximum Liquid Surface Temperature (psia):	0.0086
Daily Avg. Liquid Surface Temp. (deg R):	516.8667
Daily Min. Liquid Surface Temp. (deg R):	506.8308
Daily Max. Liquid Surface Temp. (deg R):	526.9026
Daily Ambient Temp. Range (deg. R):	24.1833
Vented Vapor Saturation Factor	0.9993
Vented Vapor Saturation Factor:	0.9993
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0066
Vapor Space Outage (ft):	2.0000
Working Losses (lb):	0.1223
Vapor Molecular Weight (lb/lb-mole):	130.0000
Vapor Pressure at Daily Average Liquid Surface Temperature (psia):	0.0066
Annual Net Throughput (gal/yr.):	6,000.0000
Annual Turnovers:	12.0000
Turnover Factor:	1.0000
Tank Diameter (ft):	4.0000
Working Loss Product Factor:	1.0000
Total Losses (lb):	0.3878

TANKS 4.0.9d
Emissions Report - Detail Format
Individual Tank Emission Totals

Emissions Report for: Annual

Hamilton Station (Oil Tanks) - Horizontal Tank

Components	Losses(lbs)		
	Working Loss	Breathing Loss	Total Emissions
Distillate fuel oil no. 2	0.12	0.27	0.39



**CE-1 to CE-6
Compressor Engine
Specifications**

USA Compression Unit TBD Caterpillar G3606TALE Engine Emissions

Date of Manufacture	TBD	Engine Serial Number	TBD	Date Modified/Reconstructed	Not Any
Driver Rated HP	1775	Rated Speed in RPM	1000	Combustion Type	Spark Ignited 4 Stroke
Number of Cylinders	6	Compression Ratio	9:1	Combustion Setting	Ultra Lean Burn
Total Displacement, in ³	7762	Fuel Delivery Method	Fuel Injection	Combustion Air Treatment	T.C./Aftercooled

Raw Engine Emissions (905 LHV BTU/SCF Fuel Gas with little to no H2S)

Fuel Consumption 6860 LHV BTU/bhp-hr or 7609 HHV BTU/bhp-hr
 Altitude 1200 ft
 Maximum Air Inlet Temp 90 F

	<u>g/bhp-hr¹</u>	<u>lb/MMBTU²</u>	<u>lb/hr</u>	<u>TPY</u>
Nitrogen Oxides (NOx)	0.5		1.96	8.57
Carbon Monoxide (CO)	2.74		10.72	46.96
Volatile Organic Compounds (VOC or NMNEHC excluding CH2O)	0.63		2.47	10.80
Formaldehyde (CH2O)	0.26		1.02	4.46
Particulate Matter (PM) <small>Filterable+Condensable</small>		9.99E-03	1.35E-01	5.91E-01
Sulfur Dioxide (SO2)		5.88E-04	7.94E-03	3.48E-02
	<u>g/bhp-hr¹</u>		<u>lb/hr</u>	<u>Metric Tonne/yr</u>
Carbon Dioxide (CO2)	441		1726	6856
Methane (CH4)	5.36		20.97	83.33

¹ g/bhp-hr are based on Caterpillar Specifications (GERP) Customer Supplied fuel gas, 1200 ft elevation, and 90 F Max Air Inlet Temperature. Note that g/bhp-hr values are based on 100% Load Operation. For air permitting, it is recommended to use a 20% safety margin for CO, VOC and other organic compounds to allow for variation in operating parameters and fuel gas quality.

² Emission Factor obtained from EPA's AP-42, Fifth Edition, Volume I, Chapter 3: Stationary Internal Combustion Sources (Section 3.2 Natural Gas-Fired Reciprocating Engines, Table 3.2-2).

Catalytic Converter Emissions

Catalytic Converter Make and Model: DCL, DC64
 Element Type: DC-24.23" Round
 Number of Elements in Housing: 2
 Air/Fuel Ratio Control: Caterpillar ADEM A3, Burn Time

	<u>% Reduction</u>	<u>lb/hr</u>	<u>TPY</u>
Nitrogen Oxides (NOx)	0	1.96	8.57
Carbon Monoxide (CO)	95	0.54	2.35
Volatile Organic Compounds (VOC or NMNEHC excluding CH2O)	68	0.79	3.46
Formaldehyde (CH2O)	80	0.20	0.89
Particulate Matter (PM)	0	1.35E-01	5.91E-01
Sulfur Dioxide (SO2)	0	7.94E-03	3.48E-02
	<u>% Reduction</u>	<u>lb/hr</u>	<u>Metric Tonne/yr</u>
Carbon Dioxide (CO2)	0	1726	6856
Methane (CH4)	0	20.97	83.33



DCL America Inc.

12620 FM 1960 W, Ste A4 Box # 560, Houston, TX 77065
Tel.: 877-897-9759 Fax: 281-605-5858 E-mail: info@dclamerica.com

To	Chris Magee	Phone	
	USA Compression	Fax	
Date	October 31, 2014	Email	cmagee@usacompression.com

RE: EMISSIONS GUARANTEE

Chris,

We hereby guarantee that our QUICK-LID™ Model DC64AL2-16 Hospital+ Grade Catalytic Silencer described below:

Catalyst model	DC64AL2
Catalyst coating	Oxidation (A coating)
Outside Diameter of catalyst substrate	24.23"
No. Of Catalyst Layers	1
No. of catalyst substrates	2
Cell Density	300 cpsi
Approx. Attenuation	40-52 dBA

and sized for the following engine:

Engine model	CAT G3606LE
Power	1775 hp @ 1000 rpm
Fuel	Pipeline Quality Natural Gas

will perform as follows:

Emissions	After Catalyst (% destruction)
Carbon Monoxide (CO)	95%
Formaldehyde (HCHO)	80%
VOC (NMNEHC)	68%

for a period of 1 year (after invoice date) or 8000 hours, whichever comes first, subject to all terms and conditions contained in the attached warranty document being respected and met.

Best regards,
DCL America

Sam Kirk
Regional Account Manager

Confidential Communication

GAS COMPRESSION APPLICATION

ENGINE SPEED (rpm):	1000	RATING STRATEGY:	STANDARD
COMPRESSION RATIO:	9.2	RATING LEVEL:	CONTINUOUS
AFTERCOOLER TYPE:	SCAC	FUEL SYSTEM:	GAV
AFTERCOOLER WATER INLET (°F):	130	WITH AIR FUEL RATIO CONTROL	
JACKET WATER OUTLET (°F):	190	DTE HAMILTON CS 2-22-17	
ASPIRATION:	TA	42.8-47.0	
COOLING SYSTEM:	JW, OC+AC	92.0	
CONTROL SYSTEM:	CIS/ADEM3	928	
EXHAUST MANIFOLD:	DRY	1200	
COMBUSTION:	LOW EMISSION	90	
NOx EMISSION LEVEL (g/bhp-hr NOx):	0.5	1775 bhp@1000rpm	

RATING	NOTES	LOAD	SITE RATING AT MAXIMUM INLET AIR TEMPERATURE			
			100%	100%	75%	50%
ENGINE POWER (WITHOUT FAN)	(1)	bhp	1775	1775	1331	888
INLET AIR TEMPERATURE		°F	90	90	90	90

ENGINE DATA						
FUEL CONSUMPTION (LHV)	(2)	Btu/bhp-hr	6860	6860	7102	7619
FUEL CONSUMPTION (HHV)	(2)	Btu/bhp-hr	7609	7609	7878	8452
AIR FLOW (@inlet air temp, 14.7 psia) (WET)	(3)(4)	ft ³ /min	4833	4833	3738	2518
AIR FLOW (WET)	(3)(4)	lb/hr	20924	20924	16181	10900
FUEL FLOW (60°F, 14.7 psia)		scfm	219	219	170	121
INLET MANIFOLD PRESSURE	(5)	in Hg(abs)	74.3	74.3	57.9	41.2
EXHAUST TEMPERATURE - ENGINE OUTLET	(6)	°F	847	847	870	937
EXHAUST GAS FLOW (@engine outlet temp, 14.5 psia) (WET)	(7)(4)	ft ³ /min	12213	12213	9613	6821
EXHAUST GAS MASS FLOW (WET)	(7)(4)	lb/hr	21495	21495	16625	11218

EMISSIONS DATA - ENGINE OUT						
NOx (as NO ₂)	(8)(9)	g/bhp-hr	0.50	0.50	0.50	0.50
CO	(8)(9)	g/bhp-hr	2.74	2.74	2.74	2.74
THC (mol. wt. of 15.84)	(8)(9)	g/bhp-hr	6.30	6.30	6.50	6.77
NMHC (mol. wt. of 15.84)	(8)(9)	g/bhp-hr	0.94	0.94	0.98	1.01
NMNEHC (VOCs) (mol. wt. of 15.84)	(8)(9)(10)	g/bhp-hr	0.63	0.63	0.65	0.68
HCHO (Formaldehyde)	(8)(9)	g/bhp-hr	0.26	0.26	0.28	0.31
CO ₂	(8)(9)	g/bhp-hr	441	441	460	494
EXHAUST OXYGEN	(8)(11)	% DRY	12.8	12.8	12.1	11.1

HEAT REJECTION						
HEAT REJ. TO JACKET WATER (JW)	(12)	Btu/min	18751	18751	15595	13025
HEAT REJ. TO ATMOSPHERE	(12)	Btu/min	7103	7103	6619	6199
HEAT REJ. TO LUBE OIL (OC)	(12)	Btu/min	9132	9132	8667	8453
HEAT REJ. TO AFTERCOOLER (AC)	(12)(13)	Btu/min	16170	16170	8805	1713


COOLING SYSTEM SIZING CRITERIA			
TOTAL JACKET WATER CIRCUIT (JW)	(13)	Btu/min	20626
TOTAL AFTERCOOLER CIRCUIT (OC+AC)	(13)(14)	Btu/min	27937
A cooling system safety factor of 0% has been added to the cooling system sizing criteria.			

CONDITIONS AND DEFINITIONS
 Engine rating obtained and presented in accordance with ISO 3046/1, adjusted for fuel, site altitude and site inlet air temperature. 100% rating at maximum inlet air temperature is the maximum engine capability for the specified fuel at site altitude and maximum site inlet air temperature. Maximum rating is the maximum capability at the specified aftercooler inlet temperature for the specified fuel at site altitude and reduced inlet air temperature. Lowest load point is the lowest continuous duty operating load allowed. No overload permitted at rating shown.

For notes information consult page three.


Engine Power vs. Inlet Air Temperature

Data represents temperature sweep at 1200 ft and 1000 rpm




Engine Power vs. Engine Speed

Data represents speed sweep at 1200 ft and 90 °F



Engine Torque vs. Engine Speed

Data represents speed sweep at 1200 ft and 90 °F



Note: At site conditions of 1200 ft and 90°F inlet air temp., constant torque can be maintained down to 760 rpm. The minimum speed for loading at these conditions is 750 rpm.

NOTES

1. Engine rating is with two engine driven water pumps. Tolerance is $\pm 3\%$ of full load.
2. Fuel consumption tolerance is $\pm 2.5\%$ of full load data.
3. Air flow value is on a 'wet' basis. Flow is a nominal value with a tolerance of $\pm 5\%$.
4. Inlet and Exhaust Restrictions must not exceed A&I limits based on full load flow rates from the standard technical data sheet.
5. Inlet manifold pressure is a nominal value with a tolerance of $\pm 5\%$.
6. Exhaust temperature is a nominal value with a tolerance of (+)63°F, (-)54°F.
7. Exhaust flow value is on a "wet" basis. Flow is a nominal value with a tolerance of $\pm 6\%$.
8. Emissions data is at engine exhaust flange prior to any after treatment.
9. Emission values are based on engine operating at steady state conditions. Fuel methane number cannot vary more than ± 3 . Values listed are higher than nominal levels to allow for instrumentation, measurement, and engine-to-engine variations. They indicate "Not to Exceed" values. THC, NMHC, and NMNEHC do not include aldehydes. An oxidation catalyst may be required to meet Federal, State or local CO or HC requirements.
10. VOCs - Volatile organic compounds as defined in US EPA 40 CFR 60, subpart JJJJ
11. Exhaust Oxygen level is the result of adjusting the engine to operate at the specified NOx level. Tolerance is ± 0.5 .
12. Heat rejection values are nominal. Tolerances, based on treated water, are $\pm 10\%$ for jacket water circuit, $\pm 50\%$ for radiation, $\pm 20\%$ for lube oil circuit, and $\pm 5\%$ for aftercooler circuit.
13. Aftercooler heat rejection includes an aftercooler heat rejection factor for the site elevation and inlet air temperature specified. Aftercooler heat rejection values at part load are for reference only. Do not use part load data for heat exchanger sizing.
14. Cooling system sizing criteria are maximum circuit heat rejection for the site, with applied tolerances.

Constituent	Abbrev	Mole %	Norm
Water Vapor	H2O	0.0000	0.0000
Methane	CH4	96.7125	96.7125
Ethane	C2H6	2.6452	2.6452
Propane	C3H8	0.1242	0.1242
Isobutane	iso-C4H10	0.0028	0.0028
Norbutane	nor-C4H10	0.0092	0.0092
Isopentane	iso-C5H12	0.0005	0.0005
Norpentane	nor-C5H12	0.0005	0.0005
Hexane	C6H14	0.0000	0.0000
Heptane	C7H16	0.0000	0.0000
Nitrogen	N2	0.2418	0.2418
Carbon Dioxide	CO2	0.2633	0.2633
Hydrogen Sulfide	H2S	0.0000	0.0000
Carbon Monoxide	CO	0.0000	0.0000
Hydrogen	H2	0.0000	0.0000
Oxygen	O2	0.0000	0.0000
Helium	HE	0.0000	0.0000
Neopentane	neo-C5H12	0.0000	0.0000
Octane	C8H18	0.0000	0.0000
Nonane	C9H20	0.0000	0.0000
Ethylene	C2H4	0.0000	0.0000
Propylene	C3H6	0.0000	0.0000
TOTAL (Volume %)		100.0000	100.0000

Fuel Makeup: DTE HAMILTON CS
Unit of Measure: English

Calculated Fuel Properties

Caterpillar Methane Number:	92.0
Lower Heating Value (Btu/scf):	928
Higher Heating Value (Btu/scf):	1029
WOBBE Index (Btu/scf):	1227
THC: Free Inert Ratio:	196.98
Total % Inerts (% N2, CO2, He):	0.51%
RPC (%) (To 905 Btu/scf Fuel):	100%
Compressibility Factor:	0.998
Stoich A/F Ratio (Vol/Vol):	9.69
Stoich A/F Ratio (Mass/Mass):	16.95
Specific Gravity (Relative to Air):	0.572
Fuel Specific Heat Ratio (K):	1.311

CONDITIONS AND DEFINITIONS

Caterpillar Methane Number represents the knock resistance of a gaseous fuel. It should be used with the Caterpillar Fuel Usage Guide for the engine and rating to determine the rating for the fuel specified. A Fuel Usage Guide for each rating is included on page 2 of its standard technical data sheet.

RPC always applies to naturally aspirated (NA) engines, and turbocharged (TA or LE) engines only when they are derated for altitude and ambient site conditions.

Project specific technical data sheets generated by the Caterpillar Gas Engine Rating Pro program take the Caterpillar Methane Number and RPC into account when generating a site rating.

Fuel properties for Btu/scf calculations are at 60F and 14.696 psia.

Caterpillar shall have no liability in law or equity, for damages, consequently or otherwise, arising from use of program and related material or any part thereof.

FUEL LIQUIDS

Field gases, well head gases, and associated gases typically contain liquid water and heavy hydrocarbons entrained in the gas. To prevent detonation and severe damage to the engine, hydrocarbon liquids must not be allowed to enter the engine fuel system. To remove liquids, a liquid separator and coalescing filter are recommended, with an automatic drain and collection tank to prevent contamination of the ground in accordance with local codes and standards.

To avoid water condensation in the engine or fuel lines, limit the relative humidity of water in the fuel to 80% at the minimum fuel operating temperature.


GE-1 Generator Engine Specifications

STANDBY POWER RATING

200 kW, 250 kVA, 60 Hz

PRIME POWER RATING*

180 kW, 225 kVA, 60 Hz



*Built in the USA using domestic and foreign parts

*EPA Certified Prime ratings are not available in the U.S. or its Territories.

Image used for illustration purposes only


CODES AND STANDARDS

Generac products are designed to the following standards:

 UL2200, UL508, UL142, UL498


 NFPA70, 99, 110, 37

 NEC700, 701, 702, 708

 ISO9001, 8528, 3046, 7637, Pluses #2b, 4

 NEMA ICS10, MG1, 250, ICS6, AB1

 **ANSI**
American National Standards Institute
ANSI C62.41

 **ICC** **osHPD**
IBC 2009, CBC 2010, IBC 2012, ASCE 7-05,
ASCE 7-10, ICC-ES AC-156 (2012)

POWERING AHEAD

For over 50 years, Generac has led the industry with innovative design and superior manufacturing.

Generac ensures superior quality by designing and manufacturing most of its generator components, including alternators, enclosures and base tanks, control systems and communications software.

Generac's gensets utilize a wide variety of options, configurations and arrangements, allowing us to meet the standby power needs of practically every application.

Generac searched globally to ensure the most reliable engines power our generators. We choose only engines that have already been proven in heavy-duty industrial application under adverse conditions.

Generac is committed to ensuring our customers' service support continues after their generator purchase.

STANDARD FEATURES

ENGINE SYSTEM

General

- Oil Drain Extension
- Air Cleaner
- Fan Guard
- Stainless Steel flexible exhaust connection
- Factory Filled Oil & Coolant
- Radiator Duct Adapter (open set only)
- Critical Exhaust Silencer

Fuel System

- Flexible fuel line - NPT Connection
- Primary and secondary fuel shutoff

Cooling System

- Closed Coolant Recovery System
- UV/Ozone resistant hoses
- Factory-Installed Radiator
- 50/50 Ethylene glycol antifreeze
- Radiator drain extension

Engine Electrical System

- Battery charging alternator
- Battery cables
- Battery tray
- Rubber-booted engine electrical connections
- Solenoid activated starter motor

ALTERNATOR SYSTEM

- UL2200 Genprotect™
- Class H insulation material
- 2/3 Pitch
- Skewed Stator
- Permanent Magnet Excitation
- Sealed Bearings
- Amortisseur winding
- Full load capacity alternator

GENERATOR SET

- Internal Genset Vibration Isolation
- Separation of circuits - high/low voltage
- Separation of circuits - multiple breakers
- Wrapped Exhaust Piping
- Standard Factory Testing
- 2 Year Limited Warranty (Standby rated Units)
- 1 Year Warranty (Prime rated units)
- Silencer mounted in the discharge hood (enclosed only)

ENCLOSURE (IF SELECTED)

- Rust-proof fasteners with nylon washers to protect finish
- High performance sound-absorbing material (L1 & L2)
- Gasketed doors
- Stamped air-intake louvers
- Air discharge hoods for radiator-upward pointing
- Stainless steel lift off door hinges
- Stainless steel lockable handles
- Rhino Coat™ - Textured polyester powder coat

CONTROL SYSTEM



Control Panel

- Digital H Control Panel - Dual 4x20 Display
- Programmable Crank Limiter
- 7-Day Programmable Exerciser
- Special Applications Programmable PLC
- RS-232/485
- All-Phase Sensing DVR
- Full System Status
- Utility Monitoring
- Low Fuel Pressure Indication
- 2-Wire Start Compatible
- Power Output (kW)
- Power Factor
- kW Hours, Total & Last Run

- Real/Reactive/Apparent Power
- All Phase AC Voltage
- All Phase Currents
- Oil Pressure
- Coolant Temperature
- Coolant Level
- Engine Speed
- Battery Voltage
- Frequency
- Date/Time Fault History (Event Log)
- Isochronous Governor Control
- Waterproof/sealed Connectors
- Audible Alarms and Shutdowns
- Not in Auto (Flashing Light)
- Auto/Off/Manual Switch
- E-Stop (Red Mushroom-Type)
- NFPA110 Level I and II (Programmable)
- Customizable Alarms, Warnings, and Events
- Modbus protocol
- Predictive Maintenance algorithm
- Sealed Boards
- Password parameter adjustment protection

- Single point ground
- 15 channel data logging
- 0.2 msec high speed data logging
- Alarm information automatically comes up on the display

Alarms

- Oil Pressure (Pre-programmable Low Pressure Shutdown)
- Coolant Temperature (Pre-programmed High Temp Shutdown)
- Coolant Level (Pre-programmed Low Level Shutdown)
- Low Fuel Pressure Alarm
- Engine Speed (Pre-programmed Over speed Shutdown)
- Battery Voltage Warning
- Alarms & warnings time and date stamped
- Alarms & warnings for transient and steady state conditions
- Snap shots of key operation parameters during alarms & warnings
- Alarms and warnings spelled out (no alarm codes)

CONFIGURABLE OPTIONS

ENGINE SYSTEM

General

- Engine Block Heater
- Oil Heater
- Air Filter Restriction Indicator
- Stone Guard (Open Set Only)

Fuel Electrical System

- 10A & 2.5A UL battery charger
- Battery Warmer

ALTERNATOR SYSTEM

- Alternator Upsizing
- Anti-Condensation Heater
- Tropical Coating

CIRCUIT BREAKER OPTIONS

- Main Line Circuit Breaker
- 2nd Main Line Circuit Breaker
- Shunt Trip and Auxiliary Contact
- Electronic Trip Breaker

GENERATOR SET

- Gen-Link Communications Software (English Only)
- Extended Factory Testing (3 Phase Only)
- 8 Position Load Center
- 2 Year Extended Warranty
- 5 Year Warranty
- 5 Year Extended Warranty

ENCLOSURE

- Standard Enclosure
- Level 1 Sound Attenuation
- Level 2 Sound Attenuation
- Steel Enclosure
- Aluminum Enclosure
- 150 MPH Wind Kit
- 12 VDC Enclosure Lighting Kit
- 120 VAC Enclosure Lighting Kit
- AC/DC Enclosure Lighting Kit
- Door Alarm Switch

CONTROL SYSTEM

- 21-Light Remote Annunciator
- Remote Relay Board (8 or 16)
- Oil Temperature Sender with Indication Alarm
- Remote E-Stop (Break Glass-Type, Surface Mount)
- Remote E-Stop (Red Mushroom-Type, Surface Mount)
- Remote E-Stop (Red Mushroom-Type, Flush Mount)
- Remote Communication - Bridge
- Remote Communication - Ethernet
- 10A Run Relay
- Ground Fault Indication and Protection Functions

ENGINEERED OPTIONS

ENGINE SYSTEM

- Fluid containment Pans
- Coolant heater ball valves

ALTERNATOR SYSTEM

- 3rd Breaker Systems

CONTROL SYSTEM

- Spare inputs (x4) / outputs (x4) - H Panel Only
- Battery Disconnect Switch

GENERATOR SET

- Special Testing
- Battery Box

ENCLOSURE

- Motorized Dampers
- Enclosure Ambient Heaters

RATING DEFINITIONS

Standby - Applicable for a varying emergency load for the duration of a utility power outage with no overload capability.

Prime - Applicable for supplying power to a varying load in lieu of utility for an unlimited amount of running time. A 10% overload capacity is available for 1 out of every 12 hours. The Prime Power option is only available on International applications. Power ratings in accordance with ISO 8528-1, Second Edition

SG200 | 14.2L | 200 kW

INDUSTRIAL SPARK-IGNITED GENERATOR SET

EPA Certified Stationary Emergency

APPLICATION AND ENGINEERING DATA

ENGINE SPECIFICATIONS

General

Make	Generac
Cylinder #	6
Type	In-line
Displacement - L (cu In)	14.17 (864.71)
Bore - mm (in)	135 (5.31)
Stroke - mm (in)	165 (6.50)
Compression Ratio	9.5:1
Intake Air Method	Turbocharged/Aftercooled
Number of Main Bearings	7
Connecting Rods	Carbon Steel
Cylinder Head Type	Cast Iron GT250, OHV
Cylinder Head	Ductile Iron
Cylinder Liners	Altronic CD1
Piston Type	Aluminum
Crankshaft Type	Ductile Iron
Lifter Type	Solid
Intake Valve Material	Special Heat-Resistant Steel
Exhaust Valve Material	Alloy Steel, High Temp
Hardened Valve Seats	Alloy Steel, High Temp

Engine Governing

Governor	Electronic
Frequency Regulation (Steady State)	+/- 0.25%

Lubrication System

Oil Pump Type	Gear
Oil Filter Type	Full-Flow Cartridge
Crankcase Capacity - L (qts)	34.3 (36.2)

Cooling System

Cooling System Type	Pressurized Closed Recovery
Water Pump Flow -gal/min (l/min)	94 (356)
Fan Type	Pusher
Fan Speed (rpm)	1894
Fan Diameter mm (in)	762 (30)
Coolant Heater Wattage	2000
Coolant Heater Standard Voltage	240 V

Fuel System

Fuel Type	Natural Gas
Carburetor	Down Draft
Secondary Fuel Regulator	Standard
Fuel Shut Off Solenoid	Standard
Operating Fuel Pressure (Standard)	7" - 11" H ₂ O

Engine Electrical System

System Voltage	24 VDC
Battery Charging Alternator	Standard
Battery Size	See Battery Index 0161970SBY
Battery Voltage	(2)12 VDC
Ground Polarity	Negative

ALTERNATOR SPECIFICATIONS

Standard Model	520
Poles	4
Field Type	Revolving
Insulation Class - Rotor	H
Insulation Class - Stator	H
Total Harmonic Distortion	<5%
Telephone Interference Factor (TIF)	<50

Standard Excitation	Permanent Magnet
Bearings	Sealed Ball
Coupling	Direct, Flexible Disc
Prototype Short Circuit Test	Yes
Voltage Regulator Type	Full Digital
Number of Sensed Phases	3
Regulation Accuracy (Steady State)	±0.25%

OPERATING DATA

POWER RATINGS

		Natural Gas
Single-Phase 120/240 VAC @1.0pf	200 kW	Amps: 833
Three-Phase 120/208 VAC @0.8pf	200 kW	Amps: 694
Three-Phase 120/240 VAC @0.8pf	200 kW	Amps: 601
Three-Phase 277/480 VAC @0.8pf	200 kW	Amps: 301
Three-Phase 347/600 VAC @0.8pf	200 kW	Amps: 241

STARTING CAPABILITIES (sKVA)

sKVA vs. Voltage Dip

	kW	480 VAC						208/240 VAC					
		10%	15%	20%	25%	30%	35%	10%	15%	20%	25%	30%	35%
Standard	200	187	280	373	467	560	653	140	210	280	350	420	490
Upsize 1	250	263	395	527	658	790	922	197	296	395	494	593	692
Upsize 2	300	303	454	605	757	908	1059	227	341	454	568	681	794

FUEL CONSUMPTION RATES*

Natural Gas - ft³/hr (m³/hr)

Percent Load	Standby
25%	900 (25.5)
50%	1543 (43.7)
75%	2083 (59.0)
100%	2571 (72.8)

* Fuel supply installation must accommodate fuel consumption rates at 100% load.

COOLING

		Standby
Air Flow (inlet air combustion and radiator)	ft ³ /min (m ³ /in)	9432 (267)
Coolant Flow per Minute	gal/min (l/min)	6.1 (32.1)
Heat Rejection to Coolant	BTU/hr	670,280
Max. Operating Air Temp on Radiator	°F (°C)	122 (50)
Max. Operating Ambient Temperature (before derate)	°F (°C)	104 (40.0)
Maximum Radiator Backpressure	in H ₂ O	0.5

COMBUSTION AIR REQUIREMENT

	Standby
Flow at Rated Power cfm (m ³ /min)	432 (12.2)

ENGINE

		Standby
Rated Engine Speed	rpm	1800
Horsepower at Rated kW**	hp	304
Piston Speed	ft/min	1949 (594)
BMEP	psi	179


EXHAUST

		Standby
Exhaust Flow (Rated Output)	cfm (m ³ /min)	1499 (42.4)
Max. Backpressure (Post Silencer)	inHg (Kpa)	0.75
Exhaust Temp (Rated Output - post silencer)	°F (°C)	1384 (751)
Exhaust Outlet Size (Open Set)	mm (in)	3.5" I.D. Flex (No Silencer)

** Refer to "Emissions Data Sheet" for maximum bHP for EPA and SCAQMD permitting purposes.


Deration – Operational characteristics consider maximum ambient conditions. Derate factors may apply under atypical site conditions. Please consult a Generac Power Systems Industrial Dealer for additional details. All performance ratings in accordance with ISO3046, BS5514, ISO8528. and DIN6271 standards.

DIMENSIONS AND WEIGHTS*




OPEN SET (Includes Exhaust Flex)

L x W x H in (mm)	127.95 (3250) x 52.93 (1344.5) x 67.37 (1711.2)
Weight lbs (kg)	5460 (2477)




STANDARD ENCLOSURE

L x W x H in (mm)	153.89 (3909) x 52.73 (1339.3) x 69.67 (1769.6)
Weight lbs (kg)	Steel: 6440 (2921) Aluminum: 5974 (2710)



LEVEL 1 ACOUSTIC ENCLOSURE

L x W x H in (mm)	180.11 (4574.7) x 52.73 (1339.3) x 69.67 (1769.6)
Weight lbs (kg)	Steel: 6744 (3059) Aluminum: 6104 (2769)



LEVEL 2 ACOUSTIC ENCLOSURE

L x W x H in (mm)	154.45 (3922.9) x 53.96 (1370.6) x 93.40 (2372.3)
Weight lbs (kg)	Steel: 6980 (3166) Aluminum: 6206 (2815)

*All measurements are approximate and for estimation purposes only.

YOUR FACTORY RECOGNIZED GENERAC INDUSTRIAL DEALER

Specification characteristics may change without notice. Please consult a Generac Power Systems Industrial Dealer for detailed installation drawings.



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
2017 MODEL YEAR
CERTIFICATE OF CONFORMITY
WITH THE CLEAN AIR ACT


OFFICE OF TRANSPORTATION
AND AIR QUALITY
ANN ARBOR, MICHIGAN 48105

Certificate Issued To: Generac Power Systems, Inc.
(U.S. Manufacturer or Importer)

Certificate Number: HGNXB14.22C1-041

Effective Date:
11/09/2016

Expiration Date:
12/31/2017


Byron J. Bunker, Division Director
Compliance Division

Issue Date:
11/09/2016

Revision Date:
N/A


Manufacturer: Generac Power Systems, Inc.
Engine Family: HGNXB14.22C1
Mobile/Stationary Certification Type: Stationary
Fuel : Natural Gas (CNG/LNG)
Emission Standards :
Part 60 Subpart JJJJ Table 1
CO (g/kW-hr) : 5.4
NOx (g/kW-hr) : 2.7
VOC (g/kW-hr) : 1.3
Emergency Use Only : Y

Pursuant to Section 213 of the Clean Air Act (42 U.S.C. section 7547) and 40 CFR Part 60, 1065, 1068, and 60 (stationary only and combined stationary and mobile) and subject to the terms and conditions prescribed in those provisions, this certificate of conformity is hereby issued with respect to the test engines which have been found to conform to applicable requirements and which represent the following nonroad engines, by engine family, more fully described in the documentation required by 40 CFR Part 60 and produced in the stated model year.

This certificate of conformity covers only those new nonroad spark-ignition engines which conform in all material respects to the design specifications that applied to those engines described in the documentation required by 40 CFR Part 60 and which are produced during the model year stated on this certificate of the said manufacturer, as defined in 40 CFR Part 60. This certificate of conformity does not cover nonroad engines imported prior to the effective date of the certificate.

It is a term of this certificate that the manufacturer shall consent to all inspections described in 40 CFR 1068.20 and authorized in a warrant or court order. Failure to comply with the requirements of such a warrant or court order may lead to revocation or suspension of this certificate for reasons specified in 40 CFR Part 60. It is also a term of this certificate that this certificate may be revoked or suspended or rendered void *ab initio* for other reasons specified in 40 CFR Part 60.

This certificate does not cover large nonroad engines sold, offered for sale, or introduced, or delivered for introduction, into commerce in the U.S. prior to the effective date of the certificate.



PRIME POWER SYSTEMS

By Gillette Generators, Inc.

LIQUID COOLED NG ENGINE GENERATOR SET

KW POWER RATINGS RANGE FOR 60 HZ


Model	PRIME 105°C RISE	
	HZ	N.G.
PR-550-60 HERTZ	60	55

STANDARD FEATURES


- All generator sets are USA prototype built and thoroughly tested. Production models are USA factory built and 100% load tested.
- Mastertrak telematics remote monitoring equipment with 2 year service subscription. Required for all prime powered generators.
- All generators are UL-1446 certified.
- Solid state, frequency compensated voltage regulation is standard on all gen-sets.
- Electronic engine governor incorporates a throttle body actuator, which allows precise isochronous frequency regulation.
- A brushless rotating field generator design with shunt wound excitation system and connectable at 1 phase or a broad range of 3 phase voltages.
- SENTINEL “ULTIMATE” digital controller allows programming to basic engine functions in the field. Controller has stop-manual-auto mode and engine shutdowns, signaled by full text LCD indicators.
- Heavy Duty 100%-125% rated Circuit Breaker is standard on all gen-sets.
- All generator set control systems components and accessories provide a 1-year limited warranty at time of initial start-up. Generators and engines are governed by separate warranties.
- “OPEN” Generator Sets: There is no enclosure, so gen-set must be placed within a weather protected area, un-inhabited by humans or animals, with proper ventilation. Muffler and flexible exhaust hose are not supplied, as installation requirements are not known. However, these two items are available as optional equipment.
- “LEVEL 2” Aluminum Housing: Full weather protection and superior sound attenuation for specific low noise applications. Critical grade muffler is standard.

MODEL
PR-550
60 HERTZ

**GE-2 Generator
Engine
Specifications**



“OPEN” GEN-SET



“LEVEL 2” HOUSED GEN-SET

GENERATOR RATINGS

GENERATOR MODEL	VOLTAGE		PH	HZ	NATURAL GAS FUEL		POWER LEAD CONNECTIONS
	L-N	L-L			105°C RISE PRIME RATING		
					KW/KVA	AMP	
PR-550-1-1	120	240	1	60	55/55	229	4 LEAD DEDICATED 1 PH.
PR-550-3-2	120	208	3	60	55/69	191	12 LEAD LOW WYE
PR-550-3-3	120	240	3	60	55/69	166	12 LEAD HIGH DELTA
PR-550-3-4	277	480	3	60	55/69	83	12 LEAD HIGH WYE
PR-550-3-5	127	220	3	60	55/69	181	12 LEAD LOW WYE
PR-550-3-16	346	600	3	60	55/69	66	4 LEAD DEDICATED 3 PH.

RATINGS: All single phase gen-sets are dedicated 4 lead windings, rated at unity (1.0) power factor. All three phase gen-sets are 12 lead windings, rated at (.8) power factor. 105°C “PRIME RATINGS” are strictly for gen-sets provide the prime source of electric power, where normal utility power is unavailable or unreliable. A 10% overload is allowed for a total of 1 hour, within every 12 hours of operation of PRIME RATED systems. All gen-set power ratings are based on temperature rise measured by resistance method as defined by MIL-STD 705C and IEEE STD 115, METHOD 6.4.4. All generators have class H (180°C) insulation system on both rotor and stator windings. All factory tests and KW/KVA charts shown above are based on 105°C (prime) R/R winding temperature, within a maximum 40°C ambient condition. Specifications & ratings are subject to change without prior notice.

APPLICATION AND ENGINEERING DATA FOR MODEL PR-550-60 HZ

GENERATOR SPECIFICATIONS

Manufacturer..... Marathon Electric Generators
 Model & Type..... 361CSL1613, 4 Pole, 4 Lead, Single Phase
 361CSL1602, 4 Pole, 12 Lead re-connectable, Three Phase
 361PSL1633, 4 Pole, 4 lead, 600 VAC, Three Phase
 Exciter..... Brushless, shunt excited
 Voltage Regulator..... Solid State, HZ/Volts
 Voltage Regulation..... ½%, No load to full load
 Frequency..... Field convertible, 60 HZ to 50 HZ
 Frequency Regulation..... ½% (½ cycle, no load to full load)
 Unbalanced Load Capability..... 100% of prime amps
 Total Stator and Load Insulation..... Class H, 180°C
 Temperature Rise..... 105°C R/R, prime rating @ 40°C amb.
 1 Ø Motor Staring @ 30% Voltage Dip (240V)..... 130 kVA
 3 Ø Motor Staring @ 30% Voltage Dip (208-240V)..... 200 kVA
 3 Ø Motor Staring @ 30% Voltage Dip (480V)..... 260 kVA
 Bearing..... 1, Pre-lubed and sealed
 Coupling..... Direct flexible disc
 Total Harmonic Distortion..... Max 3½% (MIL-STD705B)
 Telephone Interference Factor..... Max 50 (NEMA MG1-22)
 Deviation Factor..... Max 5% (MIL-STD 405B)
 Ltd. Warranty Period..... 24 Months from date of start-up or
 1000 hours use, first to occur.

GENERATOR FEATURES

- World Renown Marathon Electric Generator having UL-1446 certification.
- Full generator protection with **SENTINEL “ULTIMATE”** controller, having UL-508 certification.
- Automatic voltage regulator with over-excitation, under-frequency compensation, under-speed protection, and EMI filtering. Entire solid-state board is encapsulated for moisture protection.
- Generator power ratings are based on temperature rise, measured by resistance method, as defined in MIL-STD 705C and IEEE STD 115, Method 6.4.4.
- Power ratings will not exceed temperature rise limitation for class H insulation as per NEMA MG1-22.40.
- Insulation resistance to ground, exceeds 1.5 meg-ohm.
- Stator receives 2000 V. hi-potential test on main windings, and rotor windings receive a 1500 V. hi-potential test, as per MIL-STD 705B.
- Full amortisseur windings with UL-1446 certification.
- Complete engine-generator torsional acceptance, confirmed during initial prototype testing.
- Full load testing on all engine-generator sets, before shipping.
- Self ventilating and drip-proof & revolving field design

ENGINE SPECIFICATIONS AND APPLICATIONS DATA

ENGINE

Manufacturer..... General Motors
 Model and Type..... Ind. Power Train, Vortec, 5.7L, 4 cycle
 Aspiration..... Natural
 Cylinder Arrangement..... 8 Cylinders, V-8
 Displacement Cu. In. (Liters)..... 350 (5.7)
 Bore & Stroke In. (Cm.)..... 4 x 3.48 (10.2 x 8.84)
 Compression Ratio..... 9.1:1
 Main Bearings & Style..... 5M 400 Copper Lead
 Cylinder Head..... Hardened Cast Iron
 Pistons..... High, Silicon Aluminum
 Crankshaft..... Nodular Iron
 Exhaust Valve..... Forged Steel
 Governor..... Electronic
 Frequency Reg. (no load-full load)..... Isochronous
 Frequency Reg. (steady state)..... ± 1/4%
 Air Cleaner..... Dry, Replaceable Cartridge
 Engine Speed..... 1800 rpm
 Piston Speed, ft/min (m./min)..... 1044 (318)
 Max Power, bhp (kwm) Prime/NG..... 85 (63)
 Ltd. Warranty Period..... 12 Months or 2000 hrs., first to occur

FUEL SYSTEM

Type..... NAT. GAS, Vapor Withdrawal
 Fuel Pressure (kpa), in. H₂O*..... (1.74) 7”
 Secondary Fuel Regulator..... NG Vapor System
 Auto Fuel Lock-Off Solenoid..... Standard on all sets
 Fuel Supply Inlet Line..... 1” NPTF
 * Measured at gen-set fuel inlet, downstream of any dry fuel accessories.

FUEL CONSUMPTION

NAT. GAS: FT ³ /HR (M ³ /HR)	PRIME
100% LOAD	720 (20.3)
75% LOAD	626 (17.7)
50% LOAD	450 (12.7)
NG = 1000 BTU X FT³/HR = Total BTU/HR	

OIL SYSTEM

Type..... Full Pressure
 Oil Pan Capacity qt. (L)..... 5.0 (4.7)
 Oil Pan Cap. W/ filter qt. (L)..... 6.5 (6.2)
 Oil Filter..... 1, Replaceable Spin-On

ELECTRICAL SYSTEM

Ignition System..... Electronic
 Eng. Alternator and Starter:
 Ground..... Negative
 Volts DC..... 12
 Max. Amp Output of Alternator..... 70
 Recommended Battery to -18°C (0°F): .. 12 VDC, Size BCI# 24F
 Max Dimensions: .. 10 3/4" lg X 6 3/4" wi X 9" hi, with standard round posts. Min. output at 600 CCA. Battery tray (max. dim. at 12”lg x 7”wi), hold down straps, battery cables, and battery charger, is furnished. Installation of (1) starting battery is required, with possible higher AMP/HR rating, as described above, if normal environment averages -13°F (-25°C) or cooler.

APPLICATION AND ENGINEERING DATA FOR MODEL PR-550-60 HZ

COOLING SYSTEM

Type of System Pressurized, closed recovery
 Coolant Pump Pre-lubricated, self-sealing
 Cooling Fan Type (no. of blades) Pusher (10)
 Fan Diameter inches (cm) 21" (533)
 Ambient Capacity of Radiator °F (°C)..... 125 (51.6)
 Engine Jacket Coolant Capacity Gal (L)..... 1.8 (6.8)
 Radiator Coolant Capacity Gal. (L) 5.2 (19.7)
 Maximum Restriction of Cooling Air Intake
 and discharge side of radiator in. H₂O (kpa)..... .5 (.125)
 Water Pump Capacity gpm (L/min)..... 27 (100)
 Heat Reject Coolant: Btu/min (kw) 3200 (54.9)
 Low Radiator Coolant Level Shutdown..... Standard
 Note: Coolant temp. shut-down switch setting at 212°F (100°C) with 50/50
 (water/antifreeze) mix.

COOLING AIR REQUIREMENTS

Combustion Air, cfm (m³/min) 185 (5.2)
 Radiator Air Flow cfm (m³/min) 6000 (170)
 Heat Rejected to Ambient:
 Engine: kw (btu/min) 30.9 (1760)
 Alternator: kw (btu/min)..... 7.5 (430)

EXHAUST SYSTEM

Exhaust Outlet Size..... 2.5"
 Max. Back Pressure in. hg (KPA)..... 3.0 (10.2)
 Exhaust Flow, at rated kw: cfm (m³/min) 580 (16.5)
 Exhaust Temp., at rated kw: °F (°C) 1200 (649)
 Engines are EPA certified for Natural Gas.

SOUND LEVELS MEASURED IN dB(A)

				<u>Open Set</u>	<u>Level 2 Encl.</u>
Level	2,	Critical	Silencer74.67
Level	3,	Hospital	Silencer72.65

Note: Open sets (no enclosure) has (3) optional silencer system choices due to unknown job-site applications. Level 2 enclosure has installed critical silencer with upgrade to hospital silencer. Sound tests are averaged from several test points and taken at 23 ft. (7 m) from source of noise at normal operation.

DERATE GENERATOR FOR ALTITUDE

3% per 1000 ft. (305m) above 3000 ft.(914m) from sea level

DERATE GENERATOR FOR TEMPERATURE

2% per 10°F (5.6°C) above 85°F (29.4°C)

DIMENSIONS AND WEIGHTS

	<u>Open Set</u>	<u>Level 2 Enclosure</u>
Length in (cm).....	78 (199)	102 (258)
Width in (cm).....	42 (107)	42 (107)
Height in (cm).....	38 (97)	53 (134)
1 Ø Net Weight lbs (kg).....	1931 (876)	2471 (1121)
1 Ø Ship Weight lbs (kg).....	2031 (921)	2571 (1166)
3 Ø Net Weight lbs (kg).....	1891 (858)	2431 (1103)
3 Ø Ship Weight lbs (kg).....	1991 (903)	2531 (1148)

SENTINEL ULTIMATE DIGITAL MICROPROCESSOR CONTROLLER



SENTINEL ULTIMATE
 The “Ultimate” controller is an auto start mains (utility) failure module for single gen-set applications. This controller includes a backlit LCD display which continuously displays the status of the engine and generator at all times.

The “Ultimate” controller will also monitor speed, frequency, voltage, current, oil pressure, coolant temp., and fuel levels. These modules have been designed to display warning and shut down status. It also includes: (11) configurable inputs • (8) configurable outputs • voltage monitoring • mains (utility) failure detection • (250) event logs • configurable timers • automatic shutdown or warning during fault detection • remote start (on load) • engine preheat • advanced metering capability • hour meter • text LCD displays • protected solid state outputs • test buttons for: stop/reset • manual mode • auto mode • lamp test • start button • power monitoring (kWh, kVAR, kVAh, kVArh)

This controller includes the “Ultimate” in expansion features including RS232, RS484 (using MODBUS-RTU/TCP), direct USB connection with PC, expansion optioned using DSEnet for remote annunciation and remote relay interfacing for a distance of up to 3300FT. The controller software is freely downloadable from the internet and allows monitoring with direct USB cable, LAN, or by internet via the built in web interface.



Further expansion is available by adding the optional “WebNet” gateway interface module. This device will allow comprehensive monitoring of the generator via the cloud including identification, location, and status. Some advantages of this module include: reduced site visits and maintenance costs • remote fuel management • fault analysis • asset tracking • automatic system alerts • maximized system up-time.

STANDARD AND OPTIONAL FEATURES FOR MODEL PR-550-60HZ

STANDARD FEATURES

CONTROL PANEL:

- SENTINEL "ULTIMATE" digital microprocessor with logic allows programming in the field. Controller has:
- STOP-MANUAL-AUTO modes and automatic engine shutdowns, signaled by full text LCD indicators:
 - Low oil pressure Engine fail to start
 - High engine temp Engine over speed
 - Low Radiator Level Engine under speed
 - Three auxiliary alarms Over & under voltage
 - Battery fail alarm
- Also included is tamper-proof engine hour meter

ENGINE:

- Full flow oil filter • Air filter • Oil pump • Solenoid type starter motor • Hi-temp radiator • Jacket water pump
- Thermostat • Pusher fan and guard • Exhaust manifold
 - Residential Silencer • 12 VDC battery charging alternator
 - Flexible exhaust connector • "Isochronous" duty, electronic governor • Secondary dry fuel regulator • Dry fuel lock-off solenoid • Vibration isolators • Closed coolant recovery system with 50/50 water to anti-freeze mixture

AC GENERATOR SYSTEM:

- AC generator • Shunt excited • Brushless design • Circuit Breaker installed and wired to gen-set • Direct connection to engine with flex disc • Class H, 180°C insulation • Self ventilated • Drip proof construction • UL Certified

VOLTAGE REGULATOR:

- ½% Voltage regulation • EMI filter • Under-speed protection • Over-excitation protection • total encapsulation

DC ELECTRICAL SYSTEM:


- Battery tray • Battery cables • Battery hold down straps
- 2-stage battery float charger with maintaining & recharging automatic charge stages

WEATHER/SOUND PROOF ALUMINUM HOUSING CORROSION RESISTANT PROTECTION CONSISTING OF:




- 9 Heated And Agitated Wash Stages.
- Zinc Phosphate Etching-coating Stage
- Final Baked On Enamel Powder Coat
- 18/8 Stainless Steel Hardware

ACCESSORY ITEMS

- Engine Coolant Heater with automatic 80°F on, 100°F off, thermostat
- Starting Battery Heater Blanket with automatic 60°F on, 80°F off, thermostat
- Battery Charger Upgrade, float type, 12 VDC at max. charge, with ammeter on charger.
- External Permanent Magnet Generator (PMG) for increased induction motor starting capacity on 1Ø or 3 Ø sets, and short circuit protection.
- Exhaust Silencer Hospital Grade
- All brushed type 304 stainless steel weather and sound deadening housing for coastal areas.
- DSE WebNet Gateway expansion module will allow communications with a host server via Ethernet and the DSE cloud connection for mapping static locations, real time instrumentation, control event log tables, and automatic system alerts via email.
- Remote Annunciator for up to (10) reporting functions. An additional relay expansion module, plus a second Annunciator adds another (10) reporting functions.



Design & specifications subject to change without prior notice. Dimensions shown are approximate. Contact Gillette for certified drawings.
DO NOT USE DIMENSIONS FOR INSTALLATION PURPOSES.






**UNITED STATES ENVIRONMENTAL PROTECTION AGENCY
2015 MODEL YEAR
CERTIFICATE OF CONFORMITY
WITH THE CLEAN AIR ACT**

**OFFICE OF TRANSPORTATION
AND AIR QUALITY
ANN ARBOR, MICHIGAN 48105**

Certificate Issued To: Power Solutions International, Inc.
(U.S. Manufacturer or Importer)

Certificate Number: FPSIB5.70NGP-006

Effective Date:
10/20/2014
Expiration Date:
12/31/2015


Byron J. Bunker, Division Director
Compliance Division

Issue Date:
10/20/2014
Revision Date:
N/A

Manufacturer: Power Solutions International, Inc.

Engine Family: FPSIB5.70NGP

Certification Type: Mobile and Stationary

Fuel: Natural Gas (CNG/LNG)
LPG/Propane

Emission Standards: VOC (g/HP-hr) : 0.7

CO (g/HP-hr) : 2

NOx (g/HP-hr) : 1HC + NOx (g/kW-hr) : 2.7

CO (g/kW-hr) : 4.4

NMHC + NOx (g/kW-hr) : 2.7

Emergency Use Only : N

Pursuant to Section 213 of the Clean Air Act (42 U.S.C. section 7547) and 40 CFR Part 60, 40 CFR Part 1048, 1065, 1068, and 60 (stationary only and combined stationary and mobile) and subject to the terms and conditions prescribed in those provisions, this certificate of conformity is hereby issued with respect to the test engines which have been found to conform to applicable requirements and which represent the following nonroad engines, by engine family, more fully described in the documentation required by 40 CFR Part 60, 40 CFR Part 1048 and produced in the stated model year.

This certificate of conformity covers only those new nonroad spark-ignition engines which conform in all material respects to the design specifications that applied to those engines described in the documentation required by 40 CFR Part 60, 40 CFR Part 1048 and which are produced during the model year stated on this certificate of the said manufacturer, as defined in 40 CFR Part 60, 40 CFR Part 1048. This certificate of conformity does not cover nonroad engines imported prior to the effective date of the certificate.

It is a term of this certificate that the manufacturer shall consent to all inspections described in 40 CFR 1068.20 and authorized in a warrant or court order. Failure to comply with the requirements of such a warrant or court order may lead to revocation or suspension of this certificate for reasons specified in 40 CFR Part 60, 40 CFR Part 1048. It is also a term of this certificate that this certificate may be revoked or suspended or rendered void *ab initio* for other reasons specified in 40 CFR Part 60, 40 CFR Part 1048.

This certificate does not cover large nonroad engines sold, offered for sale, or introduced, or delivered for introduction, into commerce in the U.S. prior to the effective date of the certificate.

Ultra-clean electricity and useful thermal energy from a rugged and efficient gas turbine.

250 kW Continuous Onsite Electrical Power with Integrated Heat Recovery


KEY FEATURES

- High system efficiency
- Synchronous generator ideal for off-grid oil & gas applications
- Grid-parallel, Grid isolated, or Dual-mode operation
- Low emissions exceed stringent environmental standards
- Integrated, variable-output, waste-heat recovery unit available
- Over two million hours of fleet operating experience

ELECTRICAL PERFORMANCE*

CHARACTERISTIC	SPECIFICATION
Electrical efficiency (± 2 pts)	30% LHV without gas booster
Electrical power** (±15 kW)	250 kW nominal

ELECTRICAL OUTPUT GRAPH SHOWS CHANGE IN POWER AND EFFICIENCY WITH TEMPERATURE




Note: kWe is electrical output at terminals corrected for parasitics, but not including gas booster power

Nominal heat rate (HHV)	12,645 Btu/kWh (13.3 MJ/kWh) without gas booster
	13,080 Btu/kWh (13.8 MJ/kWh) with gas booster
Nominal heat rate (LHV)	11,380 Btu/kWh (12.0 MJ/kWh) without gas booster
	11,770 Btu/kWh (12.4 MJ/kWh) with gas booster
Voltage	480 VAC/400 VAC
Frequency	60 Hz/50 Hz
Type of service	3 phase, wye, 4 wire
Grid-isolated regulation (steady state)	± 0.50% nominal voltage
	± 0.30 Hz nominal frequency
Transient handling (linear loads) (recovery within 5 seconds)	± 10% nominal voltage max
	± 5 Hz frequency max

* At ISO Conditions (59°F [15°C] @ sea level, 60% RH) unless otherwise noted, pipeline natural gas only.

** Elevation derate of approximately 8.80 kW per 1000 ft (305 m)



CARB CERTIFICATION

- The GT250S is the first microturbine to be certified to the California Air Resource Board's 2007 emissions standards

RUGGED GAS TURBINE

- Back-to-back rotating components
- Proven oil-lubricated bearings
- High H₂S tolerance up to 6500 ppmv

SYNCHRONOUS GENERATOR

- Same technology utilities use to power the grid
- High load starting capability up to 100 hp DOL

PATENTED RECUPERATOR

- Critical to high system efficiency
- Compact rugged design

PATENTED COMBUSTOR

- Dry low NO_x
- Meets stringent environmental regulations


SOPHISTICATED CONTROLS

- Closed transition dual-mode functionality
- Remote monitoring capability

COMBINED HEAT AND POWER


- Controllable output level
- Integral heat recovery unit contained within turbine enclosure
- No ducting

HEAT OUTPUT RECOVERABLE TO WATER



Note: Heat Recovery Unit (HRU) at ISO conditions, damper fully open, ± 15%

PHYSICAL SPECIFICATIONS



Weatherproof Outdoor Enclosure

DIMENSIONS		WIDTH	LENGTH	HEIGHT	WEIGHT Est.
Indoor Unit	(in)	77.2	167.6	91.9	14,500 lb
	(cm)	196.0	425.8	229.9	6,577 kg
Outdoor Unit	(in)	77.2	167.6	158.1	14,500 lb
	(cm)	196.0	425.8	401.6	6,577 kg

MINIMUM CLEARANCE REQUIREMENTS

CHARACTERISTIC	SPECIFICATION
Vertical clearance	102 in (259 cm)
- Indoor Unit	No overhead obstruction
- Outdoor Unit	
Horizontal front, rear and left side	48 in (122 cm)
Horizontal right side	72 in (183 cm)



Generator Braking Resistor

GENERATOR BRAKING RESISTOR

CHARACTERISTIC	SPECIFICATION
Dimensions (LxWxH)	37x63x30 (94x160x76 cm)
Weight	485 lb (220 kg)

SOUND LEVELS

CHARACTERISTIC	SPECIFICATION
Standard	80 dB(A) @ 1m
Low sound option	77 dB(A) @ 1m

CONTACT INFORMATION

INFO@FLEXENERGY.COM

PHONE
USA: +1.877.477.6937

Europe: +44 (0)7710 827141

ADDRESS
30 New Hampshire Avenue
Portsmouth, NH 03801
United States

HEAT RECOVERY*

CHARACTERISTIC	SPECIFICATION
Recuperator exhaust temp. w/o HRU	493°F (256°C)
Engine air flow	4.7 lb/s (2.13 kg/s)
Max water flow	3700 scfm (5950 Nm ³ /h)
Max inlet water pressure	100 gpm (379 lpm)
Max inlet water temp.	125 psig (862 kPa)
	185°F (85°C)

* at ISO Conditions (59°F [15°C] @ sea level, 60% RH) unless otherwise noted.

FUEL REQUIREMENTS

CHARACTERISTIC	SPECIFICATION
Inlet pressure	
-with gas booster	4" (100 mm) WC to 1 psig (6.9 kPa)
-without gas booster	80 to 140 psig (551 to 965 kPa)

Min temperature*	33°F (1°C)
Max temp.	
-with gas booster	115°F (46°C)
-without gas booster	175°F (79°C)

250SW Model**	325 to 600 WI Btu/ft ³
low caloric value gas, level 1	12.1 to 22.3 WI MJ/m ³

250ST Model**	500 to 970 WI Btu/ft ³
low caloric value gas, level 2	18.6 to 36.1 WI MJ/m ³

250SM Model**	800 to 1900 WI Btu/ft ³
medium / high caloric value gas	29.8 to 70.7 WI MJ/m ³

* Or 18°F dewpoint suppression, whichever is greater
** Wobbe Index. Lower heating value (LHV), dry basis, at 14.7 psi (101 kPa) and 59°F (15°C)

EMISSIONS AT 100% LOAD*

CHARACTERISTIC	SPECIFICATION
NOx	<5 ppmv @ 15% O ₂
CO	<5 ppmv @ 15% O ₂
VOC	<5 ppmv @ 15% O ₂


* Pipeline natural gas only at ISO conditions

AMBIENT TEMPERATURE LIMIT

CHARACTERISTIC	SPECIFICATION
Standard	-10° to 115°F (-23° to 46°C)
Cold Weather Option*	-20° to 115°F (-29° to 46°C)

* Some configurations may require additional cold-weather options

GT250S GAS TURBINE CYCLE



©2015 FlexEnergy Inc. and/or its affiliates ("FlexEnergy"). This document comprises a general overview of the products or services described herein. It is solely for informational purposes, does not represent a warranty of the information contained herein and is not to be construed as an offer to sell or solicitation to buy. Contact FlexEnergy for detailed product, design, and engineering information suitable to your specific applications. FlexEnergy reserves the right to modify its products and related product information at any time without prior notice.

March 20, 2017

Subject: DTE, West Virginia – GT250S Emissions Data

Below are the expected emissions of a single Flex Turbine® GT250S operating on natural gas. The assumed site conditions are 1602 ft. asl., with an ambient temperature range of 0°F to 100°F. For permitting purposes, it is always recommended to permit for the maximum acceptable limits.

Constituent	Percent Power	ppmv @ 15% O ₂	lb/MWh
NOx	70%	12	0.45
	85%	9	0.35
	100%	5	0.20
CO	70%	50	1.12
	85%	11	0.26
	100%	5	0.12
VOCs	70%	20	0.25
	85%	10	0.13
	100%	5	0.07

Let us know if you have any additional questions.

Regards,

Joe Skuza
Applications Engineer
FlexEnergy Inc.
Phone: +1 603-957-8835
joe.skuza@flexenergy.com

Facility-Wide Emission Summary

ATTACHMENT V – FACILITY-WIDE CONTROLLED EMISSIONS SUMMARY SHEET

List all sources of emissions in this table. Use extra pages if necessary.

Emission Point ID#	NO _x		CO		VOC		SO ₂		PM ₁₀		PM _{2.5}		GHG (CO ₂ e)	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
CE-1	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	2,250.99	9,859.35
CE-2	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	2,250.99	9,859.35
CE-3	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	2,250.99	9,859.35
CE-4	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	2,250.99	9,859.35
CE-5	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	2,250.99	9,859.35
CE-6	1.96	8.58	0.54	2.37	0.99	4.34	0.01	0.03	0.13	0.59	0.13	0.59	2,250.99	9,859.35
GE-1	1.35	0.34	2.70	0.67	0.70	0.18	1.6E-03	3.9E-04	0.05	0.01	0.05	0.01	310.42	77.61
GE-2	0.19	0.82	0.37	1.64	0.15	0.64	4.4E-04	1.9E-03	0.01	0.06	0.01	0.06	86.93	380.77
MT-1	0.11	0.49	0.28	1.23	0.06	0.27	0.01	0.05	0.02	0.09	0.02	0.09	382.98	1,677.44
TEG-1	---	---	---	---	0.99	4.34	---	---	---	---	---	---	4,424.21	19,378.05
TEG-2	---	---	---	---	0.99	4.34	---	---	---	---	---	---	4,424.21	19,378.05
REB-1	0.15	0.64	0.12	0.54	0.01	0.04	8.7E-04	3.8E-03	0.01	0.05	0.01	0.05	175.68	769.47
REB-2	0.15	0.64	0.12	0.54	0.01	0.04	8.7E-04	3.8E-03	0.01	0.05	0.01	0.05	175.68	769.47
T10	---	---	---	---	0.05	0.23	---	---	---	---	---	---	0.03	0.15
T11	---	---	---	---	0.05	0.23	---	---	---	---	---	---	0.03	0.15
De minimis storage tanks	---	---	---	---	0.00	0.01	---	---	---	---	---	---	---	---
L01	---	---	---	---	0.05	0.01	---	---	---	---	---	---	---	---
Fugitives	---	---	---	---	---	1.57	---	---	---	---	---	---	---	3,069.47
Haul Roads	---	---	---	---	---	---	---	---	---	0.12	---	0.01	---	---
FACILITY TOTAL	13.70	54.43	6.84	18.80	9.01	37.91	0.06	0.27	0.92	4.00	0.92	3.83	23,486.13	104,656.68
FACILITY TOTAL (Excluding fugitives)	13.70	54.43	6.84	18.80	9.01	36.34	0.06	0.27	0.92	3.81	0.92	3.81	23,486.13	101,587.21

Annual emissions shall be based on 8,760 hours per year of operation for all emission units except emergency generators.

According to 45CSR14 Section 2.43.e, fugitive emissions are not included in the major source determination because it is not listed as one of the source categories in Table 1. Therefore, fugitive emissions shall not be included in the PTE above.

ATTACHMENT V – FACILITY-WIDE HAP CONTROLLED EMISSIONS SUMMARY SHEET

List all sources of emissions in this table. Use extra pages if necessary.

Emission Point ID#	Formaldehyde		Benzene		Toluene		Ethylbenzene		Xylenes		Hexane		Total HAPs	
	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy	lb/hr	tpy
CE-1	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.46	2.02
CE-2	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.46	2.02
CE-3	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.46	2.02
CE-4	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.46	2.02
CE-5	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.46	2.02
CE-6	0.20	0.88	5.9E-03	2.6E-02	5.5E-03	2.4E-02	5.4E-04	2.3E-03	2.5E-03	1.1E-02	0.01	0.07	0.46	2.02
GE-1	0.05	0.01	6.6E-05	1.6E-05	3.4E-05	1.5E-04	5.2E-04	1.3E-04	<0.01	<0.01	<0.01	<0.01	0.09	0.02
GE-2	0.02	0.07	1.8E-05	8.1E-05	9.6E-06	4.2E-05	1.4E-04	6.3E-04	<0.01	<0.01	<0.01	<0.01	0.02	0.11
MT-1	2.3E-03	0.01	3.9E-05	1.7E-04	4.3E-04	1.9E-03	1.0E-04	4.6E-04	2.1E-04	9.2E-04	---	---	3.4E-03	0.01
TEG-1	---	---	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01
TEG-2	---	---	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01	<0.01
REB-1	1.1E-04	4.8E-04	3.1E-06	1.3E-05	4.9E-06	2.2E-05	---	---	---	---	2.6E-03	0.01	2.7E-03	0.01
REB-2	1.1E-04	4.8E-04	3.1E-06	1.3E-05	4.9E-06	2.2E-05	---	---	---	---	2.6E-03	0.01	2.7E-03	0.01
T10	---	---	4.6E-04	2.0E-03	2.3E-04	1.0E-03	<0.01	<0.01	<0.01	<0.01	3.0E-03	0.01	4.6E-03	0.02
T11	---	---	4.6E-04	2.0E-03	2.3E-04	1.0E-03	<0.01	<0.01	<0.01	<0.01	3.0E-03	0.01	4.6E-03	0.02
De minimis storage tanks	---	---	---	---	---	---	---	---	---	---	---	---	2.5E-03	0.01
L01	---	---	---	---	---	---	---	---	---	---	---	---	0.01	1.4E-03
Fugitives	---	---	---	---	---	---	---	---	---	---	---	---	---	---
Haul Roads	---	---	---	---	---	---	---	---	---	---	---	---	---	---
FACILITY TOTAL	1.27	5.35	0.04	0.16	0.03	0.15	4.0E-03	0.02	0.02	0.07	0.10	0.44	2.91	12.36
FACILITY TOTAL (Excl. fugitives)	1.27	5.35	0.04	0.16	0.03	0.15	4.0E-03	0.02	0.02	0.07	0.10	0.44	2.91	12.36

Annual emissions shall be based on 8,760 hours per year of operation for all emission units except emergency generators. According to 45CSR14 Section 2.43.e, fugitive emissions are not included in the major source determination because it is not listed as one of the source categories in Table 1. Therefore, fugitive emissions shall not be included in the PTE above.

Class I Legal Advertisement