Longview Power

The Future of Reliable Clean Coal Power

June 9, 2017

William F. Durham, Director
WV Department of Environmental Protection
Division of Air Quality
601 57th Street SE
Charleston, WV 25304

Re: **Renewal Application**
Title V Permit # R30-06100134-2013
Longview Power, LLC

Dear Mr. Durham,

Enclosed please find 2 CD's containing full electronic versions of Longview's Title V Permit renewal application, and a hard copy of the certification page with original signature. We are submitting this application well in advance of the November 14, 2017 due date to allow time for WVDEP to review and request any additional information as may be necessary to gain "administratively complete" status prior to November 14, 2017.

The emissions calculation workbook has been updated to include the following:

- Former emission units SA-3, SA-8, SA-9, and SA-12, all within the ash handling system, have been permanently removed from Longview.
- Maximum annual operating hours for emission units EG-1 and EP-1 (emergency generator and fire pump) have each been reduced to 100 hours /year to reflect the limitation of 40 CFR 60 Subpart ZZZZ
- Moisture contents used for coal, limestone and ash handling calculations now reflect actual averages observed through ongoing analyses.
- The PM PTE for the coal boiler has been reduced to reflect the .015 lb/MMBtu limit of 40 CFR 60.42Da(c)(2).

We look forward to working with the WVDEP to complete the review of this application and renewal of the permit. Thank you for your assistance in this matter.

Sincerely,

Joseph R. Douglass
Asset and Environmental Director

1375 Fort Martin Road, Maidsville, WV 26541
Phone: (304) 599-0930 Fax: (304) 599-3829