



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone 304/926-0475

Jim Justice, Governor  
Austin Caperton, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

August 4, 2017

Wesley Leek  
Director  
City of Huntington Sanitary Board  
555 7<sup>th</sup> Avenue  
Huntington, WV 25701

RE: Approved Registration G65-C566  
Huntington Wastewater Treatment Plant  
Plant ID No. 011-00219

Dear Mr. Leek:

The Director has determined that the submitted Registration Application and construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G65-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.5.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer

Enclosures: General Permit Registration G65-C566  
General Permit G65-C



Facility Location:           Huntington, Cabell County, West Virginia  
Mailing Address:           555 7<sup>th</sup> Avenue, Huntington, WV 25701  
Facility Description:       Emergency Generator  
SIC Codes:                 4922  
UTM Coordinates:         376.60 km Easting • 4250.50 km Northing • Zone 17  
Registration Type:         Construction  
Description of Change:     Construction of an Emergency Generator

Subject to 40CFR60 Subpart IIII? **Yes**   Certified? **No**  
Subject to 40CFR60 Subpart JJJJ? **No**

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [§§ 22B-1-1 et seq.], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

**All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class I General Permit G65-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart IIII)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

**Emission Units**

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	John Deere 5030HF285G	2013	96 bhp / 1800 rpm

**Emission Limitations**

Source ID#	Nitrogen Oxides		VOC	
	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	0.67	0.17	0.25	0.06