



west virginia department of environmental protection

Division of Air Quality
601 57th Street, SE
Charleston, WV 25304-2345
Phone: 304 926 0475 • Fax: 304 926 0479

Jim Justice, Governor
Austin Caperton, Cabinet Secretary
www.dep.wv.gov

MEMORANDUM

To: File
From: William T. Rothwell II
Date: January 4, 2018
Subject: Dominion Energy Transmission, Inc. – HG Well #5853 – Lewis County, WV
ID #: 041-00086
APP #: PD17-094

BACKGROUND INFORMATION:

Dominion Energy Transmission, Inc. is proposing the addition of a EPA certified natural gas pumpjack engine to remove fluid from the above subject gas well. The engine will be a Kohler CH740 – 20.5 BHP @ 1,800 RPM 4SRB engine that was manufactured in 2017.

The engine is a new source (constructed after June 12, 2006), located at an area source of HAPs, and is therefore subject to 40CFR63, Subpart ZZZZ (NESHAP). Due to the year of construction of the engine, it is subject to a substantive requirement of that Federal Rule in which it must comply with 40CFR60 Subpart JJJJ (NSPS) if applicable.

Since the EPA certified engine is ≤ 500 HP and was manufactured after July 1, 2008, although subject to JJJJ, it is not subject to a substantive requirement in 40CFR60 Subpart JJJJ.

The potential emissions for the engine are as follows:

Table with 3 columns: Pollutant, LB/HR, TPY. Rows include PM, VOCs, CO, NOx, HAPs.

RECOMMENDATION:

The emission rates are below the emission limits of six (6) lb/hr and ten (10) TPY; 2 lb/hr, or 5 TPY of HAPs set forth set forth in 45CSR13 - 2.17.a&b. Therefore, a permit is not required by this Division for the installation and operation of the above mentioned pumpjack engine.

Handwritten signature of William T. Rothwell II

William T. Rothwell II, P.E.
Engineer

Handwritten date: 1/4/2018

Date