



---

west virginia department of environmental protection

---

Division of Air Quality  
601 57<sup>th</sup> Street, S.E.  
Charleston, WV 25304

Jim Justice, Governor  
Austin Caperton, Cabinet Secretary  
[www.dep.wv.gov](http://www.dep.wv.gov)

July 13, 2017

Mark Fick  
MEP Engineer  
Bio-Medical Applications of WV, Inc.  
900 Circle 75 Pkwy.  
Atlanta, GA 30339

Re: Permit Applicability Determination  
FMC Clinic # 3836 Charles Town  
Jefferson County, WV  
Determination No. PD17-023  
Plant ID No. 037-00107

Dear Mr. Fick:

It has been determined that a permit will not be required for your proposed installation and operation of a diesel gas-fired auxiliary generator at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on April 7, 2017, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer