



---

**west virginia department of environmental protection**

---

Division of Air Quality  
601 57<sup>th</sup> Street SE  
Charleston, WV 25304  
Phone 304/926-0475

Earl Ray Tomblin, Governor  
Randy C. Huffman, Cabinet Secretary  
www.dep.wv.gov

November 13, 2015

CERTIFIED MAIL  
91 7199 9991 7034 1379 8198

John P. Whittington  
Executive Vice President  
3660 Grandview Parkway, Ste. 200  
Birmingham, AL 35243

RE: Approved Registration G65-C555  
WV Rehabilitation Hospital, Inc.  
HealthSouth Mountain View Regional Rehabilitation Hospital  
Plant ID No. 061-00221

Dear Mr. Whittington:

The Director has determined that the submitted Registration Application and construction and operation of an emergency generator demonstrates eligibility and compliance with the requirements, provisions, standards and conditions of General Permit G65-C and hereby grants General Permit registration authorizing the proposed activity.

Please be aware of the actions required in Section 2.18 (Notification Requirements), Section 4.2 (Recordkeeping Requirements), and Section 3.5.5 (Air Quality Management Fee Program and Certificate to Operate).

Should you have any questions, please contact the undersigned engineer at (304)926-0499 ext. 1211.

Sincerely,

William T. Rothwell II, P.E.  
Engineer

Enclosures: General Permit Registration G65-C555  
General Permit G65-C

*West Virginia Department of Environmental Protection*  
*Earl Ray Tomblin*  
*Governor*

*Division of Air Quality*

*Randy C. Huffman*  
*Cabinet Secretary*

## Class I General Permit G65-C Registration to Construct



for the  
Prevention and Control of Air Pollution in regard to the  
Construction, Modification, Relocation, Administrative Update and  
Operation of Emergency Generators

*The permittee identified at the facility listed below is authorized to  
construct the stationary sources of air pollutants identified herein in accordance  
with all terms and conditions of General Permit G65-C.*

**G65-C555**

Issued to:  
**West Virginia Rehabilitation Hospital, Inc.**  
**HealthSouth Mountain View Regional Rehabilitation Hospital**  
**061-00221**

A handwritten signature in blue ink, appearing to read "William F. Durham", written over a horizontal line.

*William F. Durham*  
*Director*

*Issued: November 13, 2015 • Effective: November 13, 2015*

Facility Location: Morgantown, Monongalia County, West Virginia  
Mailing Address: 3660 Grandview Parkway, Ste. 200, Birmingham, AL 35243  
Facility Description: Hospital  
SIC Codes: 8069  
UTM Coordinates: 589.060 km Easting • 4390.149 km Northing • Zone 17  
Registration Type: Construction  
Description of Change: Construction of an Emergency Generator

Subject to 40CFR60 Subpart IIII? Yes Certified? Yes  
Subject to 40CFR60 Subpart JJJJ? No

*Any person whose interest may be affected, including, but not necessarily limited to, the applicant and any person who participated in the public comment process, by a permit or registration issued, modified or denied by the Secretary may appeal such action of the Secretary to the Air Quality Board pursuant to article one [ §§ 22B-1-1 et seq. ], Chapter 22B of the Code of West Virginia. West Virginia Code §22-5-14.*

---

*The source is not subject to 45CSR30.*

---

**All registered facilities under Class I General Permit G65-C are subject to Sections 1.0, 2.0, 3.0, and 4.0.**

The following sections of Class I General Permit G65-C apply to the registrant:

- Section 5 Reciprocating Internal Combustion Engines (R.I.C.E.)
- Section 6 Tanks
- Section 7 Standards of Performance for Stationary Compression Ignition Internal Combustion Engines (40CFR60 Subpart III)
- Section 8 Standards of Performance for Stationary Spark Ignition Internal Combustion Engines (40CFR60 Subpart JJJJ)

**Emission Units**

Emission Unit ID	Emission Unit Description (Make, Model, Serial No.)	Year Installed	Design Capacity (Bhp/rpm)
EG-1	Volvo TWD1643GE	2015	917 bhp / 1800 rpm
TO1	Fuel Tank	2015	1,000 Gallons

**Emission Limitations**

Source ID#	Nitrogen Oxides		Carbon Monoxide	
	lb/hr	ton/yr	lb/hr	ton/yr
EG-1	10.46	2.61	0.76	0.19