



west virginia department of environmental protection

Division of Air Quality
601 57th Street, S.E.
Charleston, WV 25304

Jim Justice, Governor
Austin Caperton, Cabinet Secretary
www.dep.wv.gov

October 25, 2017

Kevin Folk
VP Wireless Network Operations
Shentel Service, LLC dba Shentel
500 Summers St.
Charleston, WV 25301

Re: Permit Applicability Determination
67186 Heath Creek
Cabell County, WV
Determination No. PD17-072
Plant ID No. 011-00221

Dear Mr. Folk:

It has been determined that a permit will not be required for your proposed installation and operation of a diesel gas-fired auxiliary generator at the above referenced facility. This determination is based on information included with your Permit Determination Form (PDF) received on October 12, 2017, which indicates that the increase in emissions will not exceed two (2) lbs/hr or five (5) tons/year of total Hazardous Air Pollutants (HAPs); six (6) lbs/hour and ten (10) TPY of any regulated pollutant; or, trigger a substantive requirement of any State or Federal air quality regulation.

Please bear in mind, however, that any additional changes to the proposed facility, may require a permit under 45CSR13. Furthermore, pursuant to 45CSR13-5.14, records briefly describing the proposed change, the pollutants involved, the potential to emit for each pollutant increased or added shall be maintained by the owner or operator for at least two years and made available to the Director upon request.

Should you have any questions, please contact the undersigned engineer at (304) 926-0499 Ext. 1211.

Sincerely,

William T. Rothwell II, P.E.
Engineer