



west virginia department of environmental protection

Division of Air Quality
601 57th Street, SE
Charleston, WV 25304-2345
Phone: 304 926 0475 • Fax: 304 926 0479

Jim Justice, Governor
Austin Caperton, Cabinet Secretary
www.dep.wv.gov

MEMORANDUM

To: Beverly McKeone
From: William T. Rothwell II
Date: October 25, 2017
Subject: Shentel Service, LLC dba Shentel – 68055 Oak Hill – Fayette County, WV
ID #: 019-00120
APP #: PD17-075

BACKGROUND INFORMATION:

Shentel Service, LLC is proposing to install a diesel-fired auxiliary generator set at their above subject facility. The EPA Certified 20 KW Cummins Model C20 D6 generator set utilizes a 36 hp engine that was manufactured in 2015.

The engine is considered a new engine (constructed after June 12, 2006), located at an area source of HAPs, and is therefore subject to 40CFR63, Subpart ZZZZ (NESHAP). Due to the size of the engine, it is not subject to a substantive requirement of that Federal Rule, but it must comply with 40CFR60 Subpart IIII (NSPS) if applicable.

Since the certified engine is ≤ 500 HP and was manufactured after April 1, 2006, although subject to IIII, it is not subject to a substantive requirement in 40CFR60 Subpart IIII. The subject engine is Tier 4i compliant and complies with USEPA regulations under 40CFR89 Tier 4i emissions limits when tested per ISO 8178 D2.

The potential emissions (based on 500 hours/year) for the engine are as follows:

Table with 3 columns: Pollutant, LB/HR, TPY. Rows include PM, VOCs, CO, and NOx.

RECOMMENDATION:

The emission rates are below the emission limits of six (6) lb/hr and ten (10) TPY; 2 lb/hr, or 5 TPY of HAPs set forth set forth in 45CSR13 - 2.17.a&b. Therefore, a permit is not required by this Division for the installation and operation of the above mentioned auxiliary generator.

Signature of William T. Rothwell II, P.E.
Engineer

10/25/2017
Date