

Modi, Beena J <beena.j.modi@wv.gov>

RE: [EXTERNAL] R30-09900118-2020(SM01)

1 message

Adams, Tina N. <TAdams3@marathonpetroleum.com> To: "Modi, Beena J" <beena.j.modi@wv.gov>

Tue, Dec 7, 2021 at 12:52 PM

Yes, that is what I want to confirm that Section 5.3.1 does not make testing mandatory as long as we follow the other requirements. I have no other comments.

Thanks,

Tina

From: Modi, Beena J <beena.j.modi@wv.gov> Sent: Tuesday, December 7, 2021 12:48 PM

To: Adams, Tina N. <TAdams3@marathonpetroleum.com> Subject: Re: [EXTERNAL] R30-09900118-2020(SM01)

Are you referring to the testing in condition 5.3.1? If so, testing is required according to condition 5.1.6 which says if you do not install and configure the engine and control device according to the manufacturer's emission-related written instruction, or you change the emission-related settings in a way that is not permitted by the manufacturer, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year.

So, if you operate the certified engine according to the manufacturer's instructions and do not change the settings, you will not have to test.

On Tue, Dec 7, 2021 at 10:08 AM Adams, Tina N. <TAdams3@marathonpetroleum.com> wrote:

Hello Beena,

Thank you for the draft Title V revision for the Propane Cavern for review. I would like to verify that the information provided under the Testing section is only there if performance tests in-use are conducted and not a requirement to conduct performance tests.

Tina

Beena Modi

From: Modi, Beena J <beena.j.modi@wv.gov> Sent: Friday, December 3, 2021 8:26 AM To: Adams, Tina N. <TAdams3@marathonpetroleum.com> Subject: [EXTERNAL] R30-09900118-2020(SM01) Hi Tina, Please review the attached documents and let me know your comments by Dec 9th. Thanks,



Modi, Beena J <beena.j.modi@wv.gov>

Re: [EXTERNAL] R30-09900118-2020(SM01)

1 message

McCumbers, Carrie <carrie.mccumbers@wv.gov>
To: "Modi, Beena J" <beena.j.modi@wv.gov>

Tue, Dec 7, 2021 at 10:53 AM

Beena,

Is she referring to the testing in condition 5.3.1? If so, testing is required according to condition 5.1.6 which says if you do not install and configure the engine and control device according to the manufacturer's emission-related written instruction, or you change the emission-related settings in a way that is not permitted by the manufacturer, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year. So, if they operate the certified engine according to the manufacturer's instructions and do not change the settings, they will not have to test.

Thanks, Carrie

On Tue, Dec 7, 2021 at 10:09 AM Modi, Beena J

beena.j.modi@wv.gov wrote:

----- Forwarded message -----

From: Adams, Tina N. <TAdams3@marathonpetroleum.com>

Date: Tue, Dec 7, 2021 at 10:08 AM

Subject: RE: [EXTERNAL] R30-09900118-2020(SM01)

To: Modi, Beena J <beena.j.modi@wv.gov>

Cc: Ewing, Bill <wjewing@marathonpetroleum.com>

Hello Beena,

Thank you for the draft Title V revision for the Propane Cavern for review. I would like to verify that the information provided under the Testing section is only there if performance tests in-use are conducted and not a requirement to conduct performance tests.

Tína

From: Modi, Beena J <beena.j.modi@wv.gov> Sent: Friday, December 3, 2021 8:26 AM

To: Adams, Tina N. <TAdams3@marathonpetroleum.com>

Subject: [EXTERNAL] R30-09900118-2020(SM01)

Hi Tina,

Please review the attached documents and let me know your comments by Dec 9th.

Thanks,

Beena Modi



Modi, Beena J <beena.j.modi@wv.gov>

RE: [EXTERNAL] R30-09900118-2020(SM01)

1 message

Thu, Nov 18, 2021 at 1:14 PM

The fire pump is less than 30 l/cyl (4.5 l/cyl).

Thanks,

Tina

From: Modi, Beena J <beena.j.modi@wv.gov> Sent: Thursday, November 18, 2021 12:49 PM

To: Adams, Tina N. <TAdams3@marathonpetroleum.com> **Subject:** [EXTERNAL] R30-09900118-2020(SM01)

Hi Tina,


A 95HP diesel fired emergency use fire pump manufactured in June 2016 was installed at the Cavern in October 2016. The engine is subject to 40 CFR 63 Subpart ZZZZ "National Emission Standards for Hazardous Air Pollutants (HAP) for Stationary Reciprocating Internal Combustion Engines (ICE)" due to its potential HAP emissions and 40 CFR 60 Subpart IIII "Standards of Performance for Stationary Compression Ignition ICE" due to the year of construction. 40 CFR 63.6590(c)(6) provides that compliance with Subpart ZZZZ for new emergency engines will meet by complying with Subpart IIII with no further requirements under Subpart ZZZZ. On September 20, 2016, MPC received a determination (PD16-044) from DAQ that a permit under 45CSR13 was not required for installation and operation of the fire pump engine at the Cavern.

Is this fire pump ≥30 I/cyl?

Can you let me know which Engine category you follow?

Thanks,

Beena Modi





Modi, Beena J <beena.j.modi@wv.gov>

Completeness Determination, R30-09900118-2020

1 message

Modi, Beena J <beena.j.modi@wv.gov>

Mon, Oct 4, 2021 at 5:43 PM

To: jmrichert@marathonpetroleum.com, tadams3@marathonpetroleum.com

Your Title V application for a significant permit modification of the above referenced facility was received by this Division on September 30, 2021. After review of said application, it has been determined that the application is administratively complete as submitted.

The applicant has the duty to supplement or correct the application. An applicant who fails to submit any relevant facts or who has submitted incorrect information in any permit application shall, upon becoming aware of such failure or incorrect submittal, promptly submit such supplementary facts or corrected information. In addition, an applicant shall provide additional information as necessary to address any requirements that become applicable to the source after the date it filed a complete application but prior to release of a draft permit modification.

The submittal of a complete application shall not affect the requirement that any source have all **preconstruction permits** required under the rules of the Division.

If during the processing of this application it is determined that additional information is necessary to evaluate or take final action on this application, a request for such information will be made in writing with a reasonable deadline for a response. The source's ability to operate without a Title V permit modification in accordance with 45CSR§30-4.1.a.2. (if applicable), shall be in effect from the date of startup of the proposed changes until the final permit modification is issued, provided that the applicant submits any requested additional information by the deadline specified. This protection shall cease to apply if, subsequent to the completeness determination made pursuant to paragraph 6.1.d of 45CSR30 and as required by paragraph 4.1.b, the applicant fails to submit any additional information identified as being needed to process the application by the deadline specified in writing.

Please remember, failure of the applicant to timely submit information required or requested to process the application may cause the Application Shield (if applicable) to be revoked. Should you have any questions regarding this determination, please contact me.

Sincerely,
Beena Modi
Title V Permit Engineer
Beena.j.modi@wv.gov



Received
September 30, 2021
WV DEP/Div of Air Quality

Catlettsburg Refining, LLC

A subsidiary of Marathon Petroleum Company LP

11631 U.S. Route 23 P.O. Box 1492 Catlettsburg, KY 41129 Tel: 606 921 6200

Tel: 606.921.6200 Fax: 606.921.3500

September 30, 2021

Director West Virginia Department of Environmental Protection Division of Air Quality 601 57th Street, SE Charleston, WV 25304

ELECTRONIC SUBMITTAL - DEPAirQualityReports@wv.gov

RE: Marathon Petroleum Company, LP; Neal Propane Cavern

Permit No. R30-09900118-2020 Significant Revision Application

Dear Director:

Marathon Petroleum Company LP (MPC) owns and operates a propane storage cavern (Cavern) in Neal, West Virginia. The facility currently operates in accordance with West Virginia Department of Environmental Protection (WVDEP) Division of Air Quality (DAQ) Title V Operating Permit R30-09900118-2020, issued January 2, 2020.

A 95HP diesel fired emergency use fire pump manufactured in June 2016 was installed at the Cavern in October 2016. The engine is subject to 40 CFR 63 Subpart ZZZZ "National Emission Standards for Hazardous Air Pollutants (HAP) for Stationary Reciprocating Internal Combustion Engines (ICE)" due to its potential HAP emissions and 40 CFR 60 Subpart III "Standards of Performance for Stationary Compression Ignition ICE" due to the year of construction. 40 CFR 63.6590(c)(6) provides that compliance with Subpart ZZZZ for new emergency engines will meet by complying with Subpart IIII with no further requirements under Subpart ZZZZ. On September 20, 2016, MPC received a determination (PD16-044) from DAQ that a permit under 45CSR13 was not required for installation and operation of the fire pump engine at the Cavern.

DAQ considers the Cavern, MPLX Terminal and Storages LLC's Butane Cavern in Kenova, WV, and Catlettsburg Refining, LLC's Catlettsburg Refinery in Catlettsburg, KY to be a single source for Clean Air Act permitting purposes and considers the Cavern to be a major source of HAPs requiring an operating permit pursuant to Title V of the Federal Clean Air Act as amended and 45CSR30. It has come to our attention that while a permit was not required under 45CSR13 to construct the engine, the facility's Title V permit required a modification under 45CSR30. Because the engine triggers 40 CFR Part 60 regulations, DAQ considers the Title V modification to be classified as a significant modification. Please find attached the significant modification application to incorporate the engine and regulatory requirements of Subpart IIII into the Cavern's Title V permit.

Note the following attachments listed in Section 6 of the application form are not applicable to this modification and are not included.

- Attachment A Business Confidentiality Claims
- Attachment F Schedule of Compliance Form(s)
- Attachment G Air Pollution Control Device Form(s)
- Attachment H Compliance Assurance Monitoring Form(s)

If upon your review, you determine that any additional information is needed or if you have any questions regarding the planned changes, please contact Tina Adams at 606-921-3389 or TAdams3@marathonpetroleum.com.

Respectfully,

Jay M. Richert

Deputy Assistant Secretary

Attachments tna/wje/gdn tna wje 1991

WEST VIRGINIA DEPARTMENT OF

ENVIRONMENTAL PROTECTION

DIVISION OF AIR QUALITY

601 57th Street, SE Charleston, WV 25304 (304) 926-0475

www.dep.wv.gov/daq

Received
September 30, 2021
WV DEP/Div of Air Quality

TITLE V PERMIT REVISION APPLICATION			
PLEASE CHECK TYPE OF TITLE V PERMIT REVISION:	TITLE V PERMIT NUMBER:		
☐ ADMINISTRATIVE AMENDMENT	R30 - 09900118-2020		
☐ MINOR MODIFICATION ☐SIGNIFICANT MODIFICATION	WHEN DID OR WHEN WILL THE CHANGES OCCUR?		
☐ OFF-PERMIT CHANGE ☐ OPERATIONAL FLEXIBILITY [502(B)(10) CHANGES]	MM/DD/YYYY: October 2016		
REOPENING	SIC CODES: PRIMARY: 4247 SECONDARY: 2911		
Refer to "Title V Revision Guidance" (Appendix A, "Title V Permit Revision Flowchart"), for type of revision,			
and to Section 7 of this Application, for Application Completeness and Ability to Operate information			

Section 1: General Information

a. Name of Applicant (As registered with the WV Secretary of State's Office):	b. Facility Name or Location:
Marathon Petroleum Company, LP By: MPC Investment, LLC, general partner	Neal Propane Cavern

b. Contact Information		
Responsible Official: Jay M. Richert		Title: Deputy Assistant Secretary
Street or P.O. Box: P. O. Box 1492		
City: Catlettsburg	State: KY	Zip: 41129
Telephone Number: (606) 921 - 6200	Fax Number: (606) 921 - 3500	E-mail: jmrichert@marathonpetroleum.com
Environmental Contact: Tina N. Adams, PE		Title: Advanced HES Professional
Street or P.O. Box: P. O. Box 1492		
City: Catlettsburg	State: KY	Zip: 41129
Telephone Number: (606) 921 - 3389	Fax Number: (606) 921 - 6921	E-mail: tadams3@marathonpetroleum.com
Application Preparer: Same as Environmental Contact		Title:
Company:		
Street or P.O. Box:		
City:	State:	Zip:
Telephone Number: () -	Fax Number: () -	E-mail:
Person to contact if we have questions regarding	g this Application: Tina N. Ad	ams
All of the required forms and additional information can	be found under the Permitting Section	on of DAQ's website, or requested by phone.

f	7
۱)ť

Section 2: Revision Information

a. Description of Changes Associated with this Permit Revision
Provide a general description of changes to the facility.
Addition of a 95HP stationary diesel fueled engine to power a firewater pump
b. Business Confidentiality Claims
Does this application include confidential information (per 45CSR31)?
If Yes, identify each segment of information on each page that is submitted as confidential, and provide justification for each segment claimed confidential, including the criteria under 45CSR§31-4.1, and in accordance with the DAQ's "PRECAUTIONARY NOTICE-CLAIMS OF CONFIDENTIALITY" guidance as ATTACHMENT A.
c. Provide a Plot Plan(s) if new emission points were added since latest revision, e.g. scaled map(s) and/or sketch(es) showing the location of the property on which the new/modified stationary source(s) is located as ATTACHMENT B. For instructions, refer to " Plot Plan - Guidelines ".
d. Provide a detailed Process Flow Diagram(s) if new emission points were added since latest revision, showing each new/modified process or emissions unit as ATTACHMENT C. Process Flow Diagrams should show all emission units, control equipment, emission points, and their relationships.
e. Emission Units Table
Fill out the Emission Units Table for new and/or modified equipment and provide it as ATTACHMENT D .
f. Emission Units Form(s)
For each new and/or modified emission unit(s) with applicable requirement(s) listed in the Emission Units Table , fill out and provide an Emission Unit Form(s) as ATTACHMENT E .
. no , ou m compinmed un mem, uppneudle legunomem.
For each new and/or modified emission unit not in compliance with an applicable requirement, fill out a Schedule of Compliance Form as ATTACHMENT F .
g. Control Devices
For each new and/or modified control device listed in the Emission Units Table, fill out and
provide an Air Pollution Control Device Form(s) as ATTACHMENT G.
For any control device that is required on an emission unit in order to meet a standard or limitation for which the potential pre-control device emissions of an applicable regulated air pollutant is greater than or equal to the Part 70 Major Source Threshold level, refer to the Compliance Assurance Monitoring (CAM) Form(s) for CAM applicability. If applicable, please check appropriate box in Section 3(a) below, fill out and provide these forms for each Pollutant Specific Emission Unit (PSEU) as ATTACHMENT H .
All of the required forms and additional information can be found under the Permitting Section of DAQ 's website, or requested by phone.

Section 3: New Applicable Requirements

Pr			
a. New Applicable Requirements Summary			
Mark all applicable requirements associated with the changes involved with this permit revision:			
□ SIP	☐ FIP		
☐ Minor source NSR (45CSR13)	☐ PSD (45CSR14)		
☐ NESHAP (45CSR34)	☐ Nonattainment NSR (45CSR19)		
Section 111 NSPS (Subpart(s) IIII)	Section 112(d) MACT standards (Subpart(s)_ZZZZ)		
Section 112(g) Case-by-case MACT	☐ 112(r) RMP		
Section 112(i) Early reduction of HAP	Consumer/commercial prod. reqts., section 183(e)		
☐ Section 129 Standards/Reqts.	Stratospheric ozone (Title VI)		
☐ Tank vessel reqt., section 183(f)	☐ Emissions cap 45CSR§30-2.6.1		
☐ NAAQS, increments or visibility (temp. sources)	☐ 45CSR27 State enforceable only rule		
45CSR4 State enforceable only rule	☐ Acid Rain (Title IV, 45CSR33)		
☐ Emissions Trading and Banking (45CSR28)	☐ Compliance Assurance Monitoring (40CFR64)		
☐ CAIR NO _x Annual Trading Program (45CSR39)	☐ CAIR NO _x Ozone Season Trading Program (45CSR26)		
☐ CAIR SO ₂ Trading Program (45CSR41)			
<u>'</u>			
b. Non Applicability Determinations			
List all requirements, which the source has determined not applicable to this permit revision and for which apermit shield is requested. The listing shall also include the rule citation and a rationale for the determination. 45CSR7-To Prevent and Control Particulate Matter Air Pollution from Manufacturing Processes and Associated Operations: This rule does not apply since this facility does not emit smoke, particulate matter, or other gaseous matter. Also, this facility does not meet the definition of a manufacturing process in 45CSR7-2.20.			
45CSR21-To Prevent and Control Air Pollution from the Emission of Volatile Organic Compounds: The only potentially applicable sections of this regulation are 45CSR§21-26 for Leaks from Petroleum Refinery Equipment and 45CSR§21-40 for Other Facilities that Emit Volatile Organic Compounds. The propane cavern does not meet the definition of a petroleum refinery in 45CSR§21-2.55, since this facility is not engaged in producing gasoline, kerosene, distillate fuel oils, residual fuel oils, lubricants, or other products through distillation of petroleum or through the redistillation, cracking, or reforming of unfinished petroleum derivatives; so 45CSR§21-26 does not apply. The propane cavern's aggregate maximum theoretical VOC emissions are below 100 TPY, so 45CSR§21-40 does not apply.			
45CSR27-To Prevent and Control the Emissions of Toxic Air Pollutants: This facility does not meet the definition of "chemical processing unit" in 45CSR§27-2.4 since the propane stored in the cavern is below 5% benzene by weight, thus this rule does not apply.			
40 CFR 64-Compliance Assurance Monitoring: This facility does not have any pollutant-specific emission			

units that satisfy the requirements of 40CFR§64.2(a), thus CAM does not apply.

\boxtimes	Permit Shield Requested (not applicable to Minor Modifications,	Off-Permit Changes, or for
Ope	ational Flexibility)	

All of the required forms and additional information can be found under the Permitting Section of DAQ's website, or requested by phone.

c. Suggested Title V Draft Permit Language

Provide Suggested Title V Draft Permit language for the proposed Title V Permit revision (including all applicable requirements associated with the permit revision and any associated monitoring /recordkeeping/ reporting requirements), OR attach a marked up pages of current Title V Permit as ATTACHMENT I. Please include appropriate citations (Permit or Consent Order number, condition number and/or rule citation (e. g. 45CSR§7-4.1)) for those requirements being added / revised.

See Attachment I

d. Active NSR Permits/Permit Determinations/Consent Orders Associated With This Permit Revision			
Permit or Consent Order Number	Date of Issuance (MM/DD/YYYY)	Permit/Consent Order Condition Number	
None			

e. Inactive NSR Permits/Obsolete Permit or Consent Orders Conditions Associated With This Revision			
Permit Number	Date of Issuance (MM/DD/YYYY)	Permit/Consent Order Condition Number	
None			

Section 4: Change in Potential Emissions

Pollutant	Change in Potential Emissions (+ or -), TPY	For Off-Permit Changes: Provide Total Aggregated Emissions Increase Since Last Permit/Modification
VOC	0.06	
NOx	2.33	
СО	0.64	
PM	0.08	
SO2	0.85	

Provide Supporting Emission Calculations/Estimations as ATTACHMENT J.

All of the required forms and additional information can be found under the Permitting Section of DAQ's website, or requested by phone.

Section 5: Certification of Information

a. Certification For Use Of Minor Modification Procedures (Required Only for Minor Modification Requests) NA			
certi	certification must be signed by a responsibl fication will be returned as incomplete. The ification Procedures are as follows:		
 i. Proposed changes do not violate any applicable requirement; ii. Proposed changes do not involve significant changes to existing monitoring, reporting, or recordkeeping requirements in the permit; iii. Proposed changes do not require or change a case-by-case determination of an emission limitation or other standard, or a source-specific determination for temporary sources of ambient air quality impacts, or a visibility increment analysis; iv. Proposed changes do not seek to establish or change a permit term or condition for which there is no underlying applicable requirement and which permit or condition has been used to avoid an applicable requirement to which the source would otherwise be subject (synthetic minor). Such terms and conditions include, but are not limited to a federally enforceable emissions cap used to avoid classification as a modification under any provision of Title I or any alternative emissions limit approved pursuant to regulations promulgated under § 112(j)(5) of the Clean Air Act; v. Proposed changes do not involve preconstruction review under Title I of the Clean Air Act or 45CSR14 and 45CSR19; vi. Proposed changes are not required under any rule of the Director to be processed as a significant modification; Notwithstanding subparagraph 45CSR§30-6.5.a.1.A. (items i through vi above), minor permit modification procedures may be used for permit modifications involving the use of economic incentives, marketable permits, emissions trading, and other similar approaches, to the extent that such minor permit modification procedures are explicitly provided for in rules of the Director which are approved by the U.S. EPA as a part of the State Implementation Plan under the Clean Air Act, or which may be otherwise provided for in the Title V 			
Pursuant to 45CSR§30-6.5.a.2.C., the proposed modification contained herein meets the criteria for use of Minor permit modification procedures as set forth in Section 45CSR§30-6.5.a.1.A. The use of Minor permit modification procedures are hereby requested for processing of this application.			
(Signed): Named (typed):	NA (Please use blue ink)	Date: / / / (Please use blue ink) Title:	

	ertification of Truth, Accuracy and Completeness and Cer Required For All Revision Requests)	rtification of Compl	iance					
Note	This Certification must be signed by a responsible official. Applications without a signed certification will be returned as incomplete.							
Certification of Truth, Accuracy and Completeness								
this attac state indiv infor sign	cify that I am a responsible official (as defined at 45CSR§30-25 submission on behalf of the owners or operators of the himents. I certify under penalty of law that I have person ments and information submitted in this document and all its iduals with primary responsibility for obtaining the information are to the best of my knowledge and belief true, accurate ficant penalties for submitting false statements and information, including the possibility of fine and/or imprisonment.	source described in hally examined and a attachments. Based rmation, I certify the rate, and complete. I hation or omitting re-	this document and its am familiar with the on my inquiry of those nat the statements and am aware that there are					
Con	pliance Certification							
Except for requirements identified in the Title V Application for which compliance is not achieved, I, the undersigned hereby certify that, based on information and belief formed after reasonable inquiry, all air contaminant sources identified in this application are in compliance with all applicable requirements.								
Res	onsible official (type or print)	1						
Nam	e: Jay M. Richert	Title: Deputy	Assistant Secretary					
_	onsible official's signature: ature: Please use blue ink)	Signature Date: 9/	30/21					
Note: P	ease check all applicable attachments included with this p	ermit application:	Received September 30,					
NA	ATTACHMENT A: Business Confidentiality Claims		WV DEP/Div of Ai	r Quality				
V	ATTACHMENT B: Plot Plan(s)							
	ATTACHMENT C: Process Flow Diagram(s)							
<u>'</u>	ATTACHMENT D: Emission Units Table							
~	ATTACHMENT E: Emission Unit Form(s)							
NA	ATTACHMENT F: Schedule of Compliance Form(s)							
NA NA	ATTACHMENT G: Air Pollution Control Device Form(s)							
NA	ATTACHMENT H: Compliance Assurance Monitoring Form(s)							
~	ATTACHMENT I: Suggested Title V Draft Permit Language	2						
<u>,</u>	ATTACHMENT J: Supporting Emission Calculations/Estim	ations						
All of the	required forms and additional information can be found under the Permitti	ng Section of DAQ's webs	ite, or requested by phone.					

Section 7: Application Completeness and Ability to Operate information for different types of Title V Permit revisions

(Refer to "Title V Revision Guidance" for more information)


Type of Revision	Application/Notification Requirements	Ability to Operate
Administrative Amendment	☐ Description of change ☐ Supplemental information (rationale) ☐ Certification of application and compliance (Section 5(b))	Upon submittal of the application
Minor Modification	☐ Description of change ☐ Associated change in emissions ☐ Sample Calculations/estimations for determining emissions ☐ List of new applicable requirements associated with changes ☐ List of R13/R14 permits associated with the changes ☐ Suggested draft permit language ☐ Certification for use of Minor Modification (Section 5(a)) ☐ Certification of application and compliance (Section 5(b)) No Permit Shield	After seven (7) days from the submittal of the application, or upon issuance of the R13/R14 permit (if any), whichever is later
Significant Modification	 ✓ Description of change ✓ Associated change in emissions ✓ Sample Calculations/estimations for determining emissions ✓ List of R13/R14 permits associated with the changes ✓ List of new applicable requirements associated with changes ✓ Request for permit shield ✓ Updated drawings, plot plans, process flow diagrams, etc. ✓ Certification of application and compliance (Section 5(b)) 	Upon issuance of the modified Title V permit (if changes either conflict with, or are prohibited by existing Title V Permit terms/ conditions), OR upon obtaining of proper R13/R14 Permit for first 12 months (if changes neither conflict with, nor are prohibited by existing Title V Permit terms/conditions)
Off-Permit Changes	 Notification/application to DAQ and U.S.E.P.A. within 2 business days of the change □ Description of the change □ The date on which the change will occur or has occurred □ Pollutants and amounts emitted □ Sample Calculations/estimations for determining emissions □ Any new applicable requirements that will apply to changes □ Certification of application and compliance (Section 5(b)) No Permit Shield 	After two (2) days from the submittal of the application
Operational Flexibility	 Notification/application submitted to DAQ and U.S.E.P.A. in advance (7 days prior to making changes) □ Description of the change □ The date on which the change is to occur □ Permit terms and conditions affected by the change □ Certification of application and compliance (Section 5(b)) No Permit Shield 	After seven (7) days from the submittal of the application/notification to DAQ and EPA
Reopening	 □ Description of change □ List of new applicable requirements associated with changes □ Suggested draft permit language □ Certification of application and compliance (Section 5(b)) 	Ability to operate is not reflected by the changes

All of the required forms and additional information can be found under the Permitting Section of DAQ's website, or requested by phone.

ATTACHMENT B PLOT PLAN



Attachment C: Propane Cavern Process Flow Diagram



ATTACHMENT D - Title V Equipment Table

(includes all emission units at the facility except those designated as insignificant activities in Section 4, Item 24 of the General Forms)

Emission Point ID ¹	Control Device ¹	Emission Unit ID ¹	Emission Unit Description	Design Capacity	Year Installed/ Modified

¹For 45CSR13 permitted sources, the numbering system used for the emission points, control devices, and emission units should be consistent with the numbering system used in the 45CSR13 permit. For grandfathered sources, the numbering system should be consistent with registrations or emissions inventory previously submitted to DAQ. For emission points, control devices, and emissions units which have not been previously labeled, use the following 45CSR13 numbering system: 1S, 2S, 3S,... or other appropriate description for emission units; 1C, 2C, 3C,... or other appropriate designation for control devices; 1E, 2E, 3E, ... or other appropriate designation for emission points.

	Title V Equipment Table (equipment_table.doc)
	Page 1 of 1
Page of	Revised 4/11/05

ATTACHMENT E - Emission Unit Form							
Emission Unit Description							
Emission unit ID number: 2S	Emission unit name: Firewater Pump Diesel Engine	List any control devices associated with this emission unit:					
Provide a description of the emission under the Base Cummins 170 HP diesel engine	derated to 95HP by Cummins Fire		ne control module				
for emergency firefighting certified t	o NFPA requirements.						
Manufacturer: Cummins Firepower	Model number: CFP5E-F10	Serial number: 74000793					
Construction date: (MM/DD/YYYY) June 2016 Installation date: (MM/DD/YYYY) October 2016 NA Modification date(s): (MM/DD/YYYY)							
Design Capacity (examples: furnaces - 95 HP (71 KW)	tons/hr, tanks - gallons):						
Maximum Hourly Throughput: 5.1 gallons	Maximum Annual Throughput: 44,600 gallons	Maximum Operating Schedule: 8760					
Fuel Usage Data (fill out all applicat	ole fields)						
Does this emission unit combust fuel?	X_Yes No	If yes, is it? Indirect Fired	_X Direct Fired				
Maximum design heat input and/or ma	Type and Btu/hr rati	ng of burners:					
List the primary fuel type(s) and if app maximum hourly and annual fuel usag	• • • • • • • • • • • • • • • • • • • •	r each fuel type listed	, provide the				
Describe each fuel expected to be used	during the term of the permit.						
Fuel Type	Max. Sulfur Content	Max. Ash Content	BTU Value				
Diesel (#2 Fuel Oil)	15 ppm		138,700 BTU/gal				

Emissions Data			
Criteria Pollutants	Potentia	l Emissions	
	PPH	TPY	
Carbon Monoxide (CO)	0.15	0.64	
Nitrogen Oxides (NOx)	0.53	2.33	
Lead (Pb)	0	0	
Particulate Matter (PM _{2.5})	0.02	0.08	
Particulate Matter (PM ₁₀)	0.02	0.08	
Total Particulate Matter (TSP)	0.02	0.08	
Sulfur Dioxide (SO ₂)	0.19	0.85	
Volatile Organic Compounds (VOC)	0.01	0.06	
Hazardous Air Pollutants	Potential Emissions		
	PPH	TPY	
Benzene	6.59 E-04	2.89 E-03	
Toluene	2.89 E-04	1.27 E-03	
Xylenes	2.01 E-04	8.83 E-04	
1,3 Butadiene	2.76 E-05	1.21 E-04	
Formaldehyde	8.33 E-04	3.66 E-03	
Acetaldehyde	5.48 E-04	2.40 E-03	
Acrolein	6.53 E-05	2.87 E-04	
Naphthalene	5.99 E-05	2.63 E-04	
PAH (excluding Naphthalene)	5.88 E-05	2.58 E-04	
Regulated Pollutants other than	Potentia	1 Emissions	
Criteria and HAP	РРН	TPY	

List the method(s) used to calculate the potential emissions (include dates of any stack tests conducted, versions of software used, source and dates of emission factors, etc.).

Emission Factors derived from:

- Cummins Fire Power ULSD EPA Tier 3 Emission Data (June 2014)
- AP-42 Stationary Internal Combustion Sources: Table 3.3-1 Emission Factors for Uncontrolled Gasoline and Diesel Industrial Engines (10/96)
- AP-42 Stationary Internal Combustions Sources: Table 3.3-2 Speciated Organic Compound Emission Factors for Uncontrolled Diesel Engines (10/96)

Applicable Requirements

List all applicable requirements for this emission unit. For each applicable requirement, include the underlying rule/regulation citation and/or construction permit with the condition number. (*Note: Title V permit condition numbers alone are not the underlying applicable requirements*). If an emission limit is calculated based on the type of source and design capacity or if a standard is based on a design parameter, this information should also be included.

- 40 CFR 60.4211(a) Operate according to manufacturer's instructions and meet 40 CFR Part 1068
- 40 CFR 60.4202(d) Emission Limits (Table 4, 95 HP, model year 2016)
- 40 CFR 60.4211(c) Purchase an engine certified to the emission standards
- 40 CFR 60.4207(b) Use diesel fuel that meets the requirements of 40 CFR 1090.305
- 40 CFR 60.4211(f) Limits on operational hours to maintain emergency use status
- 40 CFR 60.4211(g)(2) Requirements for maintenance plans
- 40 CFR 60.4209(a) Requirements for installing a non-resettable hour meter
- 40 CFR 60.7214(b) Requirements for recording operational hours

_X _ Permit Shield

For all applicable requirements listed above, provide monitoring/testing/recordkeeping/reporting which shallbe used to demonstrate compliance. If the method is based on a permit or rule, include the condition number or citation. (Note: Each requirement listed above must have an associated method of demonstrating compliance. If there is not already a required method in place, then a method must be proposed.)

40 CFR 60.4211(a) -Recordkeeping of manufacturer's instructions and maintenance
40 CFR 60.4202(d) - Recordkeeping of manufacturer's certification
40 CFR 60.4211(c) - Recordkeeping of manufacturer's certification
40 CFR 60.4207(b) - Recordkeeping of supplier's fuel certification
40 CFR 60.4211(f) - Recordkeeping of operational hours and reason for use
40 CFR 60.4211(g)(2) - Maintenance records
40 CFR 60.4219(a) - Recordkeeping of manufacturer's certification
40 CFR 60.4214(b) - Recordkeeping of manufacturer's certification
40 CFR 60.4214(b) - Recordkeeping of manufacturer's certification

If no, complete the Schedule of Compliance Form as ATTACHMENT F.

ENGINE PERFORMANCE & CONSTRUCTION






Engine Specification Sheet Cummins Fire Power De Pere, WI 54115

http://www.cumminsfirepower.com

Basic Engine Model CFP5E-F10 F20, F30, F40, F50

Curve Number: FR - 91601
Revision Date: June 2014



		Оре	rat	ing	Spo	eed	(RF	PM)	130 440			
Model	14	170	17	760	19	900	2	100	23	350	26	00
CFP5E-F50	113	(84)	129	(96)	135	(101)	146	(109)	150	(112)	148	(110)
CFP5E-F40	113	(84)	123	(92)	129	(96)	136	(101)	143	(107)	141	(105)
CFP5E-F30	104	(78)	118	(88)	121	(90)	125	(93)	130	(97)	129	(96)
CFP5E-F20	94	(70)	107	(80)	110	(82)	113	(84)	118	(88)	117	(87)
CFP5E-F10	84	(63)	95	(71)	98	(73)	101	(75)	105	(78)	104	(78)
Ratings are: HP (kW)												

Specifications						
Aspiration	Turbocharged and Charge Air (Cooled				
Rotation	Counterclockwise from flywhe	el end				
Weight - Ib (kg) Est	1340	(603)				
Displacement - in ³ (liter)	272	(4.5)				
Engine Type						
Engine Series	Cummins QSB4.5	Series				
Exhaust Emissions	EPA/CARB	Tier 3				


Equipment	Standard	Optional
Air Cleaner	Disposable, Treated for High	Heavy Duty, 2 stage with
	Humidity, Indoor Service	replaceable elements.
Alternator	12V-DC, 95 AMPS; With Belt	24V-DC, 45 AMPS; With Belt
Alternator	Guard	24V-DC, 45 AMPS, WITH BEIT Guard
Cooling Loop	3/4" diameter for Fresh Water.	Cu Ni Construction available
(Maximum Pressure of 350	With alarm sensors and FM	for Sea Water applicants
PSI)	Approval.	
Exhaust Protection	Metal Guards on Manifolds and	N/A
	Turbo	
Exhaust Flex	SS Flex, NPT	SS Flex, 150# Flange
Connection		
Flywheel Power	Flywheel	Drive Shaft System
Take-Off		
Fuel Connections	Fire Resistant Flexible Supply	N/A
	and Return Lines	CONTRACTOR (
Fuel Injection	Electronic, Direct Injection, High	N/A
System	Pressure Common Rail	
Fuel Filter	Primary and Secondary	N/A
Engine Heater	120V-AC, 1500 Watts	240V-AC, 1500 Watts
Governor, Speed	Constant Speed	N/A
Heat Exchanger	Tube & Shell Type, 60 PSI with	N/A
I I I I I I I I I I	NPTF Connections	147.1
Instrument Panel	Digital, NEMA 4X, English and	Optional 316SS
	Metric, Tachometer, Hourmeter,	Construction, Custom
	Water Temperature, Oil	gauges with expansion
	Pressure & Two (2) Voltmeters	module
Junction Box	Integral with Instrument Panel;	N/A
Sunction Box	For DC Wiring to Engine	INA
	Controller	
1		
Lube Oil Cooler	Engine Water Cooled, Plate	N/A
	Туре	
Lube Oil Filter	Full Flow with By-Pass Valve	N/A
Lube Oil Pump	Gear Driven	
	Geal Dilveil	N/A
		N/A N/A
Manual Start	On Instrument Panel	N/A
Manual Start Overspeed	On Instrument Panel Electronic with Reset & Test on	
Manual Start Overspeed Controls	On Instrument Panel Electronic with Reset & Test on Instrument Panel	N/A N/A
Manual Start Overspeed Controls Raw Water	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine	N/A
Manual Start Overspeed Controls Raw Water	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine Controller & from Emergency	N/A N/A
Manual Start Overspeed Controls Raw Water	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine	N/A N/A
Manual Start Overspeed Controls Raw Water Solenoid Operation	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine Controller & from Emergency Local Control	N/A N/A
Manual Start Overspeed Controls Raw Water	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine Controller & from Emergency	N/A N/A
Manual Start Overspeed Controls Raw Water Solenoid Operation Run-Stop Control	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine Controller & from Emergency Local Control On Instrument Panel	N/A N/A N/A
Manual Start Overspeed Controls Raw Water Solenoid Operation Run-Stop Control Run Solenoid	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine Controller & from Emergency Local Control On Instrument Panel	N/A N/A N/A N/A 24V-DC
Manual Start Overspeed Controls Raw Water Solenoid Operation Run-Stop Control Run Solenoid Starters	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine Controller & from Emergency Local Control On Instrument Panel	N/A N/A N/A N/A 24V-DC 24V-DC
Manual Start Overspeed Controls Raw Water Solenoid Operation Run-Stop Control Run Solenoid	On Instrument Panel Electronic with Reset & Test on Instrument Panel Automatic from Engine Controller & from Emergency Local Control On Instrument Panel	N/A N/A N/A N/A 24V-DC








Marathon Petroleum Co., PO: 4100623403, Catlettsburg Cavern Facility, Enclosed Fire Pump Package, Item: 2000SEHH23456, PES Doc.: 9927106422-ENG rev 00





Engine Ratings Baselines

- Engines are rated at standard SAE conditions of 29.61 in. (7521 mm) Hg barometer and 77°F (25°C) inlet air temperature (approximates 300ft. (91.4 m) above sea level) by the testing laboratory (see SAE Standard J1349).
- A deduction of 3 percent from engine horsepower rating at standard SAE conditions shall be made for diesel engines for each 1000 ft. (305 m) altitude above 300 ft. (91.4 m).
- A deduction of 1 percent from engine horsepower rating as corrected to standard SAE conditions shall be made for diesel engines for every 10°F above 77°F (24°C) ambient temperature.

Certified Power

This Cummins Fire Power fire pump driver is built to comply with NFPA-20, and is UL listed and FM approved.

* Subject to change without notification

For additional information, click the hyperlinks below. www.cumminsfirepower.com

Service Information (74000793 - QSB4.5 CM850(CM2850))

Manuals	Service Bu	ulletins	Dataplate	Service 1	Tools	Fault Code Search	Symptom Search
Campaigns TRPs ATCs		ATCs	Related Inf	ormation	Safe	ty	

PRINT PRODUCT/ENGINE/SYSTEM DATAPLATE

Product/Engine/System Dataplate - (Original) VIN:							
Marketing Model Name	Service Model Name	EPA Model Name					
QSB4.5	QSB4.5 CM850(CM2850)	GCEXL0275AAG					
Shop Order	Build Plant	Build Date					
SO23023	CNS - CONSOLIDATED DIESEL CO.	27 May 2016					
Warranty Start Date	ECM Code	Fuel Pump Part #					
Not Available	Z91171	5256608					
Fuel Pump Calibration	Marketing Engine Configuration #	Technical Engine Configuration #					
Not Available	D323001CF01	D323001CX03					
CPL #	Customer Number	Customer Name					
8725	2254	Not Available					

WWW.CUMMINSFIREPOWER.COM **CUMMINS FIRE POWER** A DIVISION OF CUMMINS NPOWER, LLC **DE PERE, WI 54115** MFD. DATE: JUNE MODEL: CFP5E-F10 74000793 SERIAL # YEAR: 2016 RATED SPEED: 1760 HP OUTPUT: 95 SPEED RANGE IF APPLICABLE MIN. HP @ SPEED: MAX HP @ SPEED: HORSEPOWER RATINGS WITHIN THE SPECIFIED SPEED RANGE ARE TO BE DETERMINED BY THE **USE OF LINEAR INTERPOLATION BETWEEN** HORSEPOWERS DEVELOPED AT MINIMUM AND MAXIMUM SPEEDS. INTERNAL COMBUSTION ENGINE FOR DRIVING CENTRIFUGAL FIRE PUMP 19ZG CERTIFIED FOR USE OF SAE DF2 FUEL ONLY PER SAE J313 MAR92 **FACTORY SETTING** 1760 ENGINE SPEED SETTING: OVERSPEED SWITCH SETTING: 9526-02 FIELD SETTING ENGINE SPEED SETTING: 9626-03

ATTACHMENT I SUGGESTED TITLE V DRAFT PERMIT LANGUAGE

1.0 Emission Units and Active R13, R14, and R19 Permits

1.1. Emission Units

Emission Unit ID	Emission Point ID	Emission Unit Description	Year Installed	Design Capacity	Control Device
IS	IE	HF Alley Unit Fugitive Emissions (WV Scope)	1980	NIA	None
<u>2S</u>	<u>2E</u>	Firewater Pump Diesel Engine	<u>2016</u>	<u>95 HP</u>	None

5.0 Firewater Pump Diesel Engine [emission point ID(s): 2E]

5.1. Limitations and Standards

- 5.1.1. If you are an owner or operator and must comply with the emission standards specified in 40 C.F.R. 60, Subpart IIII, you must do the following, except as the permittee except as permitted under 40 C.F.R. §60.4211(g):
 - a. Operate and maintain the stationary CI internal combustion engine and control device according to the manufacturer's emission-related written instructions;
 - b. Change only those emission-related settings that are permitted by the manufacturer; and
 - c. Meet the requirements of 40 CFR Parts 1068, as they apply to you.

[40 C.F.R. §60.4211(a) and 45CSR16]

5.1.2. <u>Maximum hourly emissions calculations based on Table 4 of 40 C.F.R. 60, Subpart IIII as specified in 40 C.F.R. §60.4205(c) are specified in the following table:</u>

<u>Pollutant</u>	<u>Lb/hr¹</u>
Volatile Organic Compounds (VOC) +	<u>0.73</u>
Nitrogen Oxides (NOx)	
Carbon Monoxide (CO)	<u>0.063</u>

¹Based on 3.5 g/HP-hr for NMHC+NOx, 0.30 g/HP-hr for CO, and 95 HP-hr

Owners and operators of stationary CI ICE must operate and maintain stationary CI ICE that achieve the emission standards as required in 60.4205 over the entire life of the engine.

[40 C.F.R. §60.4202(d), 40 C.F.R. §60.4205(c) and 45CSR16]

5.1.3. If you are an owner or operator of a CI fire pump engine that is manufactured during or after the model year that applies to your fire pump engine power rating in table 3 to this subpart and must comply with the emission standards specified in § 60.4205(c), you must comply by purchasing an engine certified to the emission standards in § 60.4204(b), or § 60.4205(b) or (c), as applicable, for the same model year and maximum (or in the case of fire pumps, NFPA nameplate) engine power. The engine must be installed and configured according to the manufacturer's emission-related specifications, except as permitted in paragraph (g) of this section.

[40 C.F.R. §60.4211(c) and 45CSR16]

5.1.4. Beginning October 1, 2010, the permittee with stationary CI ICE with a displacement of less than 30 liters per cylinder that use diesel fuel must use diesel fuel that meets the requirements of 40 CFR 1090.305 for nonroad diesel fuel, except that any existing diesel fuel purchased (or otherwise obtained) prior to October 1, 2010, may be used until depleted.

[40 C.F.R. §60.4207(b) and 45CSR16]

5.1.5. The emergency stationary ICE may be operated according to the requirements in 40 C.F.R. §60.4211(f)(1) through (3). In order for the engine to be considered an emergency stationary ICE under 40 C.F.R. 60, Subpart IIII, any operation other than emergency operation, maintenance and testing, emergency demand response, and operation in non-emergency situations for 50 hours per year, as described in 40 C.F.R. §\$60.4211(f)(1) through (3), is prohibited. If the engine is not operated according to the requirements in 40 C.F.R. §60.4211(f)(1) through (3), the engine will not be considered an emergency engine under 40 C.F.R. 60, Subpart IIII and must meet all requirements for non-emergency engines.

•

- a. There is no time limit on the use of emergency stationary ICE in emergency situations.
- b. The emergency stationary ICE may be operated for any combination of the purposes specified in 40 C.F.R. §§60.4211(f)(2)(i) through (iii) for a maximum of 100 hours per calendar year.

 Any operation for non-emergency situations as allowed by 40 C.F.R. §60.4211(f)(3) counts as part of the 100 hours per calendar year allowed by 40 C.F.R §60.4211(f)(2).
 - Emergency stationary ICE may be operated for maintenance checks and readiness testing, provided that the tests are recommended by federal, state or local government, the manufacturer, the vendor, the regional transmission organization or equivalent balancing authority and transmission operator, or the insurance company associated with the engine. The permittee may petition the Administrator for approval of additional hours to be used for maintenance checks and readiness testing, but a petition is not required if the permittee maintains records indicating that federal, state, or local standards require maintenance and testing of emergency ICE beyond 100 hours per calendar year.
 - Emergency stationary ICE may be operated for emergency demand response for periods in which the Reliability Coordinator under the North American Electric Reliability Corporation (NERC) Reliability Standard EOP-002-3, Capacity and Energy Emergencies (incorporated by reference, see 40 C.F.R. §60.17), or other authorized entity as determined by the Reliability Coordinator, has declared an Energy Emergency Alert Level 2 as defined in the NERC Reliability Standard EOP-002-3.
 - 3. Emergency stationary ICE may be operated for periods where there is a deviation of voltage or frequency of 5 percent or greater below standard voltage or frequency.
- c. Emergency stationary ICE may be operated for up to 50 hours per calendar year in non-emergency situations. The 50 hours of operation in non-emergency situations are counted as part of the 100 hours per calendar year for maintenance and testing and emergency demand response provided in 40 C.F.R. §60.4211(f)(2). Except as provided in 40 C.F.R. §60.4211(f)(3)(i), the 50 hours per calendar year for non-emergency situations cannot be used for peak shaving or non-emergency demand response, or to generate income for a facility to an electric grid or otherwise supply power as part of a financial arrangement with another entity.
 - 1. The 50 hours per year for non-emergency situations can be used to supply power as part of a financial arrangement with another entity if all of the following conditions are met:
 - A. The engine is dispatched by the local balancing authority or local transmission and distribution system operator;
 - B. The dispatch is intended to mitigate local transmission and/or distribution limitations so as to avert potential voltage collapse or line overloads that could lead to the interruption of power supply in a local area or region.
 - C. The dispatch follows reliability, emergency operation or similar protocols that follow specific NERC, regional, state, public utility commission or local standards or guidelines.
 - D. The power is provided only to the facility itself or to support the local transmission and distribution system.
 - E. The permittee identifies and records the entity that dispatches the engine and the specific NERC, regional, state, public utility commission or local standards or guidelines that are being followed for dispatching the engine. The local balancing authority or local transmission and distribution system operator may keep these records on behalf of the permittee.

[40 C.F.R. §60.4211(f) and 45CSR16]

- 5.1.6. If you do not install, configure, operate, and maintain your engine and control device according to the manufacturer's emission-related written instructions, or you change emission-related settings in a way that is not permitted by the manufacturer and you are an owner or operator of a stationary CI internal combustion engine greater than or equal to 100 HP and less than or equal to 500 HP, you must keep a maintenance plan and records of conducted maintenance and must, to the extent practicable, maintain and operate the engine in a manner consistent with good air pollution control practice for minimizing emissions. In addition, you must conduct an initial performance test to demonstrate compliance with the applicable emission standards within 1 year of startup, or within 1 year after an engine and control device is no longer installed, configured, operated, and maintained in accordance with the manufacturer's emission-related written instructions, or within 1 year after you change emission-related settings in a way that is not permitted by the manufacturer.

 [40 C.F.R. §60.4211(g)(2) and 45CSR16]
- 5.1.7. If you are the owner or operator of an emergency stationary CI internal combustion engine that does not meet the standards applicable to non-emergency engines, you must install a non-resettable hour meter prior to startup of the engine.
 [40 C.F.R. §60.4209(a) and 45CSR16]
- **5.2. Monitoring Requirements**

None

5.3. Testing Requirements

None

- **5.4.** Recordkeeping Requirements
 - 5.4.1. If the stationary CI internal combustion engine is an emergency stationary internal combustion engine, the owner or operator is not required to submit an initial notification. Starting with the model years in table 5 to this subpart, if the emergency engine does not meet the standards applicable to non-emergency engines in the applicable model year, the owner or operator must keep records of the operation of the engine in emergency and non-emergency service that are recorded through the non-resettable hour meter. The owner must record the time of operation of the engine and the reason the engine was in operation during that time.

[40 C.F.R. §60.4214(b) and 45CSR16]

5.5. Reporting Requirements

None

5.6. Compliance Plan

None

ATTACHMENT J SUPPORTING EMISSION CALCULATIONS/ESTIMATIONS

Cummins CFP5E-F10 Fire Pump

Driver

4 Cycle; 4 Cylinder

1760 RPM 95 HP

5.1 Gal/hr fuel consumption

138700 btu/gal diesel 0.71 mmbtu/hr 8760 hours

Chemical	Source	g/HP-hr	lb/HP-hr	lb/mmbtu	TPY	lb/hr
VOC	Manufacturer ¹	0.062	0.00014		0.06	0.01
NOx	Manufacturer ¹	2.544	0.00561		2.33	0.53
CO	Manufacturer ¹	0.694	0.00153		0.64	0.15
PM	Manufacturer ¹	0.088	0.00019		0.08	0.02
SO2	AP-42 ²		0.00205		0.85	0.19
Benzene	AP-42 ³			9.33E-04	2.89E-03	6.59E-04
Toluene	AP-42 ³			4.09E-04	1.27E-03	2.89E-04
Xylenes	AP-42 ³			2.85E-04	8.83E-04	2.01E-04
Butadiene	AP-42 ³			3.91E-05	1.21E-04	2.76E-05
Formaldehyde	AP-42 ³			1.18E-03	3.66E-03	8.33E-04
Acetaldehyde	AP-42 ³			7.76E-04	2.40E-03	5.48E-04
Acrolein	AP-42 ³			9.25E-05	2.87E-04	6.53E-05
Naphthalene Polycyclic Aromatic	AP-42 ³			8.48E-05	2.63E-04	5.99E-05
Hydrocarbons ⁴	AP-42 ³			8.33E-05	2.58E-04	5.88E-05

¹ Cummins Fire Power ULSD EPA Tier 3 Emission Data (June 2014)

Neal Propane Cavern Page 1 of 1

² Stationary Internal Combustion Sources: Table 3.3-1 Emission Factors for Uncontrolled Gasoline and Diesel Industrial Engines (10/96)

³ Stationary Internal Combustions Sources: Table 3.3-2 Speciated Organic Compound Emission Factors for Uncontrolled Diesel Engines (10/96)

⁴ PAH excludes Naphthalene





EPA Tier 3 Emission Data Fire Pump NSPS Compliant

CFP5E-F10 Fire Pump Driver

Type: 4 Cycle; In-Line; 4 Cylinder

Aspiration: Turbocharged, Charge Air Cooled

	15 PPM Diesel Fuel																		
Fuel Consumption D2								02 Cycle Exhaust Emissions								Exhaust			
1						Grams per BHP - HR Grams per kW - HR									Temperature		Gas Flow		
R	PM	BHP	Gal/Hr	L/hr	NMHC	NOx	NMHC+NOx	CO	PM	NMHC	NOx	NMHC+NOx	CO	PM	°F	°C	CFM	L/sec	
1	470	84	4.2	15.9											869	465	520	245	
1	760	95	5.1	19.3											777	414	670	316	
1	900	98	4.9	18.5											761	405	711	336	
2	100	101	5.4	20.4	0.062	2.544	2.605	0.694	0.088	0.083	3.411	3.494	0.930	0.117	756	402	774	365	
2	350	105	5.8	22.0											786	419	862	407	
2	600	104	5.9	22.3			l i					1			825	441	905	427	
2	700	95	5.0	18.9											760	404	860	406	

The emissions values above are based on CARB approved calculations for converting EPA (500 ppm) fuel to CARB (15 ppm) fuel.

	300-4000 PPM Diesel Fuel																	
			Fuel Con	sumption	D2 Cycle Exhaust Emissions										Exhaust			
1		ſ				Gra	ms per BHP -	HR			Gr	ams per kW -	HR		Tempe	erature	Gas	Flow
RPN	/	BHP	Gal/Hr	L/hr	NMHC	NOx	NMHC+NOx	CO	PM	NMHC	NOx	NMHC+NOx	CO	PM	°F	°C	CFM	L/sec
1470	0	84	4.2	15.9					0.100	00 0.1	3.700	3.800	0.930	0.134	869	465	520	245
1760	0	95	5.1	19.3											777	414	670	316
1900	0	98	4.9	18.5											761	405	711	336
2100	0	101	5.4	20.4	0.075	2.759	2.834	0.694							756	402	774	365
2350	0	105	5.8	22.0											786	419	862	407
2600	0	104	5.9	22.3											825	441	905	427
2700	0	95	5.0	18.9											760	404	860	406

QSB4.5 Base Model Manufactured by Cummins Inc.

- Using fuel rating 91487

Reference EPA Standard Engine Family: ECEXL0275AAG

Reference CARB Executive Order: U-R-002-0558

No special options needed to meet current regulation emissions for all 50 states

Test Methods:

EPA/CARB Nonroad emissions recorded per 40CFR89 (ref. ISO8178-1) and weighted at load points prescribed in Subpart E, Appendix A, for Constant Speed Engines (ref. ISO8178-4, D2).

Diesel Fuel Specifications:

Cetane Number: 40-48 Reference: ASTM D975 No. 2-D

Reference Conditions:

Air Inlet Temperature: 25°C (77°F) Fuel Inlet Temperature: 40°C (104°F) Barometric Pressure: 100 kPa (29.53 in Hg)

Humidity: 10.7 g/kg (75 grains H_2O/lb) of dry air; required for NOx correction

Restrictions: Intake Restriction set to a maximum allowable limit for clean filter; Exhaust Back Pressure set to maximum allowable limit.

Tests conducted using alternate test methods, instrumentation, fuel or reference conditions can yield different results.

Revisions:

June 2014: Document Review & Approved.

Revision Date: June 2014



UNITED STATES ENVIRONMENTAL PROTECTION AGENCY 2016 MODEL YEAR CERTIFICATE OF CONFORMITY WITH THE CLEAN AIR ACT

OFFICE OF TRANSPORTATION AND AIR QUALITY ANN ARBOR, MICHIGAN 48105

Certificate Issued To: Cummins Inc.

(U.S. Manufacturer or Importer)

Certificate Number: GCEXL0275AAG-009

Effective Date: 11/04/2015

Expiration Date: 12/31/2016

Issue Date: 11/04/2015

Revision Date: N/A

Model Year: 2016

Manufacturer Type: Original Engine Manufacturer

Engine Family: GCEXL0275AAG

Mobile/Stationary Indicator: Stationary **Emissions Power Category:** 75<=kW<130

Fuel Type: Diesel

After Treatment Devices: No After Treatment Devices Installed

Non-after Treatment Devices: No Non-After Treatment Devices Installed

Byron J. Bunker, Division Director

Compliance Division

Pursuant to Section 111 and Section 213 of the Clean Air Act (42 U.S.C. sections 7411 and 7547) and 40 CFR Part 60, and subject to the terms and conditions prescribed in those provisions, this certificate of conformity is hereby issued with respect to the test engines which have been found to conform to applicable requirements and which represent the following engines, by engine family, more fully described in the documentation required by 40 CFR Part 60 and produced in the stated model year.

This certificate of conformity covers only those new compression-ignition engines which conform in all material respects to the design specifications that applied to those engines described in the documentation required by 40 CFR Part 60 and which are produced during the model year stated on this certificate of the said manufacturer, as defined in 40 CFR Part 60.

It is a term of this certificate that the manufacturer shall consent to all inspections described in 40 CFR 1068 and authorized in a warrant or court order. Failure to comply with the requirements of such a warrant or court order may lead to revocation or suspension of this certificate for reasons specified in 40 CFR Part 60. It is also a term of this certificate that this certificate may be revoked or suspended or rendered void *ab initio* for other reasons specified in 40 CFR Part 60.

This certificate does not cover engines sold, offered for sale, or introduced, or delivered for introduction, into commerce in the U.S. prior to the effective date of the certificate.